

ANNEXURE-10 : CHECKLIST FOR OFFER

Sl.No:	Description	Bidders Confirmation [Indicate as Confirm]
1.	Bidder to confirm that offered system (Gas Filter System) is in line with BHEL tender specification	
2.	Documents submitted duly filled up with bidder's signature & stamp. - Signed and stamped copy of Job spec - Signed and stamped copy of Instrument datasheets (Annexure-7). - Signed and stamped copy of MDL (Master Doc. Schedule)/Annexure-15	
3.	<u>Vendor to furnish confirmation against each point.</u> - Bidder to conform compliance with Annexure-1: P&ID enclosed with Technical specification. - Following are considered in bidders scope of supply: - Counter Flanges for all nozzles - Cable Trays - Foundation Bolts - Safety valve - Commissioning Spares as per Annexure-9A - All instrument hook-ups to be considered through impulse piping only. No tubing is acceptable. Bidder to confirm the following Performance of Filter Separator: Liquid removal efficiency 8 microns and larger – 100% 0.5 to 8 microns – 99.5% Solid removal efficiency 3 microns and larger - 100% 0.5 - 3 microns - 99.5% Turndown - 100% Bidder to confirm the following Performance of Fine Filter Skid: Liquid removal efficiency 3 microns and larger – 100% For Less than 3 microns – 99.8% Solid removal efficiency 3 microns and larger - 100% 0.5 - 3 microns - 99.5%	

	Turndown - 100%	
	f) Prefabricated FRP canopy is provided for all Transmitters, positioners and JB's	
	g)	
	h) Piping(material, schedule, pipe to pipe joints, etc.) shall be strictly in line with EIL Pipe Material Specifications as per Annexure-III of tender specification.	
	i) Process or Instrument nozzle on vessel shall be 2" NB minimum as indicated in P&ID	
	j) As per Fuel Gas Analysis, Annexure-4, Skids are designed considering this gas analysis with all cases(Normal & Design/Min. Avg. & Max.). Bidder to confirm.	
	k) Vent & Drain nozzles on vessel shall be 2" NB as indicated in P&ID.	
	l) All the sub vendors shall be as per tender specification and Approved vendor list (Annexure-16) only.	
	m) Bidder to confirm that tapings for vents are taken from top of pipe/vessels and tapping for drains are taken from bottom of pipe/vessels.	
4.	Un priced "price bid format" submitted:- Un priced "price bid format", clearly indicating all the applicable items are quoted, and not applicable items are not quoted.	
5.	Inspection & testing:- Vendor to confirm that Inspection & testing shall be as Clause 7.0 of PY51583	
6.	Press. Tapping & vent and drain Connection:- Vendor to confirm that Pressure tapping shall be as per Annexure-8B Vendor to confirm that vent and drain Connection shall be as per Annexure-8A	
7.	Vendor list: For sub vendor items, Bidder to confirm compliance with vendor list enclosed as per Annexure-16.	
8.	Skid Layout:- Vendor to confirm that Skid layout shall be as per clause 6.0 of PY51583	
9.	Master Document List (MDL): Bidder to confirm that all the documents figuring in MDL as per Annexure- 15 of Technical Specification PY 51583 shall be submitted during detailed engineering.	
10.	Miscellaneous (For Filter Separator) <u>Vendors to ensure that the following have been enclosed along with the offer:</u> a) Filtration area of each element b) No. of elements considered for each filter vessel. c) Delta P across filter in clean installed condition of	

	filter. d) Pressure drop for changeover of filter element (delta P versus dirt holding capacity curve). e) Filter element collapsing pressure drop. f) Solids/liquids holding capacity for Filter Separator-& Fine Filter.	
11.	Any specific deviations, which are impractical, shall be raised in form of pre-bid queries as per Annexure-11 before submission of Techno Commercial offer. Any deviation/ queries raised during technical bid submission shall not be entertained. Bidder to Confirm.	
12.	Completely filled datasheet for Filter Separator/Fine Filter Skids(Annexure-2) is submitted along with bidders offer. Bidder to confirm.	
13.	In case of supplies from outside India, inspection charges for TPI shall be in Bidders Scope. This is as per Annexure-9 Price Bid Format enclosed with Technical Specification, Doc. No. PY 51361. Bidder to confirm.	
14.	If Scrubber Skid is supplied from outside India, Seaworthy packing shall be considered by Bidder and the same is in Bidders scope. Packing details shall be as per Annexure-12(Packing Details) enclosed with Technical Specification, Doc. No. PY 51361. Bidder to confirm.	
15.		

SIGNATURE: _____

NAME: _____

DESIGNATION: _____

COMPANY: _____

DATE: _____