

FRAMEWORK AGREEMENT FOR BUTTERFLY VALVE (STEAM SERVICE)

TECHNICAL SPECIFICATION FOR BUTTERFLY VALVE-STEAM SERVICE

**SPECIFICATION NO. PE-TS-020-100-M016
Rev. No.: 00**



**BHARAT HEAVY ELECTRICALS LIMITED, POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA**

	TECHNICAL SPECIFICATION BUTTERFLY VALVE (STEAM SERVICE) FRAMEWORK AGREEMENT	SPECIFICATION NO. PE-TS-020-100-M016	
		REV. NO.: 00	DATE: 04.08.2017
		SHEET 1 OF 1	

CONTENTS

S No.	SECTION	TITLE	NO. OF SHEETS
1.	SECTION-I	SPECIFIC TECHNICAL REQUIREMENTS	7
2.	SECTION-II	i) DATA SHEET-A ii) QUALITY PLAN iii) ACTUATOR DATA SHEET & WIRING DIAGRAM iv) COMPLIANCE SHEET	2 8 5 1

	TECHNICAL SPECIFICATION BUTTERFLY VALVE-STEAM SERVICE FRAMEWORK AGREEMENT		SPECIFICATION NO. PE-TS-020-100-M016
			REV. NO.: 00 DATE: 04.08.2017
	SHEET 1 OF 1		

SECTION-I

SPECIFIC TECHNICAL REQUIREMENTS

 Maharatna Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 1 of 7	

1. GENERAL

- 1.1 The valves shall meet the technical requirements and conform to the requirements of Section-I and Data sheet-A of Section-II. However, in the event of contradictions between Section-I & Section-II/Data Sheet-A, Data Sheet-A will prevail.
- 1.2 The technical requirements for valves shall, in general, be as per the attached Data sheet A of Section-II.

2. SCOPE OF SUPPLY

- 2.1 The valves complete with all accessories shall be supplied as per Data sheets A of Section-II. For detail refer the same. Each valve (quantity and other details specified in Data Sheet-A) shall be complete with the following accessories.
- i) Lifting arrangement provision for handling i.e., lifting lugs, eye bolts etc.
 - ii) Actuators and limit switches as required to make valve complete in all respects.
- 2.2 Commissioning spares, if any.
- 2.3 Set of special tools and tackles if required for the maintenance, erection etc. of the equipment supplied.
- 2.4 Mandatory spares as applicable depending upon the project requirement.
- 2.5 Finish paints for touch-up painting of equipment after erection at site in sealed containers.

4.0 CODES AND STANDARDS:

The design, manufacture, inspection and testing of the butterfly valves shall suit the design parameters specified in datasheet-A & comply with the requirements of latest revisions of the following standards. However, the testing shall be as per American Water Works Association AWWA C504-10 and C516-10 (whichever is applicable) including disc strength test (all sizes of valves), gear box POD Test & Valve POD test.

- a) AWWA C504-10 upto size 1800 mm.
- b) AWWA C516-10 upto for size 2000 mm and above.

- 4.1 In case of any conflict between the above Codes/Standards and this specification, the later shall prevail and in case any further conflict in this matter, the interpretation of the specification by the BHEL engineer shall be final & binding.

5.0 DESIGN REQUIREMENTS:

- 5.1 All valves shall be suitable for the service conditions i.e. flow, temperature and pressure under which they are required to operate and those performing similar duties shall be interchangeable with each other unless otherwise specified.
- 5.2 The butterfly valves shall be suitable for Indoor/outdoor installation with shaft either in horizontal or vertical position.
- 5.3 The valves shall have min. single off-set type disc (design with shaft eccentric to disc) and long body design for AWWA C504-10 and maximum laying length for AWWA C516-10 as specified in Data sheet-A.
- 5.4 The butterfly valves shall be with butt welded ends as specified in Data sheet-A and designed to ensure bubble tight shut off at the rated pressure of valve.

 बी एच ई एल BHEL Maharaja Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 2 of 7	

5.5 MATERIALS

- 5.5.1 The materials of construction of main parts of the butterfly valves (steam service) shall be specified in Data sheet-A.
- 5.5.2 The materials of construction of the remaining parts shall be as per relevant standard governing the valves and to suit the service conditions. These materials shall be subject to approval of the purchaser.
- 5.5.3 Materials used in manufacture of valves shall be of tested quality.

6.0 CONSTRUCTION FEATURES

6.1 Valve Body

- 6.1.1 The valve body shall have integral hubs for shaft bearing housing. The minimum body shell thickness and minimum diameter of seat bore shall be as per requirement of the applicable table/equation of AWWA-C504-10/C516-10 (whichever is applicable). Material of construction of body and valve parts shall be as per materials indicated in Data sheet-A.
- 6.1.2 An arrow shall be embossed/ engraved and painted on the outside of body to clearly indicate the direction of flow.

6.2 Valve Shaft

- 6.2.1 The shaft of each butterfly valve shall be securely attached to the disc through Bolting, Riveting, threading, upsetting or cross pinning, adequately locked.
- 6.2.2 Valve shaft design shall consist of one piece unit extending completely through the valve disc. or may be the "Stub Shaft" type which consists of two separate shafts inserted into the disc. Each stub shaft shall be inserted into the valve disc hubs for a minimum distance of at least 1.5 times shaft diameter. The connection between the shaft and the disc shall be designed to transmit shaft torque equivalent to at least 75% of the torsional strength of the minimum required shaft diameter. The minimum shaft diameter shall be as per the relevant standard and shall be such that it will safely sustain the maximum differential pressure across the closed valve and transmit the maximum torque required to operate the valve.
- 6.2.3 Surface finish for shaft shall be minimum 16 RMS in the area of gland packing.

6.3 Valve Disc:

The valve disc shall have no external ribs transverse to the flow and shall sustain full differential pressure across closed valve disc without exceeding working stress of one fifth of the tensile strength of the material used. The thickness of the valve disc shall not be more than $2 \frac{1}{4}$ times the shaft diameter listed in AWWA-C504-10/C516-10 (whichever is applicable). The valve disc shall be designed to rotate 90° from full open to tight shut off position. Material of Disc shall be as per the Data sheet-A.

6.4 Body Seat & Disc Seal (Valve seat)

The soft seat shall be of replaceable type of suitable grade resilient material, adequately reinforced, securely attached to the disc or to the body, and shall be designed to provide bubble tight shut off under all operating conditions. The soft seat/ seal shall be attached by clamping ring, bolting or other suitable methods as per the standard design of the

 Maharashtra Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 3 of 7	

manufacturer. All clamping rings, bolts/studs, nuts used shall be of stainless steel. The sealing ring on the disc shall be continuous type and easily replaceable.

The mating seat surface accordingly shall be on valve body or disc and shall be of stainless steel and securely attached to the body/disc by directly clamping, bolting or suitable methods. All clamps, retaining rings, nuts, screws / all hardware shall be of stainless steel.

6.5 Valve Bearing:

Each butterfly valve shall be fitted with sleeve type bearings contained in the hub of the valve body. The bearing shall be of self-lubricating type and the coefficient of friction of bearing material shall not exceed 0.25 when rubbing at the maximum bearing pressure. The housing for this bearing shall be rigidly attached to the valve body. Thrust bearings shall also be provided for vertical shaft installation. For valves of 350 NB and larger, the bearing should be capable of taking axial thrust also. The material of the bearing shall be self-lubricated type & low coefficient of friction in accordance with the relevant standard.

6.6 Shaft Seal:

Wherever the shaft project through the valve body for actuator connection, a shaft seal shall be provided. Shaft seal shall be designed for use of Standard 'O' rings seals and they shall be contained in a removable corrosion resistant recess. Shaft seals shall be designed to allow its replacement without removal of the valve shaft.

The hand wheel shall be of malleable iron or equivalent.

6.8 Body Ends:

These shall be as butt welded as per ASME B 16.25 as specified in Data sheet-A.

6.9 Nameplate:

Each valve shall be fitted with a circular Stainless steel 2mm thick nameplate indicating the valve Tag No. and service description given in Data sheet-A1. All details shall be engraved 1 mm deep and filled with black enamel paint.

6.10 The stops which limit the travel of any valve in the 'Open' or 'Shut' position shall be arranged exterior to the valve body.

6.11 All valves shall be closed by rotating the handwheel in a clockwise direction when looking at the face of the handwheel. The pulling force required on handwheel rim shall not exceed 25 Kgf when operating the valve under full flow and operating pressure. The face of each hand wheel shall be clearly marked with the words 'Open' and 'Shut' with adjacent arrows to indicate the direction of rotation to which each refers.

6.12 Special attention shall be given to the operating mechanism for large size valves in order that quick and easy operation is obtained and maintenance is kept to a minimum.

6.13 Eyebolts shall be provided where necessary to facilitate handling heavy valves or part of valves.

6.14 Wherever practical, valves (including actuator, drive motor, integral bypass etc.) of total weight equal to or greater than 500 Kg shall be provided with suitable lugs to permit direct suspension by hanger rods or direct resting on bottom support, as applicable.

 बी एच ई एल BHEL Maharashtra Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)		SPECIFICATION NO.: PE-TS-020-100-M016	
			SECTION - I	
			REV. NO.: 00	DATE: 04.08.2017
			Sheet 4 of 7	

- 6.15 The valves as well as accessories shall be designed for easy dismantling and maintenance.
- 6.16 The disc shall rotate through 90° from full open to the tight shut position. The disc shall be contoured to ensure the least possible resistance to flow and be suitable for throttling operation. While the disc is in throttled position, the valve shall not create any noise or vibration.
- 6.17 It may be noted that all construction features design and parameters will be governed by AWWA-C504-10 for sizes upto 1800 mm and AWWA-C516-10 for sizes 2000 mm and above.

7.0 SPECIAL FEATURES:

7.1 Gland Sealing Arrangement:

Butterfly valves, provided with gland sealing arrangement, shall be vacuum tested. All valves required with this arrangement shall be provided with G3/8" connection (duly plugged) for water sealing. Sealing water shall be supplied at 4 ata and 50°C unless otherwise specifically indicated for the particular project.

7.2 Motorised Valves:

- 7.2.1 The motorized valves shall be offered with the electric actuators of reputed make observing strict quality control and approved by reputed customers. A particular make and type of actuator shall be designed for the maximum differential working pressure. However, the stall torque of the selected actuators shall be minimum 1.5 times the valve unseating torque requirement at the maximum differential working pressure (design pressure) and required operating time as mentioned in in Datasheet A.

- 7.2.2 Electric actuators shall be mounted directly on the valves.

- 7.2.3 The motors, gearing and disengaging hand wheel shall be adequate to open and close the valve under maximum differential pressure and shall be completely assembled on the respective valve and shop tested before shipment.

Gear box and Electric Actuator shall also meet the inspection & testing requirements of latest revision of AWWA-C504-10 /AWWA C542-10 respectively.


8.0 INSPECTION AND TESTING:-

All inspection & Testing for valve, Gear box and actuators shall be as per the requirements of the relevant standard.

The minimum NDT/testing and inspection requirements for valve, Gear Box, electric actuator etc. shall be as per the attached Quality Plan. However, in case of order, final inspection and testing shall be carried out as per the final approved quality plan without any price implications.

8.1 P.O.D. Tests:

 बी एच ई एल BHEL Maharaja Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 5 of 7	



TEST SET UP

FIG. 1

- a) POD (Proof-of-design) Test as per AWWA-C504-10/C516-10 (whichever is applicable) is required to be carried out for valves. In case the valve POD Test has been done earlier, only Test Report of POD test for same model/ type/size/ rating is required to be submitted for verification.
- b) Gear Box and Electric Actuator shall be designed & tested in accordance with latest editions of AWWA C 504-10(gearbox) and AWWA C 542-10 (actuator) respectively. Gear Box shall be designed to hold the valve disc in intermediate position between full open and full closed position without creeping or fluttering.
- c) For valves designed and manufactured as per AWWA POD shall follow the guidelines of AWWA-C504-10/C516-10 (whichever is applicable) and Actuators shall meet the requirements of POD test of AWWA-C-542-10.
- d) Gear box POD test: - Valve POD and gear box POD tests should be done separately on each one of the valve & the gear box. Gear box POD test shall be done as per the procedure described below or as per the procedure agreed between purchaser & vendor.
- e) Gear box POD Test shall be carried out only at full rated torque of gear box, throughout the full cycle of testing i.e. at no point during each full cycle of testing; the applied torque should be less than the full rated torque of Gear Box. Refer Sketch for Gear Box POD test set up. Dead weight and length of arm shall be so selected that the torque generated at point "C" and "B" shall in no case be less than the full rated torque of the gear box.(refer fig.1)
- f) Irrespective of the requirement of conducting the type tests, the vendor shall submit the reports of the type tests carried out within last five years from the date of placement of Purchase order for respective project (the same will be informed during detail engineering). These reports should be for the tests conducted on the equipment same (model / type/ size / rating) to those proposed to be supplied. Tests should have been conducted at an independent laboratory or should have been witnessed by a client.

These valves are for vacuum service and shall be provided with gland sealing arrangement which shall be vacuum tested with vacuum and helium gas.

9.0 PERFORMANCE GUARANTEE:

 Maharashtra Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 6 of 7	

- 9.1 The vendor shall guarantee the material & workmanship of all components as well as operation of the equipment as per the requirements of the specification.
- 9.2 The vendor shall also guarantee the following for each butterfly valve:
- Pressure drop as per the approved drop vs. opening curve.
 - The valve opening and closing time.

10.0 EXCLUSIONS:

Erection & Commissioning of equipment at site.

11.0 QUALITY ASSURANCE

- 11.1 The items covered under this contract shall be subjected to inspection, testing and quality surveillance. The Inspection Agency shall, at all reasonable times have access to Vendor's works, Quality Control records and all facilities as reasonably required for carrying out the inspection and testing efficiently, and these shall be provided by the vendor free of cost.
- 11.2 The Quality Plan enclosed with this specification specify minimum quality control requirement. During contract stage vendor shall furnish this Quality Plan duly signed & stamped for BHEL approval. Quality plans shall be approved by BHEL and customer. All inspection and testing shall be carried out by BHEL/ BHEL representative and customer (as applicable). In case inspection is by both BHEL and their customer, then the inspection can be carried out jointly or separately, which will be informed later. In case of the foreign bidder, inspection shall be carried out by reputed third party.
- 11.3 The charges for third party inspection (Lloyds, TUV or equivalent) for foreign bidders shall be included in the base price of the item by the bidder. This third party agency shall be approved by BHEL. Bidder to inform the same in the offer and mention the same in Quality Plan.

Note: There may be minor changes in quality plan depending on customer/consultant comments which will have to be accommodated by vendor at no extra cost.

12.0 PAINTING REQUIREMENT:

Surface preparation shall be as per SSPC-SP-3/ Power Tool Cleaning followed by 2 coat of Heat Resistance Aluminium paint to IS 13183 Gr. I or equivalent, paint shade Aluminium and total DFT of paint will be equal to 80 microns minimum.

13.0 PACKING INSTRUCTIONS:

- Each valve shall be drained, cleaned, prepared and suitably protected in such a way so as to minimize the possibility of damage and deterioration during transit and storage.
- The valve has to be dispatched in total assembled form.
- Discs of all valves shall be properly secured while dispatching so that there is no risk of damage to the disc & seat.
- Body ends shall be suitably sealed to protect them against damage during transit and storage.

 Maharashtra Company	SPECIFIC TECHNICAL REQUIREMENTS BUTTERFLY VALVES (STEAM SERVICE)	SPECIFICATION NO.: PE-TS-020-100-M016	
		SECTION - I	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 7 of 7	

- e) Valves with butt-welding ends shall be protected by means of polythene caps/rubber and protectors to prevent damage to ends & also to avoid foreign material entering the valve while shipment & storage.
- f) Valve Tag Nos. shall be incorporated in all the dispatch documents.
- g) Proper care shall be taken to avoid damage to the painted surface during transit.
- h) All the valves shall be packed suitably in wooden cases in order to avoid damage during transit and also during storage at site in tropical climate conditions for a period of 15-18 months.
- i) Vendor to provide the following:
 - Photographs (soft) of Valves duly placed inside the wooden box just before final packing.
 - Photographs (soft) of the wooden box in which the valves have been finally packed just before dispatch.
 Clearance for dispatch of valves will be given only after receiving the photos of valves in satisfactory condition as mentioned in the condition stated above

14.0 SPARES

- a) **Mandatory Spares:** These shall be as per Data Sheet-A.
- b) Order for the spares may be placed simultaneously or otherwise at the option of purchaser.

15.0 DOCUMENTS TO BE SUBMITTED ALONG WITH OFFER

Bidder shall submit the following documents duly filled, signed and stamped along with the bid:

- a) Compliance sheet
- b) Documents as per the list indicated in the NIT.

The above are the only documents which will be used for technical evaluation unless other documents are asked for during technical clarifications. Any other technical document enclosed with the bid shall be ignored for the purpose of technical evaluation. All other documents attached with the specification are for information of the vendor and no comments shall be marked on these

16.0 DOCUMENTS TO BE SUBMITTED AFTER AWARD OF FRAMEWORK AGREEMENT:

- 16.1 Complete cross sectional arrangement of the valve.
- 16.2 Binding dimensions, dismantling clearances & weights.
- 16.3 Bill of material incorporating all the materials of construction of various parts and also specifying the AWWA/IS/BS/ASTM standards to which the materials conform to.
- 16.4 Standard Quality Plan duly signed with bidder's company seal as a token of acceptance by the bidder.

The above drawings/ documents will be considered as reference documents for different projects PO which will be placed later.

	TECHNICAL SPECIFICATION BUTTERFLY VALVE-STEAM SERVICE FRAMEWORK AGREEMENT		SPECIFICATION NO. PE-TS-20-100-M016
			REV. NO.: 00 DATE: 04.08.2017
	SHEET 1 OF 1		

SECTION-II

- DATA SHEET – A
- QUALITY PLAN
- ACTUATOR DATA SHEET & WIRING DIAGRAM
- COMPLIANCE SHEET

	DATASHEET-A BUTTERFLY VALVE (STEAM SERVICE) FRAMEWORK AGREEMENT		SPECIFICATION NO. PE-TS-020-100-M016
			SECTION : II
	REV. NO.: 00		DATE: 04.08.2017
	Sheet 2 of 2		

Material of Construction

SL NO.	PART NAME	MATERIALS
VALVE		
a.	Valve Body Butt welded	ASTM A-216 Gr. WCB
b.	Valve Disc.	ASTM A-216 Gr.WCB
c.	Shaft	ASTM A182 Gr..F304
d.	Disc Seal/Seat	EPDM (70 ~ 75 SHORE 'A')
e.	Valve body seat edge	AISI 316 (WELD OVERLAY/ DEPOSIT)
f.	Seat retaining ring and internal Bolts etc.	SS 304/316
g.	Bearing	SLEEVE TYPE, SELF LUBRICATED
h.	Shaft seal :	'O' RINGS TYPE (65~70 SHORE 'A')
i.	Fasteners (bolts & nuts)	ASTM A193 Gr. B7 (BOLTS) / ASTM A194 Gr. 2H(NUTS)
j.	Hand wheel (actuator)	MALLEABLE IRON (or equivalent)
GEAR BOX		
k.	Main Housing /Cover (Totally enclosed construction)	Cast Iron IS:210 Gr. FG 220/260
l.	Input shaft	13/% Cr SS/ EN8 (~200 BN)
m.	Worm	EN8 (~200 BN)
n.	Worm Wheel	Ductile iron / S.G iron
o.	Hand wheel	Malleable Iron (or equivalent)

Technical Requirement/Data

1. Flow medium : Wet Steam, 2-7% moisture
2. Design pressure drop at max. flow: 0.0002 kg/cm^2 (max.)
3. Flow Velocity (Design) : 100 m/sec.
4. Connecting pipe size (Typical) and material :
 - 4.1 For 2000 NB OD 2032 x 16 thk. And material SA672 Gr. B60 Cl.12/22
 - 4.2 For 1800 NB OD 1829 x 16 thk. And material SA672 Gr. B70
 - 4.3 For 1800 NB OD 1626 x 12 thk. And material SA672 Gr. B70

 QUALITY PLAN				CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT QP NO. . PE-QP-020-100-M024REV. 00 DT. 04.08.2017			SPEC. NO : PE-TS-020-100-M016 SPEC. TITLE STANDARD SPEC. F0E TWO WAY BF VALVE FOR STEAM SERVICE		
SHEET 1 OF 8		SYSTEM STEAM SERVICE		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED			SECTION - VOLUME				
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS	
1. 1.1	MATERIALS BODY, DISC, SHAFT	1 CHEM. COMPOSITION & MECH. PROPERTIES	MA	1) CHEM. TESTS	ONE PER HEAT	APPD DRG/ TECH SPEC	APPD DRG/ TECH SPEC	TEST CERT.	3/2	2 1	
				2) MECH TESTS	ONE PER HEAT & HEAT TREATM- ENT BATCH	APPD DRG/ TECH SPEC	APPD DRG/ TECH SPEC	TEST CERT.	3/2	2 1	
			MA	1. MPI	100%	ASTM E 709	ASME B16.34	NDT REPORT	3/2	2 1	- MPI ON 100% AREA (ACCESSIBLE)
				2. RT	100%	ASME B 16.34	ASME B16.34	NDT REPORT	3/2	2 1	RT ON CHANGE OF SECTION AND BW ENDS OF BODY (RT FILM REVIEW BY BHEL)
			CR	UT	100%	ASTM A388	REFER REMARKS**	INSP REPORT	3/2	2 1	**NORMAL BEAM PROBE OF 20 MM/10 MM DIA AND 2/2.5 MHz SHALL BE USED. USING THIS PROBE THE BACK WALL ECHO SHALL BE SET AT 100% FULL SCREEN HEIGHT(FSH) IN SOUND AREA AT THIS SENSITIVITY LEVEL THE ITEM SHALL BE SCANNED AND ANY DEFECT ECHO MORE THAN 20% FSH IS NOT ACCEPTABLE ALSO ANYWHERE COMPLETE LOSS OF BACK WALL ECHO IS NOT ACCEPTABLE
			MA	VISUAL	100%	MSS SP55	MSS SP55	INSP REPORT	3/2	2 1	
1.2	CLAMP RING	CHEM., MECH PROPS	MA	1) CHEM. TESTS	ONE PER HEAT	APPD DRG/ TECH SPEC	APPD DRG/ TECH SPEC	TEST CERT.	3/2	2 1	

BHEL	PARTICULARS		BIDDER/VENDOR
	NAME		
	SIGNATURE		
	DATE		
			BIDDER'S/ VENDOR'S COMPANY SEAL

QUALITY PLAN				CUSTOMER:		PROJECT : FRAMEWORK AGREEMENT			SPEC. NO : PE-TS-020-100-M016			
SHEET 2 OF 8				VENDOR:		Qp No. . PE-QP-020-100-M024		REV. 00 DT. 04.08.2017		SPEC. TITLE STANDARD SPEC. FOE TWO WAY BF VALVE FOR STEAM SERVICE		
				SYSTEM		STEAM SERVICE		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED			SECTION - VOLUME	
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS		
				2) MECH TESTS	ONE PER HEAT & HEAT TREATM- ENT BATCH	APPD DRG/ TECH SPEC.	APPD DRG/ TECH SPEC	TEST CERT.	3/2	2	1	
1.3	DISC SEAL (FROM VENDOR'S REGULAR & APPROVED SOURCE)	1. VISUAL INSPN	MA	VISUAL	100%	APPD DRG	APPD DRG	INSPN. REPORT LOG BOOK	3/2	2	1	
		2.DIMENSIONS	MA	MEASURE- MENT	100%	APPD DRG	APPD DRG		3/2	2	1	
		3. TENSILE AND HARDNESS FOR VULCANISING	MA	MEASUREM ENT	1/BATCH	MFG TECH.SPEC/ APPD DRG	MFG TECH. SPEC./APPD DRG	TEST CERT	3/2	2	1	
		4. OZONE CRACK RESISTANCE	MA	TESTING	1/BATCH	TECH. SPEC + ASTM D1149	TECH. SPEC + ASTM D1149* AWWA C 504	TEST CERT.	3/2	2	1	SPECIMEN TYPE A, 40 DEG CENTIGRADE FOR 70 HRS
		5. ELONGATION	MA	TESTING	1/BATCH	IS 3400 PART-I	250% MIN.	TEST CERT	3/2	2	1	
		6. BLEED RESISTANCE	MA	TESTING	1/BATCH	SAMPLE TO BE KEPT IN 33% HCL, DM WATER, 48% NaOH FOR 72 HRS.	NO DISCOLOURA TION. WEIGHT GAIN +/-0 TO 2%	TEST CERT CERT	3/2	2	1	
		7. AGEING TEST	MA	TESTING	1/BATCH	TECH. SPEC + IS 3400 PART IV	TECH. SPEC + IS +IS3400 PART IV *	TEST CERT	3/2	2	1	*TEST TEMP. 125 DEG C, TEST DURATION 72 HRS, MAX CHANGE IN TENSILE STRENGTH. 20%. ELOGATION: 20%, ELONGATION: 20%, HARDNESS: 3%
		8. HYDRAULIC STABILITY TEST (AFTER AGEING)	MA	TESTING	1/BATCH	TECH SPEC./ REL STD.	TECH. SPEC./ REL STD.	TEST CERT	3/2	2	1	
BHEL												
					PARTICULARS	BIDDER/VENDOR						
					NAME							
					SIGNATURE							
					DATE	BIDDER'S/ VENDOR'S COMPANY SEAL						

QUALITY PLAN				CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT			SPEC. NO : PE-TS-020-100-M016			
SHEET 3 OF 8				SYSTEM STEAM SERVICE		Qp NO. . PE-QP-020-100-M024		REV. 00 DT. 04.08.2017		SPEC. TITLE STANDARD SPEC. FOE TWO WAY BF VALVE FOR STEAM SERVICE		
						ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED			SECTION - VOLUME			
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS		
		8. WEAR RESISTENCE	MA	TESTING	TYPE TEST	AWWA C-504/ AWWA C-516	NO DAMAGE	TEST REPORT	3/2	2	1	TYPE TEST REPORT WILL BE FURNISHED FOR REVIEW
1.4	FASTENERS ASTM A193 GR B7 ASTM A194 GR2H, GRB8M	1. VERIFICATION OF MAKE, GRADE, REVIEW OF TEST CERTIFICATES 2. DIMENSIONS	MI	VISUAL	100%	TECH. SPEC/ DATA SHEET	TECH. SPEC/ DATA SHEET	INSPN REPORT	3/2	2	1	
			MA	MEASURE- MENT	SAMPL- ING PLAN	APPD DRG	APPD DRG	INSP REPORT	2	2	1	
1.5	OPERATORS											
1.5.1	GEAR OPERATOR											
	A)GEAR, WORM & SHAFT	1. CHEM. COMP. & PHYS PROPERTIES	MA	CHEM & PHYS TEST	1/BATCH	REL V STD/ DATA SHT/ MFG DRG	REL V STD/ DATA SHT/ MFG DRG	TEST CERT	3/2	2	1	
		2. DIMENSIONS	MA	MEASURE- MENT	100%	REL V STD/ DATA SHT/ MFG DRG	REL V STD/ DATA SHT/ MFG DRG	INSP REPORT	3/2	2	1	
		3. HARDNESS	MA	MEASURE- MENT	100%	REL V STD/ DATA SHT/ MFG DRG	REL V STD/ DATA SHT/ MFG DRG	TEST CERT	3/2	2	1	
	B) TORQUE TEST	1. TORQUE TRANSMITTING	MA	TORQUE TEST AT TWICE THE RATED TORQUE	ONE/ TYPE	AWWA C-504/ AWWA C516/ DATA SHT/ MFG DRG.	AWWA C-504/ AWWA C516/ DATA SHT/ MFG DRG..	INSP REPORT*	3/2	1*	-	* VERIFICATION OF TEST REPORT ON GEAR BOX EARLIER CARRIED OUT FOR NTPC PROJECT / REPUTED CUSTOMER (SAME SIZE, MODEL & RATING)
		2. DESIGN VERIFICATION	MA	CYCLE TEST AT FULL	ONE/ TYPE	AWWA-C504/ C516 (at full rated torque of gear	AWWA-C504/ C516 / APPD PROCEDURE	INSP REPORT*	3/2	1*	-	* VERIFICATION OF TEST RECORDS ON GEAR BOX EARLIER CARRIED OUT FOR NTPC
BHEL												
PARTICULARS												
NAME												
SIGNATURE												
DATE												
BIDDER'S/ VENDOR'S COMPANY SEAL												

QUALITY PLAN		CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT		SPEC. NO : PE-TS-020-100-M016				
SHEET 4 OF 8		SYSTEM STEAM SERVICE		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED		SECTION - VOLUME				
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS

				RATED TORQUE OF GEAR BOX		box) / APPD PROCEDURE FOR GEAR BOX MODEL	FOR GEAR BOX					PROJECTS/ REPUTED CUSTOMER (SAME MODEL, SIZE & RATING)
1.6	ELECTRICAL ACTUATOR											
		1. TORQUE TESTING & SETTING OF TORQUE SWITCH	MA	{ } MECH., {} ELEC. {} TESTS	100%	TECH. SPEC./ APPD. DRG./ DATA SHEET/ IS:9334	INSP REPORT	3	2	1		
		2. TRAVEL/STROKE	MA	{ }								
		3. TRAVEL TIME	MA	{ }								
		4. OPERATION OF LIMIT SWITCH	MA	{ }								
		5. MANUAL OPERATION THROUGH HAND WHEEL	MA	{ }								
		6. OPERATION TEST WITH POWER SUPPLY VARIATION ENERGISES TO OPEN/CLOSE	MA	{ }								
		7. IR.HV.IR	MA	{ }								

BHEL	PARTICULARS	BIDDER/VENDOR
	NAME	
	SIGNATURE	
	DATE	
BIDDER'S/ VENDOR'S COMPANY SEAL		

QUALITY PLAN		CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT		SPEC. NO : PE-TS-020-100-M016				
				QP NO. . PE-QP-020-100-M024	REV. 00 DT. 04.08.2017	SPEC. TITLE STANDARD SPEC. F0E TWO WAY BF VALVE FOR STEAM SERVICE				
SHEET 5 OF 8		SYSTEM STEAM SERVICE		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED		SECTION - VOLUME				
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS
		8. .DEGREE OF PROTECTION	MA }		I/TYPE	TECH. SPEC./ APPD. DRG./ DATA SHEET/ IS-9334	TECH. SPEC./ APPD. DRG./ DATA SHEET/ IS-9334	3rd PARTY TEST CERT.	3 - 1	
		9. DESIGN VERIFICATION	MA	TYPE TEST (CYCLE TEST)	1/TYPE	AWWA C504 & AWWA C540	AWWA C504 & AWWA C540	TEST CERT	3/2 1	
2.0	INPROCESS CONTROL:- 1 DIMENSIONS 2. SURFACE DEFECTS	WELDING PROCEDURE AND WELDER PERFORMANCE QUALIFICATION	MA CR	MEASURE- MENT P.T.	100%	MFG DRG	MFG DRG	INSPN. REPORT	2 -- 1	ON MACHINED AREA ONLY.
2.1			100%	ASTM E165	ASME B 16.34 APPENDIX III	INSPN. REPORT	2 1			
2.2	WELDING OVERLAY DEPOSIT		CR	VISUAL MECH. TESTS	100%	ASME IX	ASME IX	INSPN. REPORT	3/2 --	ONLY BHEL / CUSTOMER QUALIFIED WELDERS SHALL BE ENGAGED FOR WELDING WPS SHALL BE SUBMITTED FOR APPROVAL
		CLADDING	MA	DEPTH MEASUREM ENT	100%	MFG. DWG	MFG. DWG	TEST REPORT	2 1	
			MA	SURFACE DEFECT LPI ON WELD OVERLAY AND ADJACENT AREA	100%	ASTM E 165	FREE FROM POROSITY/ CRACK	NDT REPORT	2 1	
2.2.1	SEAT RING	SUB-SURFACE DEFECT	MA	RT/UT	100%	ASME B16.34	ASME B16.34	INSP REPORT	3/2 1	
		SURFACE DEFECTS	MA	LPI	100%	ASTM E165	FREE FROM CRACKS	INSP REPORT	2 1	
2.3	BODY (BUTT WELD ENDS)	SUB-SURFACE DEFECT	CR	MPI	100% ON BW AREA	ASTM A709	ASME B 16.34 APPENDIX III	INSP REPORT	2 1	NOTE-1
		SURFACE DEFECTS	CR	RT	100% ON BW AREA	ASME B16.34	ASME B16.34	RT REPORT	2 1	RT (100%) OF BODY INCLUDING BW ENDS AS PER SL. NO. 1.1
BHEL				PARTICULARS		BIDDER/VENDOR				
				NAME						
				SIGNATURE						
				DATE		BIDDER'S/ VENDOR'S COMPANY SEAL				

 QUALITY PLAN		CUSTOMER:		PROJECT : FRAMEWORK AGREEMENT				SPEC. NO : PE-TS-020-100-M016			
		VENDOR:		QP NO. . PE-QP-020-100-M024				SPEC. TITLE STANDARD SPEC.FOE TWO WAY BF VALVE FOR STEAM SERVICE			
				REV. 00 DT. 04.08.2017							
SHEET 6 OF 8		SYSTEM		STEAM SERVICE		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED				SECTION - VOLUME	
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
									P	W	V
CLAUSE NO.2											
2.4	SHAFT	1. DIMENSION	MA	MEASURE- MENT	100%	MFG DRG	MFG DRG	LOG BOOK	2	--	--
3.1	VERIFICATIO N OF ALL PREVIOUS TESTS AND DOCUMENTS	2.SURFACE DEFECTS	MA	P.T.	100%	ASTM E165	ASME B 16.34 APPENDIX III	INSPN REPORT	2	2	1
		VERIFICATION OF RECORDS	MA	---	100%	TECH SPEC	TECH SPEC	---	2	1	1
3.2	TESTS (HYDRAULIC)	1. BODY TEST	CR	HYDRO TEST	100%	AWWA C-504 / AWWA C-516/ APPD DRG.	NO LEAKAGE	INSP. REPORT	2	1	--
		2. DISC STRENGTH	OR	HYDRO TEST	100%	AWWA C-504 / AWWA C-516/ APPD DRG.	NO DEFORMATION, NO STRUCTURAL DAMAGE TO DISC	INSP. REPORT	2	1	-
		3.SEAT LEAKAGE WITH ACTUATOR (BOTH DIRECTION)	CR	HYDRO/ AIR TEST	100%	AWWA C-504 / AWWA C-516/ APPD DRG.	NO LEAKAGE	INSP. REPORT	2	1	-
		4. PERFORMANCE TEST	CR	PERFORM- ANCE	100%	AWWA C-504* / AWWA C-516 *	SMOOTH OPERATION	INSP. REPORT	2	1	-
*COMPLETE VALVE ASSEMBLY ALONGWITH ACTUATOR SHALL BE											
BHEL			PARTICULARS			BIDDER/VENDOR					
			NAME								
			SIGNATURE								
			DATE			BIDDER'S/ VENDOR'S COMPANY SEAL					

		QUALITY PLAN		CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT QP NO. . PE-QP-020-100-M024REV. 00 DT. 04.08.2017			SPEC. NO : PE-TS-020-100-M016 SPEC. TITLE STANDARD SPEC.FOE TWO WAY BF VALVE FOR STEAM SERVICE				
SHEET 7 OF 8		SYSTEM STEAM SERVICE		CAT E-GO RY		TYPE/METH OD OF CHECK OF CHECK		EXTENT OF CHECK		ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED		SECTION - VOLUME	
S.N O.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CAT E-GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS			
										1) PARTIALLY OPENED 3 TIMES UNDER LOAD (5.25 kg/sqcm) IN HORIZONTAL POSITION ONLY 2) OPERATED 25 CYCLES UNDER NO LOAD IN HORIZONTAL OR VERTICAL POSITION AND FOLLOWING SHALL BE CHECKED i) OPERATING TIME ii) OPERATION OF TORQUE & LIMIT SWITCHES iii) CURRENT DRAWN BY ACTUATORS PROCEDURE SHALL BE SUBMITTED TO BHEL FOR REVIEW.			
		5. GLAND LEAK TEST (TOP GLAND AND BOTTOM FLANGES)	CR	HELIUM LEAK TESTS	100%	MFG APPD PROCEDURE	MFG APPD PROCEDURE	INSP. REPORT	2	1	-		
		6. VACUUM TEST	CR	VACUUM TEST	100%	MFG APPD PROCEDURE	MFG APPD PROCEDURE	INSP. REPORT	2	1	--		
		7.PROOF OF DESIGN TEST (LIFE CYCLE TEST)	CR	CYCLE TEST	AS PER AWWA C 504/ AWWA C 516	APPROVED TEST PROCEDURE / AWWA C504/ AWWA C-516		INSP REPORT	2	1*	1	* VERIFICATION OF TEST REPORTS OF POD TEST ON SAME MODEL/TYPE/SIZE/RATING CARRIED OUT EARLIER FOR ANY BHEL/NTPC/REPUTED CUSTOMER PROJECT WITHIN THE LAST 5 YEARS FROM THE DATE OF BID OPENING OF THIS PROJECT, I.E. 15/12/2015	
4.0	SHIPPING RELEASE												
4.1	FINAL INSPECTION	1. OVERALL DIMENSION 2. DOCUMENTATION REVIEW 3. CLEANLINESS 4. NAMEPLATE	MA	MEAS. REVIEW VISUAL VIAUAL	100% 100% 100% 100%	APPD DRG APPD DRG/ TECH SPEC APPD DRG/ TECH SPEC APPD DRG/ TECH SPEC		INSP REPORT INSP REPORT INSP REPORT INSP REPORT	2 2 2 2	1 1 1 1	- - - -	NOTE-1	
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE			BIDDER'S/ VENDOR'S COMPANY SEAL							

	QUALITY PLAN		CUSTOMER: VENDOR:		PROJECT : FRAMEWORK AGREEMENT QP NO. . PE-QP-020-100-M024 REV. 00 DT. 04.08.2017			SPEC. NO : PE-TS-020-100-M016 SPEC. TITLE STANDARD SPEC. FOF TWO WAY BF VALVE FOR STEAM SERVICE		
	SHEET 8 OF 8	CHARACTERISTICS CHECKED	CAT E- GO RY	TYPE/METH OD OF CHECK	EXTENT OF CHECK	SYSTEM	ITEM: CAST CARBON STEEL BUTTERFLY VALVE SIZE 1600NB, 1800NB/ CLASS 75B and 2000 NB/ CLASS 75 MOTORISED	SECTION - VOLUME		
	S.N O.	COMPONENT/ OPERATION					REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V

5.0	PAINTING	1. SURFACE PREPARATION 2. UNIFORMITY & THICKNESS	MI	VISUAL & MEASURE- MENT	100%	APPROVED DATA SHEET FROM BHEL/ CUSTOMER	REPORT INSP REPORT	2	2	1	
			MI	VISUAL & MEASURE- MENT	100%	-DO-	-DO-	2	2	1	
6.0	PACKING	SOUNDNESS	MI	VISUAL	100%	AS PER TECH SPECIFICATION	(SOFT COPY OF PHOTOGR APHS)	2	2	1	PHOTOGRAPHS OF VALVES PACKING TO BE VERIFIED BY BHEL BEFORE ISSUING MDCC.

NOTES:- CR- CRITICAL MA- MAJOR MI-MINOR
PT-PENETRATION TEST UT- ULTRA SOUND TEST MPI= MAGNETIC PARTICAL EXAMINATION
1-BHEL (PURCHASER)/CUSTOMER 2- VENDOR (MAIN) 3- SUB-VENDOR OF VENDOR
ALL MATERIALS SHALL BE AS PER APPROVED DRGS/ DATA SHEET FOR VALVES.

NOTE: ALL THE NDT TEST PROCEDURES SHALL BE AS PER ASME B 16.34

Note-1: BW ends to be machined after final tests (3.2), documents related to BW ends shall be reviewed by BHEL & customer after final inspection and subsequent machining.

Note-2: After the BW end preparation the test carried out are MPI (as per QP clause No. 2.3) and dimension check (As per QP clause no. 4.1.1).

BHEL	PARTICULARS	BIDDER/VENDOR
	NAME	
	SIGNATURE	
	DATE	
		BIDDER'S/ VENDOR'S COMPANY SEAL

	SPECIFICATION FOR MOTORISED VALVE ACTUATOR BUTTERFLY VALVE(STEAM SERVICE) FRAMEWORK AGREEMENT		SPECIFICATION NO.: PE-TS-020-145-1007	
			SECTION II	
			REV. NO. 00	DATE: 04.08.2017
			SHEET 1	OF 3
Data Sheet A & B				
DATA SHEET-A (TO BE FILLED BY PURCHASER)			DATA SHEET-B (TO BE FILLED-UP BY BIDDER)	
GENERAL *	* PROJECT	FRAMEWORK AGREEMENT		
	OFFER REFERENCE			
	* TAG NO. SERVICE			
	* DUTY	☒ ON / OFF ☐ INCHING		
	* LINE SIZE (inlet/outlet): MATERIAL	AS PER DATASHEET-A	AS PER DATASHEET-A	
	* VALVE TYPE	☐ GLOBE ☐ GATE ☐ REG. GLOBE ☒ BUTTERFLY		
	* OPENING / CLOSING TIME	AS PER DATASHEET-A	AS PER DATASHEET-A	
	* WORKING PRESSURE			
	AMBIENT CONDITION	SHALL BE SUITABLE FOR CONTINUOUS OPERATION UNDER AN AMBIENT TEMP. OF 0-55 DEG C AND RELATIVE HUMIDITY OF 0-95%		
	VALVE SEAT TEST PRESS	BIDDER TO SPECIFY		
	REQUIRED VALVE TORQUE	BIDDER TO SPECIFY		
	ACTUATOR RATED TORQUE	BIDDER TO SPECIFY		
CONSTRUCTION AND SIZING	CONSTRUCTION	TOTALLY ENCLOSED, WEATHER PROOF, IP:68		
	MECHANICAL POSITION INDICATOR	TO BE PROVIDED FOR 0-100% TRAVEL		
	BEARINGS	DOUBLE SHIELDED, GREASE LUBRICATED ANTI-FRICTION.		
	GEAR TRAIN FOR LIMIT SWITCH/TORQUE SWITCH OPERATION	METAL (NOT FIBRE GEARS). SELF-LOCKING TO PREVENT DRIFT UNDER TORQUE SWITCH SPRING PRESSURE WHEN MOTOR IS DE-ENERGIZED.		
	SIZING	OPEN/CLOSE AT RATED SPEED AGAINST DESIGNED DIFFERENTIAL PRESSURE AT 85% OF RATED VOLTAGE. FOR ISOLATING SERVICE THREE SUCCESSIVE OPEN-CLOSE OPERATIONS OR 15 MINS. WHICHEVER IS HIGHER		
HANDWHEEL	* REQUIRED	☒ YES ☐ NO		
	* ORIENTATION	☐ TOP MOUNTED ☐ SIDE MOUNTED		
	*TO DISENGAGE AUTOMATICALLY DURING MOTOR OPERATION.			
ELECTRIC ACTUATOR	ACTUATOR MAKE/MODEL	BIDDER TO SPECIFY		
	MOTOR MAKE / MODEL / TYPE / RATING (KW)	BIDDER TO SPECIFY		
	@ MOTOR TYPE	SQUIRREL CAGE INDUCTION MOTOR, STARTING CURRENT LIMITED TO SIX TIMES THE RATED CURRENT- INCLUSIVE OF I.S. TOLERANCE		
	ACTUATOR APPLICABLE WIRING DIAGRAM	☒ ENCLOSED (BIDDER TO CONFIRM) A: ☐ DRG. NO. 3-V-MISC-24227 R00 B: ☐ DRG. NO. 3-V-MISC-24283 R00 THE ABOVE WIRING DIAGRAMS ARE TYPICAL. THE TYPE OF WIRING DIAGRAM WOULD BE DECIDED DURING DETAIL ENGINEERING, SINCE IT IS PROJECT SPECIFIC. HOWEVER, NO COST IMPLICATION SHALL BE ENTERTAINED.		
	COLOUR SHADE**	☐ BLUE (RAL 5012) ☐ ...		
	PAINT TYPE (## Refer Notes)	☐ ENAMEL ☒ EPOXY ☐		
	SHAFT RPM	BIDDER TO SPECIFY		
	OLR SET VALUE	BIDDER TO SPECIFY		
	@ STARTING / FULL LOAD CURRENT	BIDDER TO SPECIFY		
	NO. OF REV FOR FULL TRAVEL	BIDDER TO SPECIFY		
	@ PWR SUPP TO MTR / STARTER**	415V, 3PH, AC, 3 wire or 4 wire		
	@ CONTROL VOLTAGE REQUIREMENT	TO BE DERIVED FROM THE POWER SUPPLY TO THE STARTER ☐ 230 V ☐ 110 V		

☒ - THIS MEANS APPLICABLE

** IT WOULD BE DECIDED DURING DETAIL ENGINEERING, SINCE IT IS PROJECT SPECIFIC. HOWEVER, NO COST IMPLICATION SHALL BE ENTERTAINED.

		SPECIFICATION FOR MOTORISED VALVE ACTUATOR BUTTERFLY VALVE(STEAM SERVICE) FRAMEWORK AGREEMENT		SPECIFICATION NO.: PE-TS-020-145-1007	
				SECTION II	
				REV. NO.	DATE:
				SHEET	OF
		00	04.08.2017	2	3
Data Sheet A & B					
DATA SHEET-A (TO BE FILLED BY PURCHASER)				DATA SHEET-B (TO BE FILLED-UP BY BIDDER)	
	@ ENCLOSURE CLASS OF MOTOR	☒ IP 68 ☐ FLAME PROOF			
	@ INSULATION CLASS	CLASS-F TEMP. RISE LIMITED TO CLASS-B			
	@ WINDING TEMP PROTECTION	☒ THERMOSTAT (3 Nos., 1 IN EACH PHASE) ☐ _____			
	SINGLE PHASE / WRONG PHASE SEQUENCE PROTECTION	REQUIRED			
INTEGRAL STARTER	INTEGRAL STARTER	☒ REQUIRED ☐ NOT REQUIRED			
	TYPE OF SWITCHING DEVICE	☒ CONTACTORS ☐ THYRISTORS			
	TYPE	☒ CONVENTIONAL ☐ SMART (NON-INTRUSIVE)			
	IF SMART				
	— a) SERIAL LINK INTERFACE	☐ INTEGRAL ☐ FIELD MOUNTED			
	— b) SERIAL LINK PROTOCOL	☐ FOUNDATION FIELD BUS ☐ PROFI-BUS ☐ DEVICE NET ☐			
	— c) SERIAL LINK MEDIA	☐ TWISTED PAIR Cu-CBL ☐ CO-AXIAL Cu-CBL ☐ OFC			
	— d) HAND HELD PROGRAMMER	☐ REQUIRED ☐ NOT REQUIRED			
	— e) TYPE OF HAND HELD PROGRAMMER	☐ BLUETOOTH ☐ INFRARED ☐			
	— f) MASTER STATION	☐ REQUIRED ☐ NOT REQUIRED			
	— g) MASTER STN INTRFACE WITH DCS	☐ MODBUS ☐ TCP/IP			
	— h) DETAILS OF SPECIAL CABLE	☐ ENCLOSED ☐ NOT REQUIRED			
	STEP DOWN CONT. TRANSFORMER	☒ REQUIRED			
	OPEN / CLOSE PB	☒ REQUIRED ☐ NOT REQUIRED			
	STOP PB	☒ REQUIRED ☐ NOT REQUIRED			
	INDICATING LAMPS	☒ REQUIRED ☐ NOT REQUIRED			
	LOCAL REMOTE S/S	☒ REQUIRED ☐ NOT REQUIRED			
	STATUS CONTACTS FOR MONITORING	☒ REQUIRED ☐ NOT REQUIRED			
	INTEGRAL STARTER DISTURBED SIGNAL	REQUIRED (MOTOR THERMOSTAT TRIP , O/L RELAY OPERATED, CONT./POWER SUPPLY FAILED, PHASE LOSS, S/S IN LOCAL or OFF MODE, STOP PB OPTD, TORQUE OPEN/CLOSE CUTOFF)			
	INTERPOSING RELAY/OPTO COUPLER (Applicable for integral Starter)	TYPE OF ISOLATING DEVICE**	☐ INTERPOSING RELAY ☐ OPTO COUPLER ☒ EITHER TO BE DECIDED		
QUANTITY		☒ 2 NOs. ☐ 3 NOs.			
DRIVING VOLTAGE		☒ 20.5 – 24V DC ☐ _____ V DC			
DRIVING CURRENT		☒ 125mA MAX ☐ _____ mA MAX			
LOAD RESISTANCE		☒ > 192 ohms - <25 k ohms ☐ > _____ ohms - < _____ ohms			
TORQUE SWITCH (Not Applicable for Smart Actuator) (\$\$ Refer Notes)	MFR & MODEL NO.	BIDDER TO SPECIFY			
	OPEN / CLOSE	☒ 1 No. ☐ 2Nos. / ☒ 1 No. ☐ 2Nos			
	CONTACT TYPE	2 NO + 2 NC			
	RATING	5A 240V AC AND 0.5A 220V DC			
	CALIBRATED KNOBS(OPEN&CLOSE TS)	REQUIRED FOR SETTING DESIRED TORQUE			
	ACCURACY	+3% OF SET VALUE			
LIMIT SWITCH (Not Applicable for Smart Actuator) (\$\$ Refer Notes)	MFR & MODEL NO.	BIDDER TO SPECIFY			
	OPEN : INT : CLOSE	☒ 1 No. ☐ 2 Nos.	2 Nos. (ADJ.)	☒ 1 No. ☐ 2Nos.	
	CONTACT TYPE	2 NO + 2 NC			
	RATING (AC / DC)	5A 240V AC AND 0.5A 220V DC			

☒ - THIS MEANS APPLICABLE

** IT WOULD BE DECIDED DURING DETAIL ENGINEERING, SINCE IT IS PROJECT SPECIFIC. HOWEVER, NO COST IMPLICATION SHALL BE ENTERTAINED.

	SPECIFICATION FOR MOTORISED VALVE ACTUATOR BUTTERFLY VALVE(STEAM SERVICE) FRAMEWORK AGREEMENT		SPECIFICATION NO.: PE-TS-020-145-1007	
			SECTION II	
			REV. NO. 00	DATE: 04.08.2017
			SHEET 3	OF 3

Data Sheet A & B

DATA SHEET-A (TO BE FILLED BY PURCHASER)	DATA SHEET-B (TO BE FILLED-UP BY BIDDER)
---	---

POSITION TRANSMITTER	POSITION TRANSMITTER (For inching duty & other specific applications)	☒ REQUIRED ☐ NOT REQUIRED	
	MFR & MODEL NO.	BIDDER TO SPECIFY	
	TYPE	☐ ELECTRONIC (2 WIRE) R/I CONVERTER ☒ ELECTRONIC (2 WIRE) CONTACTLESS	
	SUPPLY	☒ 24V DC ☐	
	OUTPUT	☒ 4-20mA	
	ACCURACY	$\pm 1\%$ FS	
SPACE HEATER	@SPACE HEATER	REQUIRED	
	@ POWER SUPPLY (NON-INTEGRAL)	230V AC, 1 PH., 50 Hz	
	@ POWER SUPPLY (INTEGRAL)	BIDDER TO SPECIFY	
	@ RATING		
TERMINAL BOX	ACTUATOR/MOTOR TERMINAL BOX	REQUIRED	
	ENCL CLASS ACTUATOR/MOTOR T.B.	@ ☒ IP 68 @ ☐	
	@ EARTHING TERMINAL	REQUIRED	
	PLUG & SOCKET** (FOR COMMD, LS/TS FEED BACK, PoT)	☐ REQUIRED ☐ NOT REQUIRED ☐ 2 NOS. ☐	
CABLE GLANDS	@ POWER CABLE GLAND	SIZE AND NOS. ARE PROJECT SPECIFIC AND WILL BE INFORMED LATER. HOWEVER, NO COST IMPLICATION SHALL BE ENTERTAINED.	
	@ SPACE HEATER CABLE GLAND		
	OTHER CONTROL CABLE GLANDS-1		
	OTHER CONTROL CABLE GLANDS-2		
WEIGHT	TOTAL WEIGHT (ACTUATOR + ACCESSORIES)	BIDDER TO SPECIFY	_____ Kg.

NOTES:

- SCOPE:** DESIGN, MANUFACTURE, INSPECTION, TESTING AND DELIVERY TO SITE OF ELECTRIC ACTUATOR FOR INCHING OR OPEN / CLOSE DUTY.
- CODES & STANDARDS:** DESIGN AND MATERIALS USED SHALL COMPLY WITH THE RELEVANT LATEST NATIONAL AND INTERNATIONAL STANDARD. AS A MINIMUM, THE FOLLOWING STANDARDS SHALL BE COMPLIED WITH:
IS-9334, IS-2147, IS-2148, IS-325, IS-2959, IS-4691 AND IS-4722
- TEMPERATURE RISE SHALL BE RESTRICTED TO 70 DEG. C FOR AMBIENT TEMPERATURE OF 50 DEG C.
- CABLE GLANDS OF DOUBLE COMPRESSION TYPE, BRASS MATERIAL SHALL BE PROVIDED.
- THE TORQUE SWITCHES SHALL BE PROVIDED WITH MECHANICAL LATCHING DEVICE TO PREVENT OPERATION WHEN UNSEATING FROM THE END POSITIONS. THE LATCHING DEVICE SHALL UNLATCH AS SOON AS THE VALVE LEAVES THE END POSITION. IF SUCH PROVISION IS NOT POSSIBLE, THE TORQUE SWITCHES SHALL BE BYPASSED BY END-POSITION LIMIT SWITCHES WHICH OPENS ON VALVE LEAVING END POSITION. THESE LIMIT SWITCHES ARE ADDITIONAL TO THE NUMBER OF LIMIT SWITCHES SPECIFIED ELSEWHERE.
- THE MOTOR SHALL OPERATE SATISFACTORILY UNDER THE +/- 10% SUPPLY VOLTAGE VARIATION AT RATED FREQUENCY, -5% TO +3% VARIATION IN FREQUENCY AT RATED SUPPLY VOLTAGE, SIMULTANEOUS VARIATION IN VOLTAGE & FREQUENCY THE SUM OF ABSOLUTE PERCENTAGE NOT EXCEEDING 10%.
- THE MOTOR SHALL BE SUITABLE FOR DIRECT ON LINE STARTING.
- ACTUATOR SHALL HAVE HARDWIRED CONTACTS FOR FOLLOWING SIGNALS (a) ACTUATOR IN LOCAL MODE (b) ACTUATOR IN REMOTE MODE
- 2 No. OF EARTHING TERMINALS SHALL BE PROVIDED FOR THE MOTOR BODY EARTHING.

\$\$ TORQUE SWITCH & LIMIT SWITCH SHALL ACT INDEPENDENT OF EACH OTHER. TANDEM OPERATION IS NOT ACCEPTABLE.

NAME SIGNATURE DATE	PREPARED BY	CHECKED BY	APPROVED BY	VENDOR COMPANY SEAL NAME SIGNATURE DATE


NOTES* = TO BE FILLED BY MPL (LEAD AGENCY). @ = TO BE FILLED BY ES

☒ - THIS MEANS APPLICABLE

** IT WOULD BE DECIDED DURING DETAIL ENGINEERING, SINCE IT IS PROJECT SPECIFIC. HOWEVER, NO COST IMPLICATION SHALL BE ENTERTAINED.

ALL DIMENSIONS ARE IN MILLIMETRES. FOR TOLERANCES OF UNTOLERANCED DIMENSIONS DURING MANUFACTURE REFER RELEVANT QCP / QP.

DRAWING NO. 3-V-MISC-24227



NOTE:-

1. ALL TORQUE AND LIMIT SWITCHES (OTS,CTS,OLS1&2, CLS1&2) ARE WITH 2NO+2NC CONTACTS '1NO+1NC' IS TERMINATED IN TBS 1-24, REMAINING CONTACTS ARE FOR INTERNAL USE. ANY SPARE CONTACTS WHICH ARE NOT USED INTERNALLY ARE TO BE TERMINATED IN TBS 25-32
2. CTS - TORQUE SWITCHES FOR CW ROTATION (CLOSE)
3. OTS - TORQUE SWITCHES FOR CCW ROTATION (OPEN)
4. OLS-1, OLS-2 - LIMITSWITCHES FOR POSITION OPEN
5. CLS-1, CLS-2 - LIMITSWITCHES FOR POSITION CLOSE
6. EPT - ELECTRONIC POSITION TRANSMITTER (POTENTIOMETRIC TYPE, FOR INCHING DUTY)
7. R1-R2-POTENTIOMETER 2 x 100 OHMS (FOR ON-OFF DUTY)
8. FOR COMMANDS & EPT EITHER INTERNALLY GENERATED 24 VDC OR EXTERNAL SUPPLY OF 24VDC CAN BE USED
9. M - MOTOR 3Ø 415V 50 Hz AC SUPPLY

SWITCH TERMINALS FOR CUSTOMER USE

CONTACT DEVELOPMENT DIAGRAM

OTS	1-2	OPEN AT OVER TORQUE DURING OPENING TRAVEL
	3-4	CLOSE AT OVER TORQUE DURING OPENING TRAVEL
CTS	5-6	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
	7-8	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL
OLS-1	9-10	OPEN
	11-12	STOP
CLS-1	13-14	CLOSE
	15-16	COMMON
OLS-2	17-18	OPEN
	19-20	STOP
CLS-2	21-22	CLOSE
	23-24	COMMON
SWITCH NO.	TERMINAL NO.	FULL OPEN
	INTERMEDIATE	b FULL CLOSE

INDICATES CONTACT CLOSED
INDICATES CONTACT OPEN

CONTACT RATING: 5A AT 250V AC & 0.5A AT 220V DC

VALVES	OPEN			CLOSE		
	MAIN	BACK UP	MAIN	BACK UP	MAIN	BACK UP
GATE VALVE OF 100 mm AND ABOVE IN 1500 CL AND ABOVE RATINGS	OLS	OTS *	CLS	OTS	CLS	CTS
ALL OTHER GATE & GLOBE VALVES	OLS	OTS *	CLS	OTS	CLS	CTS
# - CLS NOT TO BE CONNECTED IN TRIP CIRCUIT						
* - BYPASS OTS FOR INITIAL 5% OF TRAVEL (FOR GATE VALVES ONLY)						

TYPE OF PRODUCT ELECTRICAL VALVE ACTUATORS (AC) WITH INTEGRAL STARTERS
OR NAME OF CUSTOMER/PROJECT (DRAWN FOR INTERMEDIATE POSITION OF VALVES)




BHARAT HEAVY ELECTRICALS LTD.,
UNIT: HIGH PRESSURE BOILER PLANT,
TIRUCHIRAPPALLI-620014.

DEPT	VL	SCALE	WEIGHT (KG)	REFERENCE INFORMATION	DATE	NO OF VAR
365-121					07.10.04	
CODE					07.10.04	
TITLE					07.10.04	

WIRING DIAGRAM (TERMINAL PLAN)	CARD CODE	DRAWING NO.	REV
FOR ACTUATOR WITH INTEGRAL STARTER	U 01	3-V-MISC-24227	0

ALL DIMENSIONS ARE IN MILLIMETRES. FOR TOLERANCES OF UNTOLERANCED DIMENSIONS DURING MANUFACTURE REFER RELEVANT QCP / QP.



	COMPLIANCE SHEET BUTTERFLY VALVE- STEAM SERVICE FRAMEWORK AGREEMENT	SPECIFICATION NO. PE-TS-20-100-M016	
		SECTION : II	
		REV. NO.: 00	DATE: 04.08.2017
		Sheet 1 of 1	

I hereby comply/not comply (*) to all the requirements of this technical specification in totality.

* In case the bidder does not comply to the technical specification, the deviations shall be explicitly listed in the technical deviation sheet of GCC. Deviations listed in technical deviation sheet shall only be considered.

Name of Bidder / Authorized Representative :-

Designation :-

Signature :-

Company Seal :-

Date :-

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	
				COMPANY SEAL