

**AMC OF BRY-AIR AIR AND GAS PURIFICATION SYSTEM**

SPECIFICATION NUMBER: PE888S-AF-356 REV. 00

**BHARAT HEAVY ELECTRICALS LIMITED**



**SCOPE & TECHNICAL SPECIFICATION**

**FOR**

**AMC OF BRY-AIR AIR AND GAS PURIFICATION SYSTEM**  
**(Model- BPU-500-T-V-2)**

**TECHNICAL SPECIFICATION NO.: PE888S-AF-356**  
**REV. 00**

**DTG DEPARTMENT**  
**22<sup>nd</sup> FEBRUARY'20**



# AMC OF BRY-AIR AIR AND GAS PURIFICATION SYSTEM

SPECIFICATION NUMBER: PE888S-AF-356 REV. 00

## TECHNICAL SPECIFICATION FOR AMC OF ONE NO. OF BRY-AIR AIR AND GAS PURIFICATION SYSTEM (MODEL- BPU-500-T-V-2).

### **SCOPE:**

- Rectification of all faults including the replacement of faulty parts throughout the contract period.
- Newness certificate must be provided for all the replacement part.
- Quarterly preventive maintenance including collection of media samples every quarter and lab analysis.
- All the issues must be closed within seven (7) BHEL working days from the date of intimation via e-mail, failing which a penalty of ₹ 100/- per BHEL working day will be levied beyond seven (7) BHEL working days.
- Total penalty shall be limited to 10% of the total contract value excluding taxes.

### **PQR:**

- Bidder should have completed similar type of AMC work of air and gas purification system during last 3 years ending on the month in which enquiry is invited. Bidder shall submit supporting document for the same.
- Bidder should have a minimum of two years of experience in the service/maintenance of Air and Gas Purification system.

