



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

- n) Supply air diffusers/ grilles (Frame and Louvers of Diffuser/Grilles shall be of at least 20 SWG GI sheet and 22 SWG M.S. No grilles should by any chance make any rattling sound during continuous operation. All grilles shall match the decor of the space duly powder coated) with volume control dampers.
- o) 1 x 100% capacity Fresh Air Unit consisting of Air Inlet Louver with Bird Screen, Dry panel HDPE filters, Tube Axial Flow Fan with Drive Motor, Volume control damper, Supports and supporting structures etc. shall be provided for AHU Room. A differential pressure sensor shall be provided across each set of filters to initiate alarm when the pressure difference across the filters exceeds a pre-determined value, warranting cleaning/ replacement of filters.
- P) MS brackets, M.S. frame & PVC drain piping for indoor & outdoor units respectively and fixing hardware like anchor bolts, nuts, fittings etc. as would be necessary for installation of above equipment shall be provided by the contractor.

1.1.4 OPERATION PHILOSOPHY

The Precision Air Conditioners shall be operated from the respective unit mounted microprocessor based control console.

i. The Precision Air Conditioners shall have following operating controls:

- ON/ OFF thermostatic control of the compressor of Precision Air Conditioners to maintain the desired room temperature.
- Room RH control (wherever required) with the help of humidifier & heater installed within AC units getting sense from the humidistat placed in the return air path.

ii. The compressor of each Precision Air Conditioner shall be incorporated with the following safety controls and interlocks:

- High refrigerant pressure cutout.
- Low refrigerant pressure cutout.
- Cutout due to overload of all drive motors.
- Stopping of evaporator fans in case of fire in the respective zone.
- Closing of fire dampers at the supply duct from Precision Air Conditioners in case of fire with the sense from duct/ room mounted fire/ smoke detector through zonal fire panel.

iii. Interlocks

The system components shall be interlocked with one another in the following way:

The compressor shall not start unless:

- The condenser fans are running.
- The evaporator fans are running.

iv. The electric strip heater shall not be energized unless the respective evaporator fans are running. The Strip heaters will trip with the help of safety thermostat in case the temperature of air at the downstream side of the heaters exceeds a pre-determined value.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

- **Equipment Specification shall be as per TSGENCO Technical specification attached as Annexure III to Sec-II, Sub Section C1.**

1.1.5 CONTROL PHILOSOPHY OF THE PRECISION AC SYSTEM OF SWITCHYARD CONTROL BUILDING

One no. PLC (RIO) panel with operator's engineering cum workstation (OWES) shall be provided in the switchyard control building for control and monitoring of switchyard Air conditioning system. This RIO panel will be an extended node to main PLC's of Air conditioning system situated in main plant local AHU control room of TG1 and TG2 buildings i.e. Unit 1 & 2, Stage#1 AHU Control Room & Unit 3 & 4, and Stage #2 AHU Control Room. This RIO panel and HMI shall derive supply from the same UPS provided to main PLC's. Necessary ACDB's (redundant) needs to be provided.

This RIO panel shall be networked with both stage PLC's of Air conditioning system in both stage#1 & stage#2 plants.

Fiber optic cable, patch cords, converters at both the ends shall be in contractor's scope. Field instruments redundancy shall be as per specification.

All the technical specifications of PLC RIO panel shall be same as that of PLC RIO panel provided in the main plant portion of this tender. These panels shall comply to **C&I Technical specification of AC system, in Sec-I, Sub Section C4 of this specification.**

1.1.6 ELECTRICAL REQUIREMENTS FOR AC SYSTEM

One (1) no. drawn-out type HVAC power distribution board (PDB) for extending power supplies to precision packaged units, fresh air fan, fire dampers and ventilation fans of cable spreader room, battery room & LT switchgear room shall be provided. The same will be located in AC plant room. Two nos. incomers of suitable capacity, 3 ph. 4-wire rating will be provided for HVAC power distribution panel with an electrical changeover switch.

PDB shall have suitable provisions to be compatible with plant PLC based control system for control & monitoring of vital AC signals from remote location.

20% spare feeders (of each type & rating) shall be provided in the PDB as per customer specification.

The purchaser will provide 3-ph. power supply points for cassette AC units.

Interlocking of PDB shall be done with Fire Alarm Panel to trip HVAC system in case of fire and actuate the fire dampers.

This panel in scope shall comply all concerned requirements of TSGENCO specification for 415 Switchgear provided as Annexure III to Sec-II, Sub Section C1.

PLC RIO panel to be placed in switchyard control room shall derive its DC supply from the UPS package meant for entire PLC system of the main plant.

All required instruments, transducers, switches required for control & monitoring of vital air conditioning system shall be provided.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

1.1.7 MANDATORY SPARES (SWITCHYARD AIR CONDITIONING SYSTEM)

Following mandatory spares shall be provided:

S. No.	Item	Unit	Qty
I	Mandatory Spares		
A	Precision AC units		
1	Pre filters for PAC unit	Set	2
2	Bearing for outdoor unit and indoor unit	Set	2
3	Expansion valve	Set	2
4	Refrigerant gas in non-returnable cylinder	Lot	2
B	Cassette AC unit		
5	Vibration Isolators.	Set	2
6	Filters	Set	2
7	Expansion valve	Set	2
8	Fan - motor bearing for outdoor unit.	Set	2
C	Electrical Spares		
9	Control, Isolating and selectors switches (of each type & rating)	Set	2
10	MCB/ MCCB (of each type & rating)	Set	2
11	Indicating Lamps	Lot	2
12	Indicating Lamps cover of different color and holders	Lot	2
13	Push Buttons of various colors	Lot	2
14	Terminal Blocks	Lot	2
D	PLC RIO Panel		
15	Network cards, Communication Interface cards	10% for each type or but minimum 2 no.	
16	I/O Cards (Each type)	40% for each type or but minimum 2 no.	
19	Power Supply Modules & Power Packs for control system	10% for each type and range but min 2 no.	
20	Network Items (Network switch/ LIU unit/ Transceiver/ FO patch cord etc.)	20% of total nos. used for each type and model in the system or min 4(four) no. whichever is more.	
21	MCB (Miniature case circuit breaker)	2 Nos. for each type and rating.	
22	Fuses	200% or min 10 no's for each type and rating	
23	Racks for housing I/O & Processor Modules	1(One) no. each type used in the system	
24	Prefab interconnecting cables with connectors	10% of total nos. used in the system for each type.	
25	Network communication cable with end connectors	10% of total nos. used in the system for each type.	
26	I/O bus cables with connectors for remote I/O units	1 no. of each type & length	

2.0.0 SCOPE

The requirement(s) mentioned under this clause are indicative and minimum for the system. Any other item / service required to complete the work for safe and sound operation of system shall be provided and installed by the bidder at no extra cost to the Purchaser / Customer. The bidder may bring out such requirement(s) suitably.

2.1.0 SCOPE OF SUPPLY

2.1.1 Complete supplies for Air-conditioning system (as per clause no. 1.1.0)

The equipments and services to be furnished under this contract are detailed in a BOQ provided with this tender for reference. Bidders shall work out the actual requirement based on the building layout



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001	
REV.0	DATE: JULY 2020
SECTION – II, SUB SECTION C1	

enclosed with this specification. The items though not specifically mentioned but required for safe and satisfactory operation of the system will also be treated as included and the same shall be supplied at **NO EXTRA COST** to BHEL.

The Bill of Quantities shall be read in conjunction with the Instructions to Bidders, General and Special Conditions of Contract, Technical Specifications, and Drawings.

The quantities given in the Bill of Quantities are estimated and provisional, and are given to provide a common basis for bidding. The basis of payment will be the actual quantities of work ordered and carried out, as measured by the Contractor and verified by the Purchaser and valued at the rates and prices bid in the priced Bill of Quantities.

A rate or price shall be entered against each item in the priced Bill of Quantities. The cost of Items against which the Contractor has failed to enter a rate or price shall be deemed to be covered by other rates and prices entered in the Bill of Quantities.

The whole cost of complying with the provisions of the Contract shall be included in the Items provided in the priced Bill of Quantities, and where no Items are provided, the cost shall be deemed to be distributed among the rates and prices entered for the related Items of Work.

General directions and descriptions of work and materials are not necessarily repeated nor summarized in the Bill of Quantities. References to the relevant sections of the Contract documentation shall be made before entering prices against each item in the priced Bill of Quantities.

Miscellaneous items like hardware, fixtures etc. shall be deemed to be included under the relevant BOQ items and bidders shall consider the same while quoting for BOQ items.

2.1.2 Besides, the Bidder shall take a note of the following while preparing his offer:

- a) Supply of power & control cables have been excluded from contractor's scope of supply. Bidders shall submit the requirement of power & control cables (cable size, type & quantity) for AC system along with their respective bids. BHEL will provide power & control cables to the vendor as free issue item. Contractor shall have to choose their cables from the available sizes as listed in Annexure – I to Section-1 and contractor shall make necessary modifications in their equipment for termination of these cables.
- b) ***Bidder shall choose make of materials from list enclosed in Annexure-II to this section. However final applicable make is subject to ultimate customer approval. Bidder can provide any other make that is not included in the list only if it is acceptable to ultimate customer without any cost implication to BHEL.***
- c) Supply and laying of Fiber optic cable along with all accessories for networking of PLC (RIO) panel with main PLCs of different main plant control rooms is in contractor's scope of works.
- d) Purchaser will lay two incomer cables upto contractor's HVAC PDB in AC Plant room. The contractor shall do termination of the same. Cabling (laying & termination) further to other equipments, panels etc and for control & interlocking of various equipments shall be in contractor's scope. The bidders in their offers shall include supply of cable accessories such as lugs, glands, cable tags & markers etc.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

- e) Necessary cable trays will be supplied on free issue basis to the contractor, however necessary hardware for fixing the same on walls or elsewhere shall be included by the bidders in their offers.
- f) Earthing material viz. (GS flat 75 x 10, 50 x 6 & 25 x 3 mm) will also be supplied on free issue basis to contractor; however the bidders in their respective bids shall give requirement.
- g) Instruments like differential pressure sensor, temperature transducers, switches etc shall be provided for completeness of the system wherever required as per TSGENCO specification.
- h) Contractor shall submit valid Type test report for approval by Customer. Fresh type test of equipment is not envisaged. It is presumed that equipment offered is duly type tested.
- i) In case the type test reports are found un-satisfactory, tests shall be carried out afresh by contractor without any additional cost implication to BHEL.
- j) Bidder shall submit quality plan of the items of this system during detailed engineering stage in standard BHEL quality plan format for customer approval.
- k) Obtaining, "As Built" certification from purchaser or Customer on applicable drawings. Completing documentation as per specification requirement shall be in contractor scope of services.

2.1.3 SCOPE OF SERVICES

2.1.3.1 Erection, Testing & Commissioning (ETC) requirements

- i. The scope of ETC shall include receipt of material at site, safe storage of material, handling of equipment/material at site, erection of equipment /material at site including fabrication, equipment and system testing, commissioning of the entire system. The bidder shall arrange all material, consumables plus tools & tackles required for completion of ETC work.
- ii. Conducting performance guarantee tests to the satisfaction of Customer/ Purchaser and handing over of the system to Customer / Purchaser. Bidder shall submit the PG test procedure at the time of detailed engineering for approval by customer/ purchaser.
- iii. ***It is the responsibility of the contractor to abide to Guaranteed power consumption for Air conditioning system inline with the requirements of Sec-III, Sub Section 6 of the Complete plant portion of this tender.***
- iv. It is the responsibility of the contractor to maintain the system till it is handed over to customer / Purchaser.
- v. Cables laying for incomers to the AC Power distribution board (PDB) shall be done by the purchaser. The contractor has to lay and terminate all the other power and control cables supplied under the present scope.
- vi. The contractor shall do earthing of all installation under the present scope.
- vii. All machinery - tools & tackles and consumables required for erection / commissioning of the system shall be arranged by the bidder.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

- viii. Bidder shall ensure that sufficient quantities of commissioning spares are made available for timely completion of commissioning of the system. The bidder shall furnish a list of Commissioning spares that will be brought by him. The unused commissioning spares shall be returnable to the Bidder.
- ix. Piping from water tap-off to inlet of pan humidifier. The purchaser at one point near control room shall provide water tap-off.
- x. Piping from overflow of pan humidifier & AC unit (disposal of condensate) to the nearest drain point.
- xi. Cable laying & termination between Fire Alarm Panel (FAP) & PDB for HVAC system in order to switch off the system in case of fire.
- xii. Laying & fixing of cable trays on walls or elsewhere. The bidder in their offer shall include necessary hardware for the same.
- xiii. Painting of all the equipments shall be as per customer specification.
- xiv. Refrigerant piping, liquid line valves, suction, discharge valves, HP gauge provision shall be as per the standards and customer requirement.
- xv. After completion of erection and commissioning of the system, the bidder shall train site engineers of Purchaser/Customer so that they are fully conversant with both electrical and mechanical part of this package.

2.1.3.2 Civil Works

Major civil works such as room & foundations for various HVAC equipments shall be in purchaser's scope. However following shall be in contractor scope of services:

- a. Wall openings at suitable locations for duct, refrigerant/ drain piping, Fresh Air unit shall be made by the contractor. Associated civil works such as grouting, filling up crevices/cut outs etc during installations of equipments shall also be in contractor's scope. Any other damage caused to civil works during ETC work of the equipment/system shall be made good to the original finish by the contractor at no extra cost to the purchaser.
- b. Furnishing of details for construction of outdoor unit's mounting arrangement.
- c. Providing necessary guidance to/ coordination with civil contractor so that appropriate sized / correctly located cut outs are made (by civil contractor) in false ceiling for installation of grilles / diffusers / return air.

However in case wall openings / cut outs have not been provided for either duct laying, louver fixing, or fresh air fan, the same shall have to be made by the Contractor.
- d. Minor modifications, alterations in system installation as per customer's specific requirements shall be done without any extra cost to purchaser.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

2.2 Exclusions

- i. Supply of Cable trays for laying cables. Installation wherever required is in contractor scope.
- ii. Supply of power and control cables. The bidder shall choose from the BHEL procured cables listed in Annexure-I to this section & furnish **quantity** and **type** of cables required complete system in their respective bids. Laying & termination is in contractor scope.
- iii. Various rooms and foundations for locating air conditioning equipments.
- iv. Supply & installation of false ceiling.
- v. Underdeck insulation of the air-conditioned areas.
- vi. Supply of GI flat for earthing of equipments.

2.3 Handing & Taking Over

It is the responsibility of the contractor to maintain the system till it is handed over. The system/ equipment before being handed over shall be subjected to successful run test as per approved PG Test procedure. The contractor shall rectify any defect noted during the period. This running test shall be in addition to the performance tests specified earlier.

2.4 Inspection & Testing

All equipments shall be inspected prior to dispatch in line with relevant IS, approved GTP/ drawing, technical specification & BHEL/ customer approved QAP.

NOTE

- Following portions of Sec-I – Complete plant area of this technical specification is applicable for Sec-II- Switchyard area too as indicated in Index:
- SUB SECTION C1 – Customer specification.
 - SUB SECTION C2, C2A Technical Requirement, C2B – Project specific general requirement, C2C – Painting specifications.
 - SUB SECTION C4 – Technical Specification (C & I Portion)
 - SUB SECTION D – Standard Technical Specifications
 - SUB SECTION E – Annexure V, VII, VIII, IX



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

ANNEXURE - I

LIST OF THE CABLES PROCURED BY BHEL

2C x 2.5 sq mm PVC/ Copper, Armoured
5C x 4 sq mm PVC/ Copper, Armoured
5C x 2.5 sq mm PVC/ Copper, Armoured
7C x 2.5 sq mm PVC/ Copper, Armoured
14C x 2.5 sq mm PVC/ Copper, Armoured
19C x 2.5 sq mm PVC/ Copper, Armoured
2C x 10 sq.mm XLPE/ Aluminium, Armoured
4C x 10 sq.mm XLPE/ Aluminium, Armoured
4C x 16 sq.mm XLPE/Aluminium, Armoured
3.5C x 35 sq.mm XLPE/ Aluminium, Armoured
3.5C x 70 sqmm XLPE/ Aluminium, Armoured
3.5C x 300 sqmm XLPE/Aluminium, Armoured

Enclosures – TSGENCO AC system spec, TSGENCO Switchgear spec, Switchyard Control building Architectural drgs.



TECHNICAL SPECIFICATION FOR AIR CONDITIONING SYSTEM
(SWITCHYARD CONTROL BUILDING)
PROJECT: 5 x 800 MW, YADADRI TPS, NALGONDA

SPECIFICATION No: PE-TS-417-553-A001

REV.0

DATE: JULY 2020

SECTION – II, SUB SECTION C1

Annexure - II

AIR CONDITIONING SYSTEM
LIST OF MAKES OF SUB-VENDOR ITEMS

[In line with ref. Cl. No. 2.1.2 b.]

Sl. NO.	*ITEM / EQUIPMENT	SUB SUPPLIER
1.	PRECISION PACKAGE UNITS	STULZ / UNIFLAIR / EMERSON / BLUEBOX / CLIMADENTA
2.	SPLIT AC/ CASSETTE AC	VOLTAS / BLUE STAR / CARRIER / HITACHI / LG
3.	AIR FILTER	PUROLATOR / FMI / ANFILCO / TENACITY / JOHN FOWLER SPECTRUM / AIR TECH / PUROMATIC
4.	AXIAL FANS / F.A. FANS	FLAKT / KHAITAN / PATEL / NICOTRA / SARLA / KRUGER / MARATHON / C DOCTOR
5.	INSULATION MATERIAL	BEARDSHELL / K-FLEX / PARAMONT/ ARMAFLEX / SUPREME / LLOYDS / UP TWIGA / AEROCCELL
6.	GI SHEETS FOR DUCTING	TISCO / INDIAN IRON & STEEL CO LTD. / RASHITRYA ISPAT NIGAM LTD. / ESSAR/ ISPAT INDUSTRIES / JSW STEEL / LLOYDS STEEL / BHUSHAN / TATA / SAIL / JINDAL
7.	FIRE DAMPER	TSC / CARRYAIRE / RAVISTAR (SYSTEM AIR)
8.	GRILL/DIFFUSER/VOLUME CONTROL DAMPER	AIR FLOW/ TSC /AIR MASTER/ CARYAIRE/RAVI STAR (SYSTEM AIR)
9.	STRIP HEATER	ESCORTS / RACOLD / DASPASS/ ALCO/ HEATCO /HOTSET
10.	PAN HUMIDIFIER	RAPID COOL/ HOTSET /ALCO
11.	THERMOSTATS	HONEYWELL / RANCO / PENN / DANFOSS / INDFOSS /JHONSON CONTROL /RANUTROL
12.	HUMID STAT	JHONSON CONTROL / HONEYWELL / PENN
13.	ANTI FREEZE THERMOSTAT	RANCO / HONEYWELL / PENN / DANFOSS /INDFOSS
14.	FLOW SWITCH	SWITZER / LEVCON / DK INSTRUMENT / SBEM / V. AUTOMATE/ SIEMENS
15.	FLOW METER	EUREKA / INSTRUMENTATION ENGINEERS PVT LTD / PLACKA /TRAC / FLOW STAR/ SCIENTIFIC DEVICE
16.	RH SENSOR/TEMP SENSOR	HONEY WELL /JOHNSON /SIEMENS / GENERAL INSTRUMENTS
17.	PLC BASED PANEL	SIEMENS / SCHENIEDER / ROCKWELL / GE INTELLIGENT / HONEYWELL AUTOMATION / ABB/ MITSUBISHI ELECTRIC
18.	OVS / PC	HP / COMPAQ / DELL / HCL / IBM / LENOVO
19.	UPS	HITACHI-HIREL / APC / DELTA / EMERSON / DB POWER / APLAB
20.	FIBRE OPTIC CABLE	BIRLA ERICSON / FINOLEX / AKSH FIBRE
21.	LT SWITCHGEAR	SIEMENS/ NITYA ELECTROCONTROLS/ JAKSON ENGINEERS/ L&T/ PYROTECH ELECTRONICS/ RSI SWITCHGEARS
22.	PRESSURE TRANSMITTER	ABB / ENDRESS + HAUSER (INDIA) / MOORE / SIEMENS / SMART INSTRUMENT BRAZIL / SBEM

* Make of the sub-components inside above listed items of AC system will be as per the approved data sheets/ drawings by the end client without any additional implication to BHEL.

Annexure III
to
Technical Spec. for Air Conditioning System of
Switchyard Control Building (Sec-II, Sub Section-C1)

VOLUME : IIID

SECTION-I

**TECHNICAL SPECIFICATION
FOR
AIR CONDITIONING SYSTEM**

THIS ANNEXURE IS TSGENCO TS FOR ENTIRE PLANT. BIDDER SHALL REFER THIS TS FOR THE PORTIONS RELEVANT TO AC SYSTEM APPLICABLE FOR SWITCHYARD SCOPE ONLY.

VOLUME: IIID

SECTION - I

AIR CONDITIONING SYSTEM

CONTENTS

CLAUSE NO.	DESCRIPTION
1.00.00	INTRODUCTION
2.00.00	SYSTEM DESCRIPTION
3.00.00	SCOPE OF WORK
4.00.00	CONTROL PHILOSOPHY
5.00.00	DESIGN CRITERIA
6.00.00	DESIGN, CONSTRUCTIONAL AND OTHER REQUIREMENT
7.00.00	SPECIAL TOOLS
8.00.00	SPARE PARTS
9.00.00	TESTING AND INSPECITON AT MANUFACTURER'S WORKS
10.00.00	FIELD TEST
11.00.00	PERFORMANCE GUARANTEE, TOLERANCE, PENALTY AND RECORDS
12.00.00	SPECIAL CLEANING, PROTECTION & PAINTING
13.00.00	DOCUMENTS, DATA TO BE FURNISHED WITH TENDER PROPOSAL
14.00.00	POST AWARD DOCUMENTS, DATA TO BE FURNISHED
15.00.00	LIST OF DRAWINGS

VOLUME: IIID
SECTION – I

AIR CONDITIONING SYSTEM

1.00.00 **INTRODUCTION**

1.01.00 The purpose of the system is to provide Air Conditioning System for the different areas of 1X800 MW Supercritical Thermal Power Plant, Stage – VII Unit #12 at Kothagudem Thermal Power Station, Telangana.

Various control rooms in power station, housing a group of sophisticated and precision control panels and desks call for controlled environment for proper functioning and for the comfort of working personnel.

2.00.00 **SYSTEM DESCRIPTION**

2.01.00 The air conditioning system shall cover the following areas as a minimum:

- a. Power House Building including Control Room
 - i. Unit Control Room
 - ii. Control Equipment Room (CER)
 - iii. Shift Charge Engineers' Rooms
 - iv. Computer Room
 - v. Uninterrupted Power Supply (UPS) Room
 - vi. Steam and Water Analyzer (SWAS) Panel Room (Dry Panel)
 - vii. Excitation room
 - viii. AVR room
 - ix. Relay panel room
 - x. Other Office areas like Telephone Exchange Room, Conference Hall, library, Laboratory Rooms etc, if any, on the operating floor
- b. Service Building
 - i. Maintenance Office areas, conference rooms, lecture rooms and any other areas needs Air Conditioning.
 - ii. AC plant control room (in Central AC plant equipment room proposed to be located in ground floor of Service Building)
- c. ESP Control Room.
- d. VFD Control Room (if applicable)
- e. Ash Handling Plant Control Room
- f. DM plant control room, office and Laboratory area.

- g. Switchyard Control Room.
- h. Chemical Laboratory Building.
- i. Coal Handling Plant control room
- j. Any other Local Control Rooms / Cubicles of different Auxiliary Buildings housing Programmable Logic Controllers (PLC) Panels and other Input / Output (I/O) modules
- k. Rooms having the equipment required controlled temperature by nature for their operating feature.
- l. Any other area requiring Air conditioning as per manufacturer's recommendation.

All the buildings described above shall preferably be provided with separate air conditioning systems because they may be far apart from each other.

- 2.02.00 For the Power House Building and the attached Service Building, one Common Central Chilled type Air Conditioning plant shall be provided with individual Air Handling Units / Fan-Coil Units (as applicable) for the Unit Control Room, Control Equipment Room, Shift Charge Engineer's Room, Computer Room, Uninterrupted Power Supply (UPS) Room, Excitation Room, AVR Room, Relay Panel Room, SWAS (Dry Panel) Room, all Laboratory Rooms and other Office areas, Telephone Exchange Room, Conference Hall, and Library etc, if any, on the operating floor.
- 2.03.00 Water Cooled Precision air Conditioners of 3 x 50% capacity shall be provided for the ESP Control room, VFD Control Room (if applicable), AHP Control Room, DM Plant Control Room and its associated office and Laboratory and Chemical Laboratory Building. Condenser cooling water for these Air Conditioners shall be supplied from main plant ACW system through Non-Chemical Water Treatment Device. Provision of a Fresh Air unit consisting of Air Inlet Louver with Bird Screen, Dry panel HDPE filters, Tube Axial Flow Fan with Drive Motor, Volume control damper, Supports and supporting structures etc. shall be provided for each PAC Room.
- 2.04.00 Air Cooled Packaged Units (Precision Type) will be used for air conditioning of the Switch Yard Control room and CHP Control room. Provision of a Fresh Air unit consisting of Air Inlet Louver with Bird Screen, Dry panel HDPE filters, Tube Axial Flow Fan with Drive Motor, Volume control damper, Supports and supporting structures etc. shall be provided for each PAC Room.
- 2.05.00 Air cooled non duct able Split Air Conditioners shall be provided for Rooms / cubicles housing Programmable Logic Controllers (PLC) and other Input / Output (I/O) modules or any other area requiring for Air conditioning. Required no. of AC units of suitable capacity should be selected with 100% units as stand-by for AC areas having 24 hours operation. For AC areas with less than 12 hours operation, stand-by units may be avoided if multiple units are installed.

- 2.06.00 The systems described above are only minimum requirement. Any other area/areas, if felt by the Bidder himself or by the Purchaser/their consultant, or if demanded by the process/equipment should be air conditioned, shall be included in Bidder's scope of work.
- 2.07.00 The foregoing and subsequent clauses specify the equipment/system for general guidance only. Any other equipment and /or materials necessary to ensure safe and satisfactory erection, commissioning and operation of the plant shall be supplied.
- 2.08.00 The air conditioning requirement for different areas are as follows:
- 2.08.01 One Common Central chilled water Air Conditioning system consisting of 2x100% Packaged Screw type Chiller Units associated with 2 x 100 % capacity Chilled water pumps, 2 x 100 % capacity Condenser water pumps , 2 x 100 % capacity Cooling towers and controls & instrumentation to serve the Unit Control room, Control Equipment room, Computer room, UPS room, SWAS (Dry Panel) room and Shift Charge Engineer's room, AVR Room, Excitation Room, Relay Panel Room, Other Office areas, telephone exchange room, Conference Hall, library and Laboratory etc, if any, located in the Power House building and all the floors of the attached Service Building.
- Clarified water shall be used as the make-up to cooling towers. This condenser cooling water will be treated through the Non-Chemical Water Softening Equipment installed in the common header of Condenser water pump outlets.
- 2.08.02 Unit Control Room & Shift Charge Engineer's Room, Computer Room, Control Equipment Room and UPS room in the Control Building will be served by at least 2 nos. each of 50% capacity AHUs located in the AHU Room.
- For SWAS (Dry Panel) Room and Shift Charge Engineer's Room, AVR Room, Excitation Room, Relay Panel Room, Other Office areas, Telephone Exchange Room, Conference Hall, Library and Laboratory etc, if any, and the attached Service Building individual AHUs/ Fan Coil Units shall be provided. Each floor of Service Building shall have separate AHUs. For each room / area at least 2 nos. AHU/FCU shall be provided.
- However, the combination of areas to be served by AHUs / FCUs will depend upon the actual layout when the building drawings will be finalized.
- 2.08.03 1 x 100% capacity Fresh Air Unit consisting of Air Inlet Louver with Bird Screen, Dry panel HDPE filters, Tube Axial Flow Fan with Drive Motor, Volume control damper, Supports and supporting structures etc. shall be provided for each AHU Room serving critical areas like Control Room, Control Equipment Room, UPS room, AVR Room, Excitation Room, Relay Panel Room, Telephone Exchange Room, Laboratory, etc.
- For other non-critical areas like Office areas, Conference Hall, Library, various floors of Service Building fresh air will be inducted in the AHU room through the wall mounted rain protection cowl with bird screen and a volume control damper.

1 x 100% capacity Fresh Air Unit consisting of Air Inlet Louver with Bird Screen, Dry panel HDPE filters, Tube Axial Flow Fan with Drive Motor, Volume control damper, Supports and supporting structures etc. shall be provided for each PAC Room serving critical areas like ESP Control Room, VFD Control Room (if applicable), Ash Handling Plant Control Room, Chemical Laboratory Building, DM Plant Control Room, Office and Laboratory area, Switchyard Control Room and Coal Handling Plant Control Room etc.

Fresh air for small areas like SWAS room, AC plant control room, small office and control rooms fresh air will be inducted through door opening.

2.08.04 ~~1 x 100 % capacity Electrode Type Humidifier with associated controls and accessories shall be provided in each AHU room serving critical areas of Power House Building.~~

2.08.05 ~~Provision of Duct mounted Electric Strip heater and High Efficiency Filter shall also be kept with the common supply duct from the AHUs serving critical areas like Unit Control Room, Shift Charge Engineer's Room, Computer Room, Control Equipment Room, UPS Room, AVR Room, Excitation Room, Relay Panel Room, telephone exchange room, Laboratory, etc.~~

Duct mounted Electric Strip heater shall be provided with the common supply duct for non-critical areas like Office, Conference Hall, library, various floors of Service Building etc.

2.08.06 Smoke Evacuation system consisting of smoke exhaust fans with ducting, motorized isolating dampers and rain protection cowl with bird screen shall be located in AHU rooms serving control room and associated areas of Power House building.

2.08.07 Exhaust fans of required capacity & quantity to be provided for Central AC plant equipment room.

3.00.00 **SCOPE OF WORK**

Scope has been defined under subsequent Clauses.

3.01.00 **Central Chilled Water Air Conditioning Plant** (Common for Power House Building and Service Building)

The central chilled water AC plant consists of the following equipment:

3.01.01 Two (2) Nos. (one as running and one as stand-by) Water Cooled Screw Chiller Unit of adequate capacity and each consisting of:

a) One(1) / Two(2) Nos. Screw Compressors (As per Manufacturer's standard).

Type: Rotary Screw type, hermetic/semi- hermetic, directly driven, R-134a duty.

Accessories include suction and discharge shut-off valves, discharge check valve, oil Separator, oil heater, HP, LP, Low oil level cutout, high winding temperature cutout through PTC sensors, Motor overload cutout, liquid Injection system, integrated pressure relief valve, oil service valve, Step less Automatic capacity control arrangement with automatic unloaded starting device, Anti Recycle device, Heater, Setting and Overhauling tools, foundation bolts, vibration isolating device etc.

Adequately sized Induction Motor (for the above compressors) suitable for $415V \pm 10\%$, 3 phase, $50Hz \pm 5\%$ AC. AC Supply.

b) One(1) No. Refrigerant Condenser.

Type :Water cooled, horizontal, shell and tube R-134a duty & capacity to match the above compressor with integrally finned copper tubes with steel shell having adequate surface area to cater to the requirement of the above compressor & to provide sub-cooling by 2 Deg. C at least.

Design fouling factor : Not less than .0002 Hr. Sq. M. $^{\circ}C/Kcal$ (.001 Hr-Sq. ft $^{\circ}F/BTU$).

Heat removal and water flow rate :To be calculated and furnished by be Bidder.

Accessories: Relief valve, vent connection with valve, De-scaling connection, charging connection, water flow switch, drain connection with valve. Thermo-well connections on water side, liquid trap etc.

c) One(1) No. Refrigerant Chiller.

Type : Horizontal shell and tube direct expansion/flooded type R-134a/water duty with copper tube having adequate surface area to provide superheating by 3 Deg.C.

Design fouling factor : Not less than 0.00013 hr-Sq. m. $C/Kcal$ (0.00065 hr-Sq. ft. Deg. $F./BTU$).

Heat removal and Water flow rate: To be calculated and furnished by the Bidder.

Accessories: Liquid and water connection provided with thermo-wells, water flow switch and pressure gauge connections.

At least 39 mm thick insulation of Aluminium foil faced Nitrile Rubber /XLPE or equal, with removable type insulated flange cover, water side drain connection with valve in every portion of the chiller isolated by baffle plates.

- d) Piping & Auxiliaries : Common base frame for compressor, condenser, chiller unit fabricated of M.S. angles, channels etc. anchor bolts, nuts, hot gas piping, cold gas piping, liquid refrigerant piping all of seamless steel or ERW steel pipes, insulation of cold gas piping with minimum 39 mm thick Aluminium foil faced Nitrile Rubber /XLPE or equal liquid valves, muffler if needed, gauges and instrument piping, filters, drier, moisture indicator isolating valves etc. as may be required for safe and trouble free operation. The entire chiller package assembly shall be installed with spring type vibration isolation devices (One set for each chiller unit)

Equipment drain water connection with siphon and valves, fittings etc. up to the nearest drain point with proper insulation shall also be included.

- e) Controls: Electronic expansion valve, solenoid valve in the refrigerant circuit, operating temperature sensor and anti freeze thermostat/ sensor.

Microprocessor based control panel of each chiller unit will provide safety against high & low refrigerant pressure, low oil pressure, freezing of chilled water, overload, winding heating and single phasing and phase reversal of compressor by means of high & low pressure transmitter, oil pressure transmitter, temperature sensors & transmitter, O/L relays, Thermistor relays, etc. and other safety Controls including Over/Under voltage and voltage unbalance protection, over/under current and current unbalance protection and others as per manufacturer's standard.

It will also provide capacity control by sensing low chilled water return temperature through operating temperature sensor and motorized sliding valve. Other safety devices like flow switches for the condensers and chillers, compressor unloaded starting device shall also be provided through Microprocessor based control panel. (One set for each chiller). Such Microprocessor based Control Panel shall be provided with 20% extra properly wired I/O units.

- f) Oil and Refrigerant: First charge of refrigerant R-134a and oil for the above chiller units.

- 3.01.02 Condenser cooling water piping of MS ERW (heavy grade) complete with valves, fittings, hangers / supports. between cooling towers and condensers (of Screw Chiller Units) including the condenser cooling water pumps complete with valves, bends, strainers, fittings, instruments, hangers and supports etc. Equipment drain water connection and valves, fittings etc. up to the nearest drain point shall also be included. A single line diagram in this connection is to be furnished by the Bidder.

- 3.01.03 Chilled water piping connecting the chillers(of Screw Chiller Units), chilled water pumps and cooling coils of air handling units / FCUs and expansion tank, complete with valves, bends, strainers, fittings, instruments, hangers and supports, insulation etc. A single line diagram in this connection is to be furnished by the Bidder.
- The insulation shall be at least 39mm thick Aluminium foil faced Nitrile Rubber /XLPE or equal (Refer elsewhere for detailed specification of insulation). For Chilled water drain pipes the insulation thickness shall be at least 26 mm.
- 3.01.04 Make up water piping of medium class GI complete with fittings, hangers / supports from Make-up Water tank through booster pumps (1R+1S) to various points of consumption like cooling tower sumps, expansion tank and Humidifiers.
- 3.01.05 Two (2) Nos. (1 working + 1 Stand-by) Condenser Cooling Water Pumps to meet the requirement of the Central Chilled Water plant.
- Type : Centrifugal, horizontally split casing / end suction type, single stage directly coupled to electric motor and mounted on a common base frame.
- Speed : Preferably not more than 1500 rpm.
- Capacity and Head : To be calculated and furnished by the Bidder.
- Duty : Continuously running.
- Accessories : Pressure gauges at suction and discharge, isolating valves, all integral piping, required for sealing, cooling etc. strainers, check valves, flexible coupling guard, foundation bolts and nuts etc. and other standard accessories as may be necessary for successful operation. Vibration isolators shall also be supplied. Condenser water pumps shall be provided with mechanical seals.
- Motor for the above : Adequately sized TEFC, squirrel cage induction motor, suitable for 415 V $\pm$ 10%, 3 pH, 50 Hz $\pm$ 5% supply.
- 3.01.06 Two (2) Nos. (1 working + 1 stand-by) Chilled Water Circulating Pumps for all areas.
- Type : Centrifugal, horizontally split casing / end suction type, single stage directly coupled to electric motor and mounted on a common base frame.
- Speed : Preferably not more than 1500 rpm.
- Capacity and Head : To be calculated and furnished by the Bidder.
- Accessories : Pressure gauges at suction and discharge, isolating valves, all integral piping required for sealing, cooling etc. strainers, check valves, flexible coupling guard, foundation bolts and nuts, complete insulation with minimum 39 mm thick Nitrile Rubber /XLPE or equal with 24G aluminium sheet cladding. For the pumps, vibration isolators shall also be supplied. Chilled water pumps shall be provided with mechanical seals.

Duty : Continuously running.

Adequately sized, TEFC squirrel cage induction motor suitable for 415 V $\pm$ 10%, 3 Phase, 50 Hz $\pm$ 5% supply for the above.

- 3.01.07 Two (2) Nos. (1 working + 1 stand-by) Cooling Tower Induced draft cross/counter flow type to meet the requirement of the Central Chilled water plant. Design Wet bulb temp. will be 27.6 °C with a approach (Maximum) of 4.0 °C.

Construction of various components will be as under:

Casing	:	FRP
Louver	:	FRP
Fill	:	PVC
Drift eliminator	:	PVC
Strainer	:	Brass wire mesh
Headers and pipe connection	:	G.I.
Basin	:	R.C.C./FRP
Nuts and Bolts etc.	:	Suitable corrosion resistant material i.e. G.I. or cadmium plated.

Accessories include supports, supporting structure, make-up water piping with float valve, drain connection with siphon and valve, over flow and quick fill connections etc.

- 3.01.08 Expansion Tank

The expansion tank shall be made of G.I or FRP and shall be of adequate thickness & suitably reinforced. It shall be complete with make-up connection with float valve, quick fill connection, overflow connection and drain connection with valve. The tank shall be provided with level gauge glass and shall be completely insulated with 6 mm thick Aluminium foil faced Nitrile Rubber /XLPE or equal. The capacity shall be selected based on 1.2% of circulated chilled water capacity. Filtered water shall be supplied as make-up.

- 3.01.09 Make-up water Tank

The Make-up water tank shall be made of G.I or FRP and shall be of adequate thickness & suitably reinforced. It shall be complete with make-up connection with float valve, quick fill connection, overflow connection and drain connection with valve. The tank shall be provided with level gauge glass. This tank will supply make-up water to Cooling towers, Expansion tank and

- humidifiers. The tank size is to be designed based on capacity to hold water for 15 minutes of make-up water requirement for above.
- 3.01.10 Two (2) Nos. (1R+ 1S) Make-up Water Booster pumps.
- Mono block type centrifugal pump to supply make-up water from the Make-up water tank to the Cooling towers, Expansion tank and humidifiers, each complete with drive motor, common base plate, isolating valves, non return valve etc.
- 3.01.11 One(1) No. on line Non-chemical water treatment equipment to suit the common condenser water header. The equipment shall be complete with flanges at ends and supports.
- 3.02.00 **Air Handling Units/Fan Coil Units with controls**
- Number and individual capacities of Air Handling Units/Fan Coil Units should be calculated and furnished by the Bidder. Each A.H.U. shall consist of the following:
- 3.02.01 DIDW Centrifugal Fan having forward/backward curved blades and belt driven by TEFC squirrel cage Induction motor suitable for AC 415V $\pm$ 10%, 3 Ph, 50 Hz $\pm$ 5% supply shall be provided. M.S. Scroll casing of the fan will be suitably painted.
- Accessories include V-belts with pulleys, belt guard, supporting frame, volume control damper etc.
- NOTE: For small FCUs single phase motors shall be used.
- 3.02.02 1 No. Cooling Coil will be provided in each AHU. The cooling coil will be chilled water circulating type.
- Construction will be seamless copper tubes with aluminium fins, number of fins as per manufacturer's standard but not greater than five (5) per Cm. [thirteen (13) per inch].
- Design fouling factor will be 0.00013 hr-Sq. m.- $^{\circ}$ C/Kcal.
- 3.02.03 Panel type dry HDPE filter having an efficiency of 90% down to 10 micron size particles will be provided. A differential pressure sensor shall be provided across the filters to initiate alarm when the pressure difference across the filters exceeds a pre determined value, warranting cleaning /replacement of filters.
- 3.02.04 AHU will have Double skin G.I casing (Sand witched panel with internal insulation of min. 25mm thick TF quality Expanded polystyrene/ PUF) with inspection facilities, supports made in a 16-G M.S. structure of sectionalized construction with one coat of rust proof anti-corrosive paints followed by two coats of final paint and complete with insulated SS drain pan, insulated drain piping etc. The AHUs shall be cabinet type with Fan section, Coil section and filter section. Adequate space between Filter section and Coil section shall be

kept for maintenance purpose and proper air flow. Fan section also shall have adequate maintenance space all around the fan and motor.

- 3.02.05 One set of operating controls consisting of motorized modulating 3-way mixing valve with cooling coils of AHUs and FCUs with temperature sensor, transmitter and actuator for controlling the flow of chilled water, will be provided. Small FCUs shall have multi-speed motor.

3.03.00 Fresh Air System

Fresh air unit for Control room areas and areas served by Precision air conditioners shall consist of a tube axial flow/centrifugal fan with drive motor, inlet louver with bird screen, dry panel HDPE filters, volume control damper, supports, supporting structures etc. 1 x100% capacity Fresh air unit shall be provided in each AHU room / PAC room. A differential pressure sensor shall be provided across each set of filters to initiate alarm when the pressure difference across the filters exceeds a pre determined value, warranting cleaning /replacement of filters.

For Fan coil unit, there shall be provision for suitable arrangement of fresh air intake from the nearest evaporative cooling units.

For Service Building and other non-critical areas, fresh air opening with air inlet louver and a volume control damper shall be provided in the AHU room.

3.04.00 High Efficiency Filter

High efficiency filter having an efficiency of 99 % down to 5 microns mounted in supply air duct is to be provided for air conditioning of all control rooms and allied area. A differential pressure sensor shall be provided across the filters to initiate alarm when the pressure difference across the filters exceeds a pre determined value, warranting cleaning /replacement of filters.

3.05.00 Electrode Type Humidifier

Electrode humidifier consists of high temperature Polypropylene water tank, electrodes, auto flash cycle activated on demand from the microprocessor based control system with humidity sensor, located in the AHU room for control room areas of Power House building. This Humidifier shall also be complete with make up connection with float valve, overflow connection and drain connection with valve.

3.06.00 Electric Strip Heaters

Electric strip heaters will be of adequate capacity mounted in supply air duct with thermostat, humidistat, air stat/safety thermostat and controlling temperature sensor etc. (For winter heating purpose and for monsoon reheat purpose.) for control room areas of Power House building.

Electric strip heaters will be of adequate capacity mounted in supply air duct with thermostat, air stat/safety thermostat and controlling temperature sensor etc. (For winter heating purpose) for various floors of Service Building.

3.07.00 **Smoke Exhaust System**

~~Smoke Evacuation system consisting of smoke exhaust fan with ducting and motorized isolating dampers with cowl & bird screen shall be located in AHU rooms servicing Control room areas of Power House building. The fan and motor shall be designed to withstand a temperature of 400 Degree C for 2 hours.~~

3.08.00 **Duct Work**

Duct work includes:

- a) ~~G. I. Duct having zinc deposition of at least 180 gm/m².~~
- b) Damper with control arrangement at each branch off and wherever necessary.
- c) All supply & return air grilles and diffusers made of extruded aluminum powder coated and complete with volume control dampers (for SA grilles/diffusers only) and supporting frames.
- d) Flexible connections of rubberized canvas.
- e) Hangers and supports.
- f) Sealing compound and jointing gasket for ducts.
- g) ~~13 mm thick Aluminium foil faced Nitrile Rubber /XLPE or equal or equivalent thermal insulation for the entire air conditioning ducting.~~
- h) ~~Acoustic insulation of 25 mm thick open cell erosion resistant Nitrile Rubber foam of density min. 140 Kg/CuM provided in the ducting up to a length of 6 M from the Air Handling Unit / Precision Air Conditioner outlet.~~
- i) Motorized fire damper with sensors, control etc. at strategic locations, as required. Provision of manual overriding operation through latch shall also be kept with the Motorized Fire Damper.

3.09.00 **Water Cooled Precision Air Conditioners**

(Applicable for ESP Control room, VFD Control Room (if applicable), AHP Control Room, Chemical Laboratory Building and DM Plant Control Room and its associated Office and Laboratory)

~~Water Cooled Precision Air Conditioners shall be complete with scroll compressors (suitable for R-410/407c refrigerant) and water cooled shell and tube condensers, interconnecting refrigerant piping (duly insulated) between condensers and PAC units, evaporator fans with highly efficient EC motors and their controls, high efficiency filters, cooling coils with electronic expansion valve, electrode type humidifiers with controls, electric strip heaters, thermally and acoustically lined powder coated MS casing, insulated SS drain pan, insulated~~

drain piping, and built-in microprocessor based control panel.

~~Such Air Conditioners will be associated with air distribution system consisting of a GI duct - work as elaborated above, Non Chemical Water Treatment Equipment at the inlet to the condensers of PAC. Condenser cooling water will be fed to the condenser from the Plant ACW system.~~

3x 50% capacity Precision AC Units are to be provided each for each PAC room.

Provision of introducing fresh air into the PAC unit room shall be kept through Fresh Air Unit as described earlier.

3.10.00 Air Cooled Precision Air Conditioners

(Applicable for Switch Yard Control room and CHP Control room)

Air Cooled Precision Air Conditioners shall be complete with scroll compressors (suitable for R-407C / 410A refrigerant) and remote air cooled condensers, interconnecting refrigerant piping (duly insulated) between outdoor condensers and indoor PAC units, evaporator fans with highly efficient EC motors and their controls, high efficiency filters, cooling coils with electronic expansion valve, insulated SS drain pan electrode type humidifiers with controls, electric strip heaters and built-in microprocessor based control panel thermally and acoustically lined powder coated MS casing and insulated drain piping. Such Air Conditioners will be associated with air distribution system consisting of a GI duct - work as elaborated above.

3x 50% capacity Precision AC Units are to be provided each for each PAC room.

Provision of introducing fresh air into the PAC Unit Room shall be kept through Fresh air unit as described earlier.

3.11.00 Air Cooled Non Duct-able Split Air Conditioners

(Applicable for rooms/cubicles housing PLC and other I/O units, computer room and any other area requiring air conditioning)

Air Cooled Non Duct-able Split Air Conditioners shall be complete with hermetically sealed rotary compressors and air cooled condensers in the outdoor units with powder coated GI casing, built-in electrical items & supports and Indoor units housing dry panel type HDPE filters, cooling coils, evaporator fans with two speed drive motors, all encased in powder coated GI casings with swiveling type supply air grilles and decorative RA grilles and interconnecting refrigerant piping (duly insulated) between outdoor and indoor units and insulated drain piping, microprocessor based cordless remote control panel and 240V, single phase MCB with connecting cable for each split unit.

~~Required no. of suitable capacity should be selected with 100% units as stand-by for all rooms/ cubicles housing PLC and other I/O units/ computer room running for 24 hours.~~

~~For AC areas with less than 12 hours operation, stand-by units may be avoided if multiple units are installed.~~

3.12.00 Electrical Work

3.12.01 One (1) 415 V Motor Control Centre (MCC) for operation and control of the complete Central AC system required for the Power House Building and the associated Service Building. The MCC be shall be located in the central Air-Conditioning Plant room.

Each MCC shall be fed by 2 x 100% incoming feeders, which shall be located at either end of the panel.

3.12.02 One (1) no. Local Starter Panel (LSP) for each AHU room of Power House Building and attached Service Building. This LSP will house In-coming MCB, outgoing starter for all drives located in AHU room and MCB for heaters, humidifiers and FCUs.

3.12.03 One (1) 415V Power Distribution Board (PDB) each for supplying power to the PAC units of each Auxiliary Building.

Each PDB shall be fed by 2 x 100% incoming feeders, which shall be located at either end of the panel.

3.12.04 Non Duct-able Split units shall be fed from local distribution board / nearest power source available in the respective building.

3.12.05 All the Electrical items as described above shall be as per relevant volume of the technical specification on electrical work.

3.12.06 DDC Based Control Panel

- I. Control, monitoring, operating and safety controls & interlocks, indication and audio-visual annunciation for all AC equipment of the Central Chilled Water Plant and AHU rooms shall be activated from central DDC based Control Panel located in the AC plant control room.
- II. Power shall be fed to this DDC Panel from the MCC located in the Central AC plant room. This DDC panel shall be interfaced with the MCC, Individual Microprocessor based Control panels of Chillers and LSPs located in AHU rooms.
- III. This DDC panel shall be associated with two nos. Workstations (Engineering & Operating).
- IV. The DDC System shall consist of:
 - a) One (1) no. DDC panel housing Direct Digital Controllers for Central Air Conditioning System. The DDC panel shall be suitable for HMI interfacing directly with sensors, actuators and environmental delivery systems (i.e., all component equipment and accessories of AC system), controls and monitoring for the central AC System. This Control system along with one work station shall be complete with necessary software & Licenses (OS cum ES) for control

and monitoring of the Central AC System and generation of alarm list, report etc.

- b) One (1) no work station complete with suitable Central Processing Unit (CPU) Key Board, Mouse and Video Display Unit (VDU) with 21 inches monitor.
- c) Necessary battery back up for RAM for 24 hours continuous operation during power failure and necessary UPS and battery charger with minimum 30 minutes back up.
- d) Necessary UPS Battery & Charger for DDC System back up shall be provided in the AC Plant Control Room.
- e) Necessary interface hardware and software for interconnection with other system for two-way data transfer for information exchange. The data format, the exact number of points etc. shall be finalized during detailed engineering stage.
- f) All other necessary hard wares to make the system complete and functional.
- g) One Common Hooter for audio annunciation of any malfunction of AC equipment and systems.
- h) System earthing and panel earthing of the DDC Panel.
- i) The DDC shall have inbuilt PID function's for precise control of the process parameters.
- j) The user friendly programming shall be done via Windows software.
- k) Interlock list for equipment should be incorporated in the operator station.
- l) Alarm List (Process & System), Event List , Different level of security.
- m) The DDC Control system and its HMI shall have necessary Graphic user interface for display of the processes with indication of devices and instruments. In case of alarms the alarm indication window will be displayed on the screen to attract the attention of the operator and generate output for audio-visual annunciation.
- n) Various controls and annunciations to be provided in DDC panel shall be as per clause no. 4.00.00: Control Philosophy.

3.12.07 Local Push Button Stations

Local Push Button Stations shall be provided for each drive motor and equipment (Cooling Tower Fan Motors, FCUs and Make-up Water Booster Pump Motors etc.), suitably located near drives and equipment of each AC system. LPBS shall consist of one no. emergency Red Stop P.B (pressed to latch and turn to release type) for each drive.

Local Push Button Stations shall be as per the relevant Volume of the electrical specification.

For Other detail VOLUME : II-F shall be referred to.

3.12.08 Local Distribution Board (240V)

Local Distribution Boards containing Switch / MCB for Non Duct-able Split Air Conditioners detail specification VOLUME : II-F shall be referred to.

3.12.09 Drive Motors

- i) Motors shall be supplied with mounting and coupling hard wares such as base plate, coupling, coupling guard, anchor bolts and nuts, all hardware etc.
- ii) Design ambient temperature of all motors for air conditioning system shall be 50 °C.
- iii) Motors shall have class F insulation but the temperature rise shall be limited to that of class B over an ambient temperature of 50 °C.
- iv) The motor nameplate kilowatt rating multiplied by the motor nameplate service factor shall be at least 15% greater than the driven equipment operating range maximum brake kilowatt.
- v) Motors rated 30 KW and above shall be provided with space heater suitable for 240 V, 50 Hz, 1 Ph. AC.
- vi) Motors rated below 250 watts shall be suitable for 240 V, 50 Hz, 1 Ph. AC. Motors rated 250 watts and up to 160 KW shall be suitable for 415V±10%, 3-Phase, 50Hz±5% AC.
- vii) Motors rated above 110 KW shall be fed by Air Circuit Breaker and others of lower rating shall be fed by MCB/MCCB.
- viii) All motor enclosures shall conform to the degree of protection IP-55 unless otherwise specified. Motor for outdoor or semi-outdoor service shall be of weather proof construction.
- ix) All drive motors shall be as per relevant Volume of the Electrical Specification.

3.12.10 All Power, Control and Instrumentation cabling as required and conforming to the requirement of relevant Volume of Electrical Specification.

3.12.11 Grounding of all electrical items as per relevant Volume of Electrical Specification.

3.13.00 Suspended Ceiling work with supporting grids, hangers etc. for all the air conditioned areas. The Suspended Ceiling shall be complete with 12mm thick GYPSUM board at various elevations including supplying, fixing snap grid

systems of approved manufacturer with 40 mm X 50 mm cross tees and 40 mm X 50 mm end channels including MS hangers, cleats, supports, turn-

buckles, ties placed around 1200 mm (Max.) centre to centre for forming frame work to support snap grid systems and lighting fixtures including all ancillary work at site like providing of various cut outs, holes, recess, trap door (removable panels), wherever shown, welding to reinforcement to hangers, if required, grouting of hangers and complete with all finish in super decorating manner, providing openings for lighting and air conditioning fixtures including painting of all structural with two coats of approved primer and final paint and also complete with all materials as per working drawings, and direction of engineers.

3.14.00 Under-deck Insulation work for all the air conditioned areas. Roofs of AC spaces are insulated with 25 mm thick EPS (Under-deck) for roofs not exposed to Sun and 50mm thick EPS (Under-deck) for roofs exposed to Sun.

3.15.00 **Supply, Erection, Testing and Commissioning**

3.15.01 Erection, testing and commissioning of all the equipment and accessories mentioned herein above including supply of all grouting pieces, all matching flanges, connecting flanges, valves and other fittings bolts, nuts, gaskets and supporting arrangement as required, are included in the scope of work.

3.15.02 Base plate and foundation plates including anchor bolts, nuts, loose fittings etc. for equipment and as would be necessary for erection and complete anchoring of steel materials for the pipes, hangers and supports for water chilling unit and other equipment, are to be supplied.

3.15.03 ~~At least 39 mm thick Aluminium foil faced Nitrile rubber / XLPE insulation on refrigerant piping as required for the Precision type PAC units and 26 mm thick similar insulation for Non Duct-able Split units.~~

3.15.04 Supply, erection, testing and commissioning of all electrical drives and equipment mentioned herein above including supply erection, testing and commissioning of cables, cable trays, grounding of all drives and equipment for each AC plant and system as required for efficient and trouble-free operation and successful commercial operation, are included in the scope of work.

Erection, testing and commissioning of electrical drive motors and equipment shall be as per relevant volume of the specification.

3.16.00 **Consumables**

All consumables such as grease and lubricating oil for one year's trouble free operation after handing over, are to be included.

3.17.00 **Spare parts**

Supply of recommended spare parts for three years trouble free operation and maintenance is to be included.

3.18.00 Special tools and tackles

Supply of special tools and tackles including tool box required for operation, maintenance and overhauling of the system is to be done.

3.19.00 Documents

Drawing, data, characteristic curves and instruction manuals for the equipment and system as detailed herein after and as described in the relevant volume of the specification are required.

3.20.00 Training of Purchaser's Personnel

Contractor is to arrange for training of purchaser's personnel for operation and maintenance of the plant and equipment supplied.

3.21.00 General

Above clauses specify the equipment for general guidance only. Any other equipment and/or materials necessary to ensure safe and satisfactory erection, commissioning and operation of the plant shall be supplied.

4.00.00 CONTROL PHILOSOPHY

4.01.00 Chilled Water Air Conditioning System

The chilled water plant shall operate with 2 x 100% capacity Packaged Screw Chiller unit (1R+1S), 2x100% capacity (One no. working and one no. Standby), condenser water (CW) pumps, 1x100% capacity (One no. working and one no. Standby), chilled water (CHW) pumps, 2x100% capacity (One no. working and one no. Standby) induced draft-cooling towers.

All the equipment of this system shall be operated from the DDC system work stations located in the AC plant room. Furthermore cooling tower fans, make up Water Booster Pumps and FCUs shall also be operated from their individual local Push-button stations.

One no. Local starter Panel shall be installed in each AHU room which will feed power to all the AHU fans, motors of 3-way mixing valves of AHUs, Fresh air fans (wherever applicable), Smoke Exhaust fans (wherever applicable) and their motorized isolating dampers, Fire damper motors, Electric heaters and Humidifiers and FCUs of SWAS rooms, UPS Room. This equipment located in each AHU room and SWAS/ UPS Room shall be operated and controlled from the workstations through DDC system located in the AC Plant Room as well as from these Local Starter Panels.

FCU/s for AC Plant Control room shall be operated from the workstations through DDC system and from their local Push-Button stations.

The Packaged Screw Chilling units shall incorporate microprocessor based control panel, which will also be interfaced with the DDC system.

The Packaged Screw Chilling units can be started only when its associated cooling tower fans, condenser & chilled water pumps are in operation.

All the drives of the AC system shall be manually started / restarted through DDC from the work stations after any trip.

The chilled water system shall be provided with the following safety & operating controls:

(i) Operating Control:

Room temperature control with the help of modulating 3-way chilled water flow regulating valve with the cooling coil of AHUs / FCUs through the central DDC system, getting sense from the temperature sensor and associated transmitter placed in the return air path.

Chilled water temperature control based on the room load with the help of operating temperature sensor and controlling through compressor's automatic unloading mechanism for screw chillers through the built-in Microprocessor based control panel of Packaged Screw Chiller. This control shall also be possible through the central DDC system.

Room RH control with the help of humidifiers (if required) & duct mounted re-heaters through the central DDC system getting sense from the RH & Temperature sensors and their associated transmitters placed in the return air path inside AHU rooms.

(ii) Safety Control:

The chilled water system shall be incorporated with the following safety controls and interlocks:

High discharge pressure cutout (HP).

Low suction pressure cutout (LP).

Low oil level cutout

High winding temperature cutout
through PTC sensors

Low chilled water temperature cutout by anti-freeze thermostat /temperature sensor for Screw chiller.

Cutout due to low flow of chilled water & condenser water by flow switches.

Cutout due to overload of all drive motors.

High air temperature cutout by safety thermostat / temperature sensor for duct mounted electric heaters.

Low cooling tower sump water level cutout for CW pumps. (Alarm for low water level in expansion tank & humidifier as applicable shall be provided).

Stopping of AHU fans in case of fire in the respective zone through the central DDC system.

Short circuit protection.

Closing of fire dampers at the air supply duct from AHUs in case of fire with the sense from room mounted fire/smoke detector through zonal fire panel and the DDC system.

Heater for compressors, which will be energized during compressor idling time. This safety control shall be actuated through the built-in Microprocessor based control panel of each Screw chiller.

Safety controls of Screw chillers will also include Over/Under voltage and voltage unbalance protection, Single phase & Phase reversal preventor, over/under current and current unbalance protection and others as per manufacturer's standard.

(iii) Interlocks:

The system components shall be interlocked with one another in the following way:

The Screw Compressor shall not start unless:

At least one cooling tower fan is running.

At least one condenser water pump is running.

At least one chilled water pump is running.

The duct mounted electric strip heater shall not be energized unless the respective AHU fans are running.

All the above Interlocking shall be actuated through the DDC Panel.

On-Off-trip status for all the drives, electric heaters & humidifiers (if required) shall be available at the work stations of the DDC Panel located in the respective AC plant rooms.

Motors of fire dampers provided in supply air duct of AHU shall remain energized in normal condition to effect opening of dampers. In the event of fire, the motors of fire dampers will be de-energized and the damper will close due to spring action, the relevant AHU fan motors will be tripped at the same time. These dampers shall be operated through the DDC Panel getting signal from relevant duct mounted smoke detectors / fire alarm panel.

Provision for one common audio annunciation for any kind of malfunctioning in AC plant shall be kept through a hooter located in the AC Plant Control Room and suitably interfaced with the DDC Panel.

The control system shall comprise central DDC Panels with two workstations located in the AC Plant control room.

The basic function of the system is as follows: -

To closely control and monitor inside temperature and humidity condition inside the air-conditioned spaces.

To optimize / minimize energy consumption by automated operation.

To provide centralized monitoring and control for various mechanical facilities including sequential start / stop of the whole AC system.

To generate maintenance data and alarms.

To maintain records of plant operation.

Programmed start / stop of individual AHU as per operating requirements and for maintaining the room temperature / RH by controlling the 3 way mixing valves at chilled water line, humidifier and duct heater.

Programmed start / stop of individual FCU as per operating requirements and for maintaining the room temperature by controlling the 3 way mixing valves at chilled water line.

Safe and reliable operation, supervision & control, alarm & event management and optimization, maintenance management of the entire AC system shall be accomplished with the DDC system.

The DDC system shall be interfaced with:

The Air Conditioning MCC.

The Microprocessor based control panels of Screw Chiller.

The LSPs located in each AHU rooms.

The Temperature and RH sensors and their associated transmitters located in the AHU rooms.

The Temperature sensors located in the rooms served by FCUs.

The zonal fire panels/ duct mounted smoke detectors.

The two work stations and the Hooter.

4.02.00 Air Conditioning System with Water-Cooled Precision Air Conditioner

This system will operate round the clock for ESP Control Rooms, VFD Control Room (if applicable), Ash Handling Plant Control room, DM Plant Control room with associated office and Laboratory.

Water Cooled Precision Air Conditioners of 3x50% (Two nos. working and one no. Standby) capacity shall be provided for ESP Control Rooms, VFD Control Room (if applicable), Ash Handling Plant Control room, DM Plant Control room with associated office and Laboratory.

Condenser cooling water for the Precision Air Conditioners shall be supplied directly from the ACW system.

The Precision Air Conditioners shall be operated from the respective unit mounted microprocessor based control console.

(i) Operating Control

The Precision Air Conditioners shall have following operating controls:

- ON / OFF thermostatic control of the compressor of Precision Air Conditioners to maintain the desired room temperature.
- Superheat control by means of electronic expansion valve, wherever applicable.
- Room RH control (wherever required) with the help of humidifier & heater installed within AC units getting sense from the humidistat placed in the return air path.

(ii) Safety Control

The compressor of each Precision Air Conditioner shall be incorporated with the following safety controls and interlocks:

- High refrigerant pressure cutout.
- Low refrigerant pressure cutout.
- Low Oil Pressure Cut out (if applicable).
- Cutout due to overload of all drive motors.
- Stopping of evaporator fans in case of fire in the respective zone.
- Closing of fire dampers at the supply duct from Precision Air Conditioners in case of fire with the sense from duct/room mounted fire/smoke detector through zonal fire panel.

- Low condenser water flow cutout.

(iii) Interlocks

The system components shall be interlocked with one another in the following way:

The compressor shall not start unless:

- a) Condenser water flow is low.
- b) The evaporator fans are running.

The electric strip heater shall not be energized unless the respective evaporator fans are running. The Strip heaters will trip with the help of safety thermostat in case the temperature of air at the downstream side of the heaters exceeds a pre-determined value.

On-Off-trip indications for all the drives & electric heaters shall be provided at the unit mounted microprocessor based control console.

4.03.00 Air Conditioning System With Air-Cooled Precision Air Conditioner

This system will operate round the clock for Switch Yard Control room and Coal Handling Plant Control Room.

Air Cooled Precision Air Conditioners of 3x50% (Two nos. working and one no. Standby) capacity shall be provided for Switch Yard Control room and Coal Handling Plant Control Room.

The Precision Air Conditioners shall be operated from the respective unit mounted microprocessor based control console.

(i) Operating Control

The Precision Air Conditioners shall have following operating controls:

- ON / OFF thermostatic control of the compressor of Precision Air Conditioners to maintain the desired room temperature.
- Superheat control by means of electronic expansion valve, wherever applicable.
- Room RH control (wherever required) with the help of humidifier & heater installed within AC units getting sense from the humidistat placed in the return air path.

(ii) Safety Control

The compressor of each Precision Air Conditioner shall be incorporated with the following safety controls and interlocks:

- High refrigerant pressure cutout.
- Low refrigerant pressure cutout.
- Low Oil Pressure Cut out (if applicable).
- Cutout due to overload of all drive motors.
- Stopping of evaporator fans in case of fire in the respective zone.
- Closing of fire dampers at the supply duct from Precision Air Conditioners in case of fire with the sense from duct/room mounted fire/smoke detector through zonal fire panel.

(iii) Interlocks

The system components shall be interlocked with one another in the following way:

The compressor shall not start unless:

- a) The condenser fans are running.
- b) The evaporator fans are running.

The electric strip heater shall not be energized unless the respective evaporator fans are running. The Strip heaters will trip with the help of safety thermostat in case the temperature of air at the downstream side of the heaters exceeds a pre-determined value.

On-Off-trip indications for all the drives & electric heaters shall be provided at the unit mounted microprocessor based control console.

4.04.00 Non Duct Able Split Air Conditioners

Non-duct able Split air-conditioners will be controlled from the unit mounted Control panel or from the cordless hand operated remote.

5.00.00 DESIGN CRITERIA

5.01.00 The design outside conditions are taken from Meteorological Station at Khammam nearest to Kothagudem Thermal Power Station area. For designing of the equipment, outdoor conditions shall be considered as follows:

Outdoor design condition	:	Summer	: 42.6 Deg. C (DB), 26.6 Deg. C (WB)
		Monsoon	: 30.9 Deg. C (DB), 25.8 Deg. C (WB)
		Winter	: 20.8 Deg. C (DB),

Inside design condition : ~~22.0 Deg. C $\pm$ 1 Deg. C DB & RH 55 % $\pm$ 5% for critical areas like control room, control equipment rooms, computer room, UPS rooms, AVR rooms etc.~~

~~24.0 Deg. C $\pm$ 1 Deg. C DB & RH not exceeding 60% for the non-critical areas like offices, conference room, SWAS room, etc. and the areas served by split air conditioners.~~

~~For service building the inside conditions shall be 24.0 Deg. C $\pm$ 1 Deg. C DB & RH not exceeding 60% in all seasons except winter. In winter a DB temperature of 22.0 Deg. C shall be maintained.~~

Any equipment/process demanding any other (less) temperature shall be provided with.

Floor area : As per actual layout

Roof area : As per actual layout

Glass area : As per actual layout. All windows in the Air Conditioned shall be provided with light coloured Venetian blind

Lighting load : ~~21.4 Watt/sq.m (or actual) for all areas except shift charge engineer's room & service building where 16 watt per sq.m (or actual) shall be considered.~~

Occupancy : ~~One (1) person in 12 sq.m (or actual)~~

Equipment/Panel load : As actual.

Solar load : Solar and transmission load through walls, roofs, doors, windows, glazing, floors etc. should be considered.

Ventilation Air : ~~Fresh air at the rate of 1.5 air changes per hour for the control rooms and 1 air change per hour for office areas or at least 34 Cu. M/Hr. per person, whichever is higher, should be considered to achieve pressurization of air conditioned space and to meet the ventilation requirement of occupants.~~

Other loads : Heat load due to AHU fan motor, duct friction etc. shall be considered while finding total heat load.

Plant sizing : ~~Plant sizing is to be done by allowing 5% margin on total sensible and latent heat calculated on the basis of above design considerations. An overall margin of 10% on calculated cooling load shall be considered in selecting Plant capacity.~~

All Condenser cooling water pumps and chilled water pumps, AHUS and FCUS shall have further, 10% margin on their flow capacities.

Insulation : Roof over AC space exposed to sun will be provided with 50 mm thick expanded polystyrene or equivalent. Roof over AC spaces not exposed to sun will be provided with similar insulation of 25mm thickness.

5.02.00 Individual air handling equipment shall be provided for individual facilities. Chilled water flow control valve (3-way), strip heater and electrode humidifier are provided for maintaining inside conditions.

5.03.00 All water piping for the make-up at cooling tower sump, Electrode humidifiers, Expansion tank and Make-up water tank etc. shall be provided by the bidder. Such make-up water piping shall be taken from the nearest clarified water header.

5.04.00 Electric power supply will be 415V $\pm$ 10%, 3 phase, 50 Hz. $\pm$ 5% A C.

5.05.00 The basic proposal by the bidder shall be for equipment strictly according to the technical specification. The location of air conditioning equipment, layout of ducting, piping etc. shall be designed by the bidder and approved by the Consultants/Owner.

5.06.00 The bidder shall satisfy himself regarding the refrigerating capacity required for maintaining the end conditions inside AC spaces before submitting the offer. For this purpose, the basis of computing air-conditioning load mentioned earlier is to be referred. The bidder shall have to guarantee the end conditions mentioned earlier.

5.07.00 Codes and Standards

Design, manufacture, inspection and testing of the equipment covered by the specification shall unless otherwise specified conform to the latest edition of the standards and codes including all addenda mentioned below :

IS-659 : Safety code for air-conditioning

IS-660 : Safety code for mechanical refrigeration

ASHRAE-23	:	Standard method of testing and rating [67 Standards] air conditioner.
AR1-450-6	:	Standards for water cooled refrigerant Condenser.
ASME Sec. VII	:	Unfired pressure vessels
IS-4503	:	Shell and tube type heat exchanger.
ASHRAE 22-72	:	Method of testing for rating water cooled refrigerant condenser.
ANSI-8-31.5	:	Refrigeration piping.
ANSI-8-9.1	:	Safety code for mechanical refrigeration.
AR1-410	:	Standard for air cooling and air heating coils.
AR1-210	:	Standard for unitary air conditioning equipment.
IS-3588	:	Specification for electrical axial flow fans.
AMCA-210	:	Methods of performance test for fans.
BS-2831	:	Methods of test for air filters used in AC and general ventilation.
IS-4671	:	Expanded polystyrene for thermal insulation purpose.
IS-702	:	Industrial bitumen.
IS-1239	:	Heavy class Pipes for sizes upto 150 mm dia.
IS-8188	:	For Water conditioning.
IS-325	:	3 phase induction motors.
IS-4029	:	Guide line for testing 3 phase induction motor.
IS-210	:	Specification grey iron casting.
IS-2062	:	Structural steel
AMCA -Bulletin No. 210	:	Standard code of testing centrifugal and axial flow fans
IS-2825	:	Code of practice for welding mild steel
IS-2676	:	Dimensions for wrought aluminum and aluminum alloy sheets and strips.

ASHRAE Code : for various filter

IS-655 : Specification for metal air ducts

BS-4735 : Horizontal Burning for XLPE insulation

BS- 4370 Part-1 : Dimensional Stability for XLPE Insulation

ASTM D 1056 : Water Absorption for XLPE Insulation

Pump design and testing should correspond to the procedure mentioned in IS-1520.

5.08.00 The refrigerant for Split units shall be R-22 as per ARI designation.

5.09.00 For requirements of materials of construction, 5.00.00 of this section shall be referred to.

5.10.00 Special Note

In case any discrepancy is found between requirements of this section and those mentioned in other sections, stipulations of this section shall prevail.

6.00.00 DESIGN, CONSTRUCTIONAL AND OTHER REQUIREMENT

6.01.00 General Instruction to the Tenderer

6.01.01 The Tenderer shall refer only to those of the following clauses which are applicable for this particular project as detailed in clause 1.00.00 and 2.00.00 of this specification. The clauses which are not applicable for this project shall be ignored.

6.02.00 General Design, Constructional and other Requirement

6.02.01 All the equipment shall be capable of withstanding the stresses which may be experienced during normal operation and test.

6.02.02 All the equipment shall be designed to permit inter-changeability of parts and ease of access during inspection, maintenance, installation and repair of various parts.

6.02.03 All parts subject to substantial temperature changes shall be designed and supported such as to permit free expansion or contraction without resulting in leakages, harmful distortion, misalignment or play.

6.02.04 Proposals for repair or any similar operations involving the plugging, welding, boring or addition of metal to the original castings shall be submitted to the Purchaser/Consulting Engineer and approval shall be received before any such

- work is carried out. Drawing showing details and locations of such modifications shall be submitted to the Purchaser/Consulting Engineer for his records.
- 6.02.05 All equipment shall be heavy duty type suitable for installation in heavy industries and for long period of uninterrupted service.
- 6.02.06 All materials used shall conform to the specification and shall be new and first class in all respects.
- 5.02.07 Anchor bolts, nuts and seating steel work shall be supplied with the equipment. Only hexagonal nuts shall be used for holding down the equipment, with proper lock nuts. All bolt holes shall be spot faced for nuts. In specific cases where not necessary, spot facing may be omitted.
- 6.02.08 Casting and welding shall conform to their respective specifications and shall be free from flaws and objectionable imperfections, machined true and in a workmanlike manner.
- 6.02.09 The separate pieces of equipment shall be marked with unit number. The assembly drawings shall indicate part number of each equipment and unit number for easy correlation.
- 6.02.10 Coupling guards and belt guards shall be furnished as applicable.
- 6.02.11 All equipment, ducts, pipes, controls etc. shall be fully treated against corrosion and sealed against moisture, sand and dust ingress.
- 6.02.12 All plant including ducts and pipes as well as machines shall be vibration isolated, or otherwise treated so that :
- No excessive vibration is felt in the floors or walls of the rooms served by any machine.
 - The mechanically induced vibration levels in floors, walls and ceilings of rooms are sufficiently small as to limit the radiation of the sound level to the rooms within acceptable levels.
- 6.03.00 **Packaged Screw Chillers**
- A. Refrigerant Compressors (Twin Screw Type)
- I. The compressor may be designed either for direct or for indirect drive.
 - II. The compressor assembly shall be adequately designed for minimum vibration and noise disturbances.
 - III. The shaft seal shall be of proven design.
 - IV. All safety devices against high-pressure refrigerant, low-pressure refrigerant and low oil pressure shall be provided, High winding temperature through PTC sensor. The compressor units must be provided with oil pressure regulator.

- V. The horsepower of the compressor motor shall be sized for 115% of maximum rated power required for the unit including the drive loss.
- VI. The compressors shall be provided with built-in-unloaded starting device. The compressor shall have automatic capacity control device preferably built-in-type to match reduced refrigeration load.
- VII. Capacity control must be achieved by use of slide valve, which provides fully modulating capacity control from 100% to 10% (20%, at least) of full load. The slide valve shall be actuated by oil pressure controlled by external solenoid valves.
- VIII. The oil separator should be effective enough to incur gravity drop out of oil from the refrigerant gas before it enters the condenser.

B. Heat Exchangers (Condensers and Chillers)

- I. All condensers shall be of shell and tube type with water in the tubes and refrigerant in the shell.
- II. All chillers for chilled water plant shall also be shell and tube type with water either in tubes or outside the tubes.
- III. The heat exchanger shall be designed for a minimum working pressure of 10.5 kg/cm² gauge on the water side and 11.3 kg/cm² on the refrigerant side and shall generally conform to the latest ASME CODE for unfired pressure vessels Section- VIII. The design pressure shall have a reasonable margin over the maximum working pressure.
- IV. The average velocity of water in tubes shall not be more than 2.5 m/sec.
- V. Water heads or refrigerant heads of the heat exchangers shall be as not to allow leakage of fluid from one pass to the other.
- VI. Tube supports of adequate strength shall be provided to prevent the tubes from sagging and vibrating.
- VII. The overall fouling factor for the condensers and chillers shall be 0.0002 and 0.00013 Hr.M² °C /K Cal respectively.
- VIII. The condensers shall be designed to provide at least 2 °C sub cooling of refrigerant under rated design condition. The water chillers also shall be designed to superheat the refrigerant by at least 3 °C under rated design condition.
- IX. Testing and other design feature of the heat exchanger shall meet the requirements of TEMA Class-C heat exchangers or approved equal.

- X. The heat exchangers shall have open able water boxes for ease in maintenance.
- XI. The tube for water chillers shall be of deoxidised copper with or without integral fins. The tubes for the condensers shall also be copper with integral fins. The tube wall thickness at any point shall not be less than 18 SWG.
- XII. The baffle plates and the tube sheets shall be made of steel. The shell shall be made up of seamless tube or shall be fabricated from flange quality steel plate (ASTM-A285 Grade-C). The tube support plates shall be made of flange quality carbon steel plates and shall be as per TEMA Standard.
- XIII. The heat exchangers shall be provided with vent valve, relief valve, and/or safety fusible plug on refrigerant side and vent valve and drain valve on water side (at every section of the baffled shell of heat exchanger).
- XIV. The tenderer shall quote packaged units having compressor, condenser and chiller assembly together in a single framework and mounted on a common base plate. Provision for refrigerant charging and chemical cleaning of water tubes shall be provided.
- XV. Each heat exchanger shall be provided with water flow switch. This shall be interlocked with the control of the individual refrigeration system/corresponding compressor drive.
- XVI. All the heat exchangers shall be provided, with standard connections like thermo wells, inspection valve and antifreeze thermostat / temperature sensor and external equaliser connection for expansion valves for chiller. Insulation shall be terminated in such a manner that it will not be damaged during removal of bolts, covers etc. Separate covers similar to flange covers shall be constructed to facilitate easy removal.

6.04.00 Water Pumps

- 6.04.01 Each pump shall be of horizontal split casing / end suction centrifugal type, directly coupled to electric drive motor and mounted on a common base plate. Pumps having motor of 5 HP capacity or below can be of mono-block construction, provided its materials of construction are as mentioned below and motor is as per desired motor specification.

The pump shall be complete with casing, impeller, renewable type wearing rings, shaft, shaft sleeve, bearings, stuffing box, Mechanical Seal (if applicable), cowlings, base plate etc. as applicable. The design pressure for the casing shall not be less than 16 bar for chilled water pumps.

- 6.04.02 Pump head-capacity characteristics shall be gradually rising from operating to shut off point without any zone of instability. The pump BHP-flow characteristics shall be preferably be non-over loading type beyond rated capacity point.
- 6.04.03 Operating speed of the pump shall not preferably be more than 1500 rpm. Vibration isolations of efficiency 90% (approx.) shall be provided.
- 6.04.04 Material of the pump shall preferably as follows (all material shall be of tested quality).
- a) Casing : Cast Iron, as per IS 210, Gr FG 260 for both CHW & CW pumps. (As per manufacturer's Standard)
 - b) Impeller : Bronze to IS: 318 Grade 2
 - c) Shaft : Carbon Steel C-45.
 - d) Shaft sleeve : Bronze
 - e) Wearing ring : Bronze
 - f) Base Plate : Cast Iron
- 6.04.05 Pumps shall be provided with suitable bearings sized adequately to take the maximum possible unbalance load occurring due to all mechanical and hydraulic reasons.
- 6.04.06 Pump and drives shall be directly coupled through a flexible coupling. Suitable coupling guard shall be provided for each pump.
- 6.04.07 Each pump shall be completed with pressure gauge at the suction and discharge, isolating valves, all integral piping required for sealing and cooling, casing drain and vent connections etc. The pressure gauge of pump will be connected with a siphon and a two-position brass cock.
- 6.04.08 The rated BHP of the motor shall provide for 15% margin over the rated BHP of the pump. For other electrical particulars of the motor refer detailed specification of the motors.
- 6.04.09 The design of the pumps shall conform to the relevant IS Code.
- 6.04.10 Major rotating components of the pumps like impellers, balancing drums etc. shall be individually balanced statically and finally each pump shall be dynamically balanced.
- 6.04.11 The critical speed of the pump shall be at least 20% above the operating speed.

- 6.04.12 All pumps and motors shall be aligned properly, and bolted and doweled to a common base frame.
- 6.05.00 **Induced Draft Cooling Towers**
- 6.05.01 The cooling towers shall be cross flow induced draft type with FRP casing & sump with air entry on all four sides and air discharge on top. The fan motor shall be easily accessible from outside and out of moist air stream.
- The internals shall be of stainless steel SS or MS epoxy painted to withstand corrosive atmosphere. The tower shall be of low height, suitable for round the clock operation at location in the space shown in the applicable drawings. The tenderer shall confirm that the tower supplied by them can be accommodated in the space shown in the drawing.
- 6.05.02 Cooling tower shall be of sufficient capacity to cool the rated amount of water through the specified range at the design W.B. temperature.
- 6.05.03 The structural frame work of the tower including all members and connections shall be designed for operating loads and prevailing wind pressure. Steel members shall be MS epoxy painted and be of sufficient size to safely withstand all imposed loads.
- 6.05.04 FRP casing sheets shall be clamped on close centre to the structural steel members. Rubber neoprene gaskets must be used on all bolted joints as a seal against water leakage.
- 6.05.05 Louvers shall be of fixed type.
- 6.05.06 The fan deck shall be of ample strength to support all loads normally encountered in operation and maintenance. Stiffeners shall be provided on the under side.
- 6.05.07 Galvanised steel ladder with safety cage and hand railing shall be provided in such a number and locations as necessary to give safe and complete access to all parts to tower requiring occasional inspection or adjustment. An access door shall be provided for fan deck and the cell for ready access to the interior parts of the tower.
- 6.05.08 Fills shall be of extended area of formed PVC suitable to withstand hot water temperature of 55 °C.
- 6.05.09 Louvers and drift eliminators shall be of PVC/FRP construction.
- 6.05.10 Eliminators shall be provided in removable sections & installed in the cell of the tower. The number of deflection in the eliminators shall be so arranged as to reduce drift loss to 0.2% of the water circulated.

- 6.05.11 The water distribution system shall be open basin with gravity feed nozzles. The system shall be self draining and non-clogging and designed for flexible operation and ready accessibility. All main piping connection shall be brought out and end in flanges, to flexible connection.
- 6.05.12 The cold water basin shall be of F.R.P. construction. The basin shall be complete with float valve for make up water control, a drain and overflow connection. The make-up water supply pipe shall be positioned at least double the pipe diameter above the maximum water level in the basin. The water basin shall be constructed such as to provide a coarse strainer of Brass wire mesh easily accessible from outside.
- 6.05.13 Fan shall be of the propeller type, cast aluminium and multi bladed aerofoil construction with adjustable pitch. The entire fan assembly shall be statically balanced. Outlet velocity of air shall be not less than 610 meters per minutes and the fan tip speed shall not exceed 4570 meters per minute.
- 6.05.14 Each fan shall be gear driven. Where reduction gears are used, housing shall be of heavy cast iron construction with large oil reservoir and complete with supply of oil.
- 6.05.15 Fan motors shall be of the totally enclosed fan cooled type and of the required capacities. Motor shall preferably be located outside the moist air stream.
- 6.05.16 Fan drive shaft using reduction gearing shall be dynamically balanced and connected through flexible couplings.
- 6.05.17 The mechanical equipment assembly shall be adequately supported on the fan deck.
- 6.05.18 Fan discharge hatch shall be covered with galvanised wire mesh to prevent birds nesting during idle periods.
- 6.05.19 All nuts, bolts and fasteners used in the cooling tower shall be stainless steel / Nickel or chrome plated.
- 6.06.00 **Piping**
- A. Refrigerant Piping
- I. Refrigerant piping shall be of M.S. seamless (as per IS-1239, Part-I heavy grade) or copper tube (IS-5493). Welding rings shall be used for smaller pipes. Weld preparation of joints, cleaning of pipes shall be carried out as per relevant code.
- II. Pressure drop in hot gas, liquid and suction lines should not exceed the value corresponding to 2 °F (1.1 Deg C) change in saturation temperature of the fluid.

- III. Velocity in the discharge and suction pipe of the refrigerant shall not be too high as to create undue vibration and noise, velocity in the vertical length of discharge and suction pipe of the refrigerant shall be high enough to carry the entrained oil in the refrigerant, even in case of unit running at lowest partial capacity. An angle type drain valve with male flare outlet connection will be installed at the bottom end of each vertical riser pipe to drain any accumulated oil.
- IV. Instrument piping for gauges, switches etc. shall be copper only. Capillary tubes will be used wherever possible. For field-mounted instruments, this is not applicable.
- V. Spacing and location of hanger shall conform to preferred engineering practice. Hangers and supports shall be made up of structural steel sections. The design of the hangers and supports shall provide for suitable protection to insulation on the pipes, wherever applicable. All materials for anchoring the hangers with reinforced concrete work or building structural beams and columns shall be furnished by the Bidder.
- VI. Liquid-moisture indicator with leak proof glass on opposite sides shall be provided in the liquid line for facilitating visual inspection of liquid refrigerant charge.
- VII. The liquid line shall be provided with Drier-Strainer.

B. Water Piping

- ~~I. Condenser cooling water piping and chilled water piping for 150 NB or below GI-Heavy Class conforming to IS-1239, Part-I, for higher sizes black steel pipe, heavy grade conforming to IS-3589, Fe 410 grade. Drain water piping shall be of M.S. heavy grade.~~
- II. The piping shall be so designed that the water velocity through the piping shall not exceed 2.5 m/sec and also the piping friction drop shall be limited to 4 m per hundred meters of pipe length. Pipe sizes indicated in tender drawings shall be followed.
- III. The pipes shall be of plain end in case of M.S. Pipes (i.e., suitable for welded connections) as far as possible.
- IV. Counter-flanges for connecting to flanges on valves or equipment shall be made of IS-2062 or superior and shall preferably be slip on type, suitable for welding on the piping in case of M.S. Piping.
- V. All bolts and nuts for flange connection shall be hexagonal carbon steel type as per IS-1363 and with the material and other requirements as per IS-1367. All threaded valves shall be provided with nipples and flanged pairs on both sides to permit flanged connections for ease of removal / replacement of valves.
- VI. Bends, fittings fabricated at site are not acceptable. The Contractor shall use the standard fittings / bends, as per IS-1239, Part-II.

- VII. Spacing and location of hanger shall conform to preferred engineering practice. Hangers and supports shall be made up of structural steel sections. The design of the hangers and supports shall provide for suitable protection to insulation on the pipes, wherever applicable. All materials for anchoring the hangers with reinforced concrete work or building structural beams and columns shall be furnished by the

Bidder. The supports within the plant room shall be of structural/pipe supports from the floor, provided by the A.C. Contractor.

- VIII. The flanged joints for water line will use canvas, impregnated rubber gasket. Compressed fiber gaskets shall be used with flat face flanges and raised face slip-on flanges. Spiral wound gaskets shall be used with raised face flanges, except for raised face slip-on flanges. Gaskets containing asbestos are not acceptable.

Gaskets shall be suitable for the design pressures and temperatures: -

- i) **Compressed Fiber Gaskets:** Compressed fiber gaskets shall be in accordance with ANSI B16.21, and materials shall be suitable for a maximum working pressure of 40 bar and a maximum working temperature of 400° C. Gaskets shall be dimensioned to suit the contact facing. They shall be full faced for flat face flanges and shall extend to the inside edge of the boltholes on raised face flanges. Gaskets for plain finished surfaces shall be not less than 1.6 mm thick and for serrated surfaces shall be not less than 2.4 mm thick.
- ii) **Spiral Wound Gaskets:** Spiral wound gaskets shall be constructed of a continuous stainless steel ribbon wound into a spiral with non-asbestos filler between adjacent coils. The gasket shall be inserted into a steel gauge ring whose outside diameter shall fit inside the flange bolts properly positioning the gasket. The gauge ring shall serve to limit the compression of the gasket to the proper value. Compressed gasket thickness shall be 3.3 mm $\pm$ 0.1 mm.
- iii) **Ring Joint Gaskets:** Ring joint gaskets shall be octagonal in cross section and shall have dimensions conforming to ANSI B16.20. Material shall be suitable for the service conditions encountered and shall be softer than the flange material.
- iv) **Rubber Gaskets:** Rubber gasket materials shall be cloth inserted sheet rubber and shall conform to ANSI B16.21. They shall be full face and 1.6mm thick.

The material should be able to withstand adequate strength in compression without damage. Pipe lines should be such installed that any equipment or valves can be removed by disconnecting flange bolts and nuts union joints. If necessary, a short piece joint to be installed for easy removal. All threads for screwed joints should be properly made. The threads will be covered to make a leak proof joint. Pipes passing through any building structure will pass through a pipe sleeve. The thickness of pipe sleeve will be not less than the

thickness of the passing pipe itself. A rubber grommet or such other material will protect pipes entering any equipment.

- IX. All drainpipes will use 'tee' fitting instead of elbows or bends. 'Tee' fitting should be such installed that the plug can be removed and any section of pipe can be cleaned. Drain valves will be located at lowest point of pipelines. If necessary more than one drain valve will be

installed to facilitate complete drainage from pipe. Condensate drain piping shall be insulated as per the specification.

- X. Water filling valve and air vent shall be installed on the highest point of pipeline. If necessary more than one valve is to be installed for satisfactory operation or maintenance of the plant. In case of insulated pipes the connections for pressure gauge, thermometer, drain valve, purge valve, filling valve and any such other accessories, the connection should be long enough such that the requisite pipe insulation can be carried out on the main pipe. The connecting pipes or fittings will be insulated separately if necessary. Location of instruments, fittings, fixtures shall be as in single line flow diagram. Location / sizes of air vents are also indicated.

- XI. The insulation will be fixed as per manufacturer's recommendation. Where valves, pipe fittings etc. occur, access to both shall be provided. Flange insulation shall be in two halves for easy removal without affecting insulation covering adjacent parts. Insulation of valves shall be with provision of aluminium valve boxes with hinged cover / halves.

- XII. Piping arrangement and alignment shall be as per layout.

6.07.00 Valves & Accessories

A. General

Valve pressure classes, sizes, types, body materials, and end preparations shall generally be as described herein. Special features and special application valves shall be utilized where required.

Valves specified to have flanged, socket-welded, or screwed connections shall have ends prepared in accordance with the applicable ANSI standards. Steel flanges shall be raised face type unless otherwise required. Cast iron and bronze flanges shall be flat-faced type. Butt-welding ends shall be prepared in accordance with 2.11.5 Butt Weld End Preparation and Piping Fit-Up.

Steel body gate, globe, angle, and check valves shall be designed and constructed in accordance with ANSI B16.34 as applicable. Valve bodies and bonnets shall be designed to support the valve operators (hand wheel, gear, or motor) with the valve in any position, without external support.

B. Steel Body Valves 50 mm and Smaller

Steel body valves 50 mm and smaller shall have forged steel bodies. Forged steel valves complying with the standards and specifications listed in Table 126.1 of ANSI B31.1 shall be used within the manufacturer's specified pressure temperature ratings with the following limitations. The use of Class 1500, 2500, and 4500 forged steel valves shall be limited in accordance with the pressure temperature ratings specified in ANSI B16.34, and the criteria established in MSS SP-84.

Class 800, 1500, 2500 and 4500 forged steel valves shall be constructed as follows: -

- a) Class 800 valves shall have bolted bonnet joints. Class 1500, 2500 and 4500 valves shall have pressure seal, integral, or breech lock bonnet joints. Gate, globe, and angle valves shall have outside screw and yoke construction.
- b) All valves, except gate valves, shall have seats of the integral type. Gate valves shall have renewable seats.
- c) Class 1500, 2500, and 4500 valves shall be of loose back seat design.
- d) Class 1500, 2500, and 4500 globe valves shall be of the Y-pattern type.
- e) Valve ends shall be socket-weld type unless otherwise required.
- f) Except as otherwise required, check valves shall be of the guided piston or swing disk type. All check valves shall be designed for installation in either horizontal piping or vertical piping with upward flow.

C. Steel Body Valves 65 mm and Larger

Steel body valves 65 mm and larger shall have cast steel bodies. The face-to-face and end-to-end dimensions shall conform to ANSI B16.10. The use of these valves shall be in accordance with the pressure temperature ratings specified in ANSI B16.34 as applicable.

Gate, globe, and angle valves shall be provided with back seating construction; and shall be of outside screw and yoke construction. Gate valves 100 mm and larger shall have flexible wedge disks. Split disks shall not be permitted. Valves shall have full size ports, except where venturi ports are specifically permitted to Engineer's approval. The use of valves with venturi ports shall be limited to selected large diameter, high-pressure valve applications.

Class 150, 300, and 400 valves 65 mm and larger shall be constructed as follows: -

- i) Bonnet joints shall be of the bolted flanged type having flat face flange facings for Class 150 valves; and male and female facings for Class 300 and 400 valves.
- ii) Body ends shall be butt weld type unless otherwise required.

Class 800, 900, 1500, 2500, and 4500 valves 65 mm and larger shall be constructed as follows: -

- i) Bonnet joints shall be of the pressure seal or breech-lock type.
- ii) All Class 800, 900, 1500, 2500, and 4500 valves shall have grease-lubricated antifriction bearing yoke sleeves.
- iii) Body ends shall be butt weld type unless otherwise required.

Check valves used on pump discharge installations, and on other applications in which the valves may be subjected to significant reverse flow water hammer or fluid surges, shall be of the non slam tilting disk type. All other check valves shall be of the guided piston, swing disk, or double disk spring check type. The use of double disk spring check valves shall be limited to 350 mm and larger cold-water services. All check valves shall be designed for installation in either horizontal or vertical piping with upward flow. Stop check valves, where specified, shall be Y-pattern globe type.

D. Iron Body Valves

Iron body gate, globe, and check valves shall have iron bodies with bronze trim. The face-to-face dimensions shall be in accordance with ANSI B16.10. These valves shall have flanged bonnet joints. Gate and globe valves shall be of the outside screw and yoke construction. Body seats shall be of the renewable type. Gate valves shall be of the wedge disk type. Lined cast iron body diaphragm and check valves used with lined piping shall be flanged body with liner and diaphragm material suitable for the service.

E. Butterfly Valves

Rubber-seated butterfly valves shall be generally constructed in accordance with AWWA C504 Standard for Rubber-Seated Butterfly Valves. The valves shall also generally conform to the requirements of MSS Standard Practice SP-67, Butterfly Valves. Valves of the wafer or lug wafer type shall be designed for installation between two ANSI flanges. Valves with flanged ends shall be faced and drilled in accordance with ANSI B16.1. The selected use of butterfly valves shall be in accordance with the pressure temperature ratings specified in AWWA C504, the pressure temperature ratings specified by the manufacturer as per the following criteria: -

- a) Butterfly valves shall generally be used for 150 mm and larger cold-water services only.
- b) Butterfly valves for buried service shall be of cast iron body material and shall be equipped with flanged ends.
- c) Cast iron butterfly valves shall have pressure class selected based on the piping design pressure as follows:

	Piping Design Pressure	Valve Class
i)	1.8 bar and below	Class 25

- | | | |
|------|---------------------------|-----------|
| ii) | Above 1.8 bar to 5.2 bar | Class 75 |
| iii) | Above 5.2 bar to 10.3 bar | Class 150 |
- d) Cast iron butterfly valves shall be limited to use with piping systems having a design temperature of 50 C or less.
- e) Butterfly valves for other than buried service shall be of carbon steel or cast iron body material depending on the service application. Valves 600 mm and larger in size shall be equipped with flanged ends. Valves 500 mm and smaller in size shall be of the wafer type, or lug wafer type, if used with steel piping; and shall be flanged if used with other piping materials (cast iron, etc.).
- f) Carbon steel butterfly valves shall be limited to use with piping systems having a design temperature of 65 C or less. Carbon steel butterfly valves shall have pressure class selected in accordance with the pressure temperature ratings specified in ANSI B16.34 for 600 mm and smaller valves. Valves 750 mm and larger in size shall be selected and specified based on the piping design pressure and temperature, without reference to a specific pressure class.

Metal seated or Teflon seal ring seated butterfly valves for special service applications shall be of the wafer or lug wafer type; and shall be designed for installation between ANSI flanges. The use of these valves shall be in accordance with the pressure temperature ratings specified by the manufacturer.

F. Bronze Body Valves

Bronze gate and globe valves 50 mm and smaller shall have union bonnet joints and screwed ends. Bronze gate and globe valves used in control air service shall have brazed joint ends. Gate valves shall be inside screw, rising stem type with solid wedge disks. Globe valves shall have renewable seats and disks.

Bronze check valves 50 mm and smaller shall be Y-pattern swing disk type or guided piston type designed for satisfactory operation in both horizontal piping and vertical piping with upward flow.

Bronze valves 65 mm and larger shall have bolted flange bonnet joints and flanged ends. Gate and globe valves shall be of the outside screw rising stem construction. Gate valves shall have either integral or renewable seats. Globe valves shall have renewable seats.

The use of these valves shall be in accordance with the pressure temperature ratings specified by the manufacturer and in accordance with the criteria established in MSS SP-80. Bronze valves shall generally be Class 200, and shall be limited to service with piping systems having design pressures of 14 bar or less, and design temperatures of 65°C or less.

Bronze valves shall generally be limited to a size of 80 mm or less.

G. Plug Valves

Plug valves shall be of the eccentric, lubricated, or Teflon sleeve plug type, as required by the service. Plug valve bodies shall conform to the requirements of ANSI for dimensions, material thickness, and material specifications. Bonnets shall be of the bolted flange type. Body ends shall be flanged, faced, and drilled

for installation between ANSI flanges. The use of these valves shall be in accordance with the pressure temperature ratings specified by the manufacturer.

H. Ball Valves

All ball valves shall have full area ports, Teflon seats & seals, and chrome plated carbon steel or stainless steel balls. Ball valve bodies 50 mm and smaller shall have threaded end connections. Ball valves 65 mm and larger shall have flanged ends. The valves shall not require lubrication. The use of these valves shall be in accordance with the pressure temperature ratings specified by the manufacturer.

I. Check Valves

These shall be swing check type with material of construction as given above. The body shall be of cast iron with flanged ends.

J. Flow Regulating-Cum-Measuring Valves

These are special valves to be installed at the outlet of each cooling coil/heating coil as shown in drawings. The Contractor shall also supply measurement it including manometer. The valves shall be of variable orifice design double regulating type. The valve shall have measurement ports for connecting the manometers. The Contractor shall supply all calibration charts etc. The valve shall have provision for locking at pre set flow condition and it shall be possible to close the valve and again open up to this pre set point. The valves shall be of gun-metal/bronze construction.

K. 3-Way Mixing Valves

These are special valves to be installed at the outlet of each AHU heating coil as shown in drawings. The motor shall be actuator based controlled. The valve shall operate from the sense of the room thermostat. The Contractor shall also supply measurement kit including manometer. The valves shall be of variable orifice design double regulating type. The valve shall have measurement ports for connecting the manometers. The Contractor shall supply all calibration charts etc. The valve shall have provision for locking at pre-set flow condition and it shall be possible to close the valve and again open up to this pre set point. The valves shall be of gunmetal / bronze construction.

L. Refrigerant Valves

All refrigerant valves as may be applicable shall have Brass body with flange connection or sweat connection for welding or brazing to pipe. For copper pipes size 5/8" and below flare connection will be acceptable. The valve body and bonnet connection shall have bolted and welded connection.

It is preferable to have Teflon gland packing for the valves construction of the discs of the valves shall be either globe or angle type. The valve seat shall have white metal lining or any equivalent soft replaceable lining. The valves shall be of tested quality. Leak proof-ness of the valves shall be tested at

minimum 1.5 times the design pressure for the system but not less than 35 Kg / Sq. Cm.

6.08.00 Air Handling Equipment

6.08.01 Air Handling Units

A. FAN

The fans shall be forward/backward curve bladed centrifugal type. The number of fans per unit shall be as per standard of the manufacturer. The impeller and the scroll casing of the fans shall be made of steel and protected with suitable painting as per Manufacturer's standard.

The fan shaft shall be of Carbon steel. Bearing shall be heavy-duty self-aligning type. The fans shall be dynamically balanced. The motor shall be adequately rated to prevent overload.

B. DRIVE

Centrifugal fans shall be equipped with V-belt drive and belt tensioning arrangement. All belts shall be sized with 1.1 service factor. All belt drive shall be equipped with removable guards to avoid accidental hazards. There shall be a minimum of two belts per drive.

C. DRY FILTER

The filter media shall be designed to hold dust and prevent it from being dislodged by vibration or other cause and passing through filter.

The filters shall be of dry panel type. The filter shall have G.I. frames of adequate thickness but not less than 20 SWG suitable for long use in an industrial plant. The filters may be in panels of sizes about 600 mm x 600 mm for easy handling of the same. The face velocity of air across the filters shall not exceed 2.5m/sec and maximum limitation pressure drop will be 6 mm of WG. Filter thickness will be at least 50 mm. The efficiency shall be about 90% down to 10-micron size particles.

D. COOLING COIL

The cooling coil for chilled water shall consist of seamless copper tubes with aluminium fins. There shall be preferably only one cooling coil per AHU or as per manufacturer's standard.

The cooling coil for chilled water plant shall be equipped with manually - operated flow regulating valve with provision for flow balancing at site to control the chilled water flow. This cooling coil shall be designed for chilled water / air duty. Counter-flow process of heat transfer shall be considered in the design requirement. The flow factor of 0.001 Hr. Sq. Ft. - °F / BTU (0.0002 hr - Sq. M °C / Kcal) shall be taken in the design of the cooling coil. Number of rows shall be minimum 4 and shall follow even number for any

particular coils to facilitate connection of water/refrigerant only on one side of the unit.

Fin design shall be chosen for the duty to be performed with special attention to the possibility of lint accumulation. However, in any case, number of fins in the coils shall not exceed 13 / Inch. Velocity of air across the coils shall be limited to 2.5 m/sec.

In case of chilled water-cooling coil, arrangement for air purging and water draining from the coil is to be provided.

E. CASING

- a) The casing shall be of double skin type GI with at least 25mm thick PUF insulation (density approximately 35Kg/ M³) in between two skins (made of 24 G GI sheet) and complete with supply air outlets with volume control dampers and flexible connections, structural frame work with supports and serrated rubber pads as vibration isolators and shall be provided with thermal break at the joints of different sections. Outer skin of the AHU shall be powder coated.
- b) Base frames shall be supplied for floor mounted type units. Drain pans shall be in SS-304 construction having at least 65mm depth and shall be fabricated in such a way to form the slope towards drain point.
- c) The main structure of the Unit (i.e. framework) shall be in extruded aluminium construction. The structural members shall have industrial anodized finish to form scratch proof, corrosion resistant, smooth finish surface. The structural member shall have a thermal break between inner & outer surface to minimize heat loss. The sealing surface of the extrusions shall be provided with the groove to hold the gasket. The gasket shall be of synthetic construction having tubular shape for proper sealing. The inner face of the panels shall be flushed with inner face of the extrusions to minimize the corners.
- d) Panels of the casing shall be fitted reasonably airtight with suitable gaskets with cams or similar fastenings for easy opening.
- e) Necessary arrangement shall be provided on the casing for measuring temperature and pressure in a cooling coil.

- f) Easily open able inspection doors shall be provided at required locations for easy maintenance. The Doors shall have handles and hinges in glass filled nylon construction.
- g) The Lock shall be flushed type to minimize projections. Locks shall have proper arrangement to secure the doors tightly.

6.08.02 Fan Coil Units

- A. The fan coil units shall be of reputed make – horizontal type for ceiling suspension. The units shall be complete with chilled water coil, one or more centrifugal fans and motors, cleanable HDPE filters, double wall insulated condensate drain pan with 15 mm thick expanded polystyrene (self extinguishing quality) insulation sandwiched between top and bottom sheets of drain pan and 18 gauge sheet steel casing panels. Horizontal fan coil units shall be provided with auxiliary secondary condensate drain pans.
- B. Access panels shall have positive locking fasteners for easy removals. The filters shall be mounted at the rear section of the cabinet with filter box.
- C. All cooling coils shall be standard three row staggered seamless copper tube with aluminium plate fins mechanically bonded to copper tubes. Tubes shall be aluminium 10 mm O.D. and wall thickness shall be minimum 0.5 mm. All bends and joints shall be enclosed within the insulated end sections of the base unit for protection against sweating. Each coil shall be provided with an air vent and drain plug. All coils shall be factory tested at 21 kg. Per Sq. cm. air pressure while submerged in water. Fin spacing shall not be less than 10 fins per inch. Tubes shall be mechanical / hydraulically expanded for thermal contact resistance with fans.
- D. Fans shall be centrifugal, forward-covered, and direct driven by shaded pole motor.
- E. All fans coil units shall be equipped with copper piping connection and manual air vent at the cooling coil. Other accessories shall be wall mounted thermostat for individual unit, containing two speed and ON / Off control for fan speed, motorized three-way diverting/mixing valve for individual unit, Y-strainer, ball valve and globe valve, adjustable discharge air grilles.
- F. The fan coil unit shall be selected for the lowest operating noise level. It should offer capacity at the lower speed.

6.09.00 Air Filters

6.09.01 Pre-Filters

The filter media shall be designed to hold dust and prevent it from being dislodged by vibration or other cause and passing through filter.

The filters shall be of HDPE construction. The filter shall have G.I. frames of adequate thickness but not less than 20 SWG suitable for long use in an industrial plant. The filters may be in panels of sizes about 600 mm x 600 mm for easy handling of the same. The face velocity of air across the filters shall not exceed 2.5m/sec and maximum limitation pressure drop will be 6 mm of WG. Filter thickness will be at least 50 mm. The efficiency shall be about 90% down to 10-micron size particles.

6.09.02 High Efficiency Filters

The filters shall be having efficiency of 99% down to 5 microns. The filters shall be of cleanable type construction of reinforced glass fiber or cotton fabric or fabric-like material sandwiched in between two galvanized wire netting arrangement in a uniformly corrugated form to increase the surface area.

The filters shall have G.I. frames of adequate thickness suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling.

The filter panels shall be mounted on the ladder type angle iron holding frames. The frames shall be designed strong enough to take the load of double the pressure drop in dirty condition of the filters. Face velocity of air across the filters shall not exceed 1.5 m/sec.

High efficiency filters shall be provided with differential pressure switch with alarm.

6.10.00 Duct Work

6.10.01 Velocity of air in any section of the supply duct shall not exceed 8 m/sec.

6.10.02 Sheet metal thickness for AC duct shall conform to IS-655.

6.10.03 The general layout of the ducting location and number of air grilles and diffusers etc. shall conform to the specific requirements of individual areas of application so as to ensure proper air distribution of all the zones. The same shall be subject to approval by the Engineer.

6.10.04 Where dimensional locations are not indicated on the drawings, the Contractor will be responsible for the final arrangement and routing of the ductwork. Variations in duct sizes may be made as acceptable to the Owner if the cross-sectional area remains the same and the revised aspect ratio is less than four. Ductwork will be arranged to minimize pressure drop using low-loss fittings and transitions. Where radius elbows are used for duct turns, the radius ratio will not be less than 1.5 wherever possible. Where space limitations require a bend with a radius ratio of 0.75 or less, not less than two turning vanes will be installed in the bend.

6.10.05 All ductwork for supply of air inclusive of accessories such as damper, vanes, access doors etc. shall be fabricated from G.I. sheet of at least grade 180 as per IS 277 or aluminium sheet. The ductwork shall be properly reinforced to prevent sagging, buckling or vibration. Interior of all ducts shall be smooth and free from obstruction. All duct sections shall be cross-broken.

6.10.06 The construction of ducts shall conform to IS : 655/ASHRAE/SMACNA as far as applicable, unless otherwise stated here.

6.10.07 JOINTS

- a) All longitudinal joints for the ducts will be Pittsburgh Lock seam type.
- b) Transverse joints for the low-pressure ducting shall be continuous around the four sides, the corner closure are required. The type of transverse joints shall be as follows:

<u>Large side mm</u>	<u>Type of transverse joints</u>
Up to 600	25 mm wide pocket, drive or S-slip
601 - 1000	85 mm wide, bar s-slip or pocket slip
1001 – 2250	40 mm x 40 mm x 6 mm M.S. angle connection

- c) The low-pressure ducting work shall be provided with intermediate transverse bracing continuous around the four sides between the joints according to the following sizes:

<u>Large side mm</u>	<u>Bracing</u>
0 - 450	None
451 - 1500	40 mm x 40 mm x 6 mm angle 1200 from joints.
1501 and above	40 mm x 40 mm 6 mm angle 600 mm from joints.

- d) Riveting and Sealing

All joints, slips and seams shall be made secure by reverting on centres not exceeding 150 mm. All transverse stiffeners and all reinforced bar slip joints shall cross at corners and be riveted. All bar slip joints and angle iron bracing shall be riveted on centres not exceeding 75 mm.

- e) All construction joints and duct seams shall be reasonably sealed with bitumastic cold emulsion or equivalent vapour seal.

6.10.08 Hangers and Supports

- a) All ductwork shall be provided with adequate hangers or supports to ensure rigid support and to prevent vibration. Spacing of duct supports shall not exceed 3 m centres.
- b) Hangers shall be suspended from the building steel with provision for necessary auxiliaries, or special steel members, or by hooks fixed to the embedded plates provided in the ceiling.
- c) Hangers for all ducts shall be trapeze type with the shelf construction from 35 mm x 35 mm x 5 mm angle iron and hung by two steel rods each of not less than 10 mm dia. for ducts, with larger side less than 2250 mm while for those greater than 2250 mm shall be with 50 x 50 x 5 angles and rods not less than 16 mm dia.
- d) All hangers and supports shall be as per drawings / specifications. When vertical ducts pass through floor slab, they shall be supported by means of collars, constructed of steel structural angles securely fastened about the girth of the duct and bitumastic compound between the horizontal leg of the supporting angle and the floor. The duct aspect ratio shall not be more than 4: 1. Turning vanes are required to be provided with bend more than 45 Deg.

6.10.09 Access Doors

All main ductwork shall be accessible throughout using tight fitted hinged access doors. Doors shall have to be cemented on sponge rubber gaskets. Angle joints shall be provided with felt or rubber gaskets for leak-tightness of the joints.

Access doors/panels are to be provided at following places:

- Near each fire damper
- Near each heater coil
- Near each filter bank

In case access doors are to be installed in the insulated ducts, the access door panel should be suitably insulated, such that it can be operated without damaging the duct insulation and there should be no condensation either on the access doors or on the duct when the plant is running.

6.10.10 Flexible Connection

Rubber impregnated canvas or equal flexible connections of at least 150 mm length shall be provided at each connection between ductwork and fan units.

6.10.11 Dampers

- i) **SPLITTER DAMPER**

Splitter dampers in branch take off shall be provided. Dampers blades shall be minimum 16 SWG thick. Alternatively catcher shall be provided in right angle tee of ducts.

ii) FIRE DAMPER

~~Fire dampers shall be provided as per the requirement mentioned elsewhere in the specification. The fire dampers shall be of motorised / solenoid/fusible link type operated by smoke detectors of the zone fire fighting system. The fire damper shall be smoke-tight type and shall have 120 min fire rating. Provision shall be kept for manual operation of the damper.~~

Blade thickness : At least 16G CRCA
Frame : At least 40 x 40 x 3 mm Angle.

Motorised Fire Dampers shall be rated for 240 V, 50 Hz, 1 Ph., AC supply. Motor for Fire dampers shall be continuously rated. These Dampers shall close on de-energisation and open on energisation of Motor. Provision shall be kept for manual operation of the Damper.

Fire dampers will be provided at the supply/exhaust duct for fire-rated walls/floors as required by National Fire Protection Association (NFPA) and International Building Code (IBC).

iii) ACTUATORS

The actuators will be UL listed.

Dampers will be equipped with operators of sufficient power to control dampers, without flutter or hunting, through the entire operating range at air velocities at least 20 percent greater than maximum design velocity. Operators will have sufficient power on closure to provide tight sealing against maximum system pressures. Damper actuators will be designed to provide a minimum of 200 percent of the torque required to operate the damper and to meet the air leakage criteria. Damper actuators will not be less than 2.26 N-m (20 inch-pounds). Each damper section will contain one or more damper actuators. Jack-shafting of the section is not permitted.

Operators functioning in sequence with other operators will have adjustable operating ranges and set points.

Spring-return operators will be provided for two-position control or on reversible operators where required for fail-safe operation.

Electric motor operators for modulating control will be reversible type.

Locations where temperatures fall below minimum operating temperature of operator will be heated.

When dampers are installed on ducts to be externally thermally insulated, each damper operator will be equipped with stand-off mounting brackets, bases, or adapters to provide clearance between the duct and operator not less than the thickness of insulation. Standoff mounting items will be integral with the operator or standard accessory of damper manufacturer.

iv) OPPOSED MULTIPLE LOUVRE DAMPER

Opposed multiple louvers dampers shall be provided at the fan outlets and wherever mentioned in the drawings, specification and fan schedule. Each blade of the dampers shall be provided with bronze, gunmetal or nylon bearing at each end of its spindle. The spindle with bearing shall be mounted in a strong structural framework. Operating lever with fixing device for keeping the damper at the desired position shall be fitted for the manually operated dampers.

Operating level will be fixed on an indicator to show the percentage of opening of the damper in all cases except for the application with grilles and nozzles.

Velocity across the dampers shall not exceed 10 m/sec. Damper blades at fan outlet shall be made up of 16 gauge M.S.

6.10.12 Diffusers, Grilles, Registers - Conventional Design

Design of grilles & diffusers shall be such as to create desired throw and spread of air and shall be approved by the purchaser/engineer.

All diffusers and grilles shall be made up of powder coated sheet steel / extruded aluminium with finish painting. Design of all diffusers and grilles shall be made by the Contractor matching with the lighting and other fittings and to be approved by the Engineer. Each supply air diffusers shall be fitted with opposed blade damper, built-in vanes and louvers arranged as per manufacturer's standard design.

Side throw type supply registers shall have two sets of adjustable louvers with opposed blade dampers. The front of louvers shall be horizontal to provide horizontal deflection and the rear set of vertical louvers shall adjust vertical deflection. The dampers shall have horizontal opposed blades regulated by an operating lever in the frame. All wall type exhaust / return air grilles shall have one set of louvers in the front. The louvers shall be fitted such as to remain in position by friction grip. All supply air grilles shall have one set of opposed multiple louver dampers at the inlet. The dampers shall be gang operated and will have a device to keep the dampers fixed in one position.

The grille frame and louvers shall be manufactured of at least 20 SWG GI sheet and 22 SWG M.S. respectively. No grilles should by any chance make any rattling sound during continuous operation. All grilles shall match the decor of the space.

All grilles/diffusers shall be fitted with suitable gasket to prevent air leakage.

6.11.00 **Insulation**

6.11.01 Thermal Insulation

- A. The following items are to be insulated:
- I. Refrigerant suction piping from the evaporator coil outlet up to the compressor inlet shall be insulated with minimum 39 mm thick aluminium foil faced Nitrile rubber/ XLPE for Screw type Package Water Chilling Unit and 26 mm Nitrile Rubber/XLPE with 30G Aluminium sheet Cladding for Precision/ Split Air Conditioner. For better efficiency of operation the liquid line running side by side with the suction line may be insulated together with the suction line already mentioned.
 - ~~II. Double skin Casing of the cabinet type air-handling unit with at least 25 mm thick Poly Urethane Foam (PUF)/ EPS sandwiched between them.~~
 - ~~III. Supply air duct and part of the return air duct passing through non conditioned space, if any, with at least 13mm thick aluminium foil faced Nitrile Rubber / XLPE Insulation~~
 - ~~IV. Entire chilled water-piping, valves, chilled water circulating pumps, and chillers with 39 mm thick aluminium foil faced Nitrile rubber/XLPE.~~

The portion of Chilled water piping exposed to atmosphere shall be insulated with 50 mm thick (TF quality) expanded polystyrene and finished with chicken wire mesh, 12 mm thick sand-cement plaster and an overall cladding of 30G Al. sheet.
 - V. Drain Piping from AHU/Precision ACs /Split AC unit/ FCU and Chillers shall be insulated with 13 mm/ 6mm (for FCU and Split units) thick aluminium foil faced Nitrile Rubber/ XLPE.
 - ~~VI. Screw type Packaged Chiller and Chilled Water Pump shall be insulated with 39 mm thick aluminium foil faced Nitrile Rubber/ XLPE.~~
 - ~~VII. Chilled water Expansion tank drain piping with 6 mm thick aluminium foil faced Nitrile Rubber/XLPE.~~
 - VIII. Insulation of Precision AC Unit/ Split AC Unit shall be as per manufacture's standard.
 - IX. Roof of AC spaces shall be insulated with 25 mm thick EPS (under deck) for not exposed to sun and 50mm thick EPS (under deck) for exposed to sun.
- B. Insulation shall be fixed as per manufacturer's recommendation. Due care shall be taken to avoid damage to vapour arresters and insulation.
- C. Extra insulation thickness shall be provided at duct pipe hangers and special care shall be taken to seal the insulation and hanger member penetrations and instruments and accessories tapings.

- D. Special care shall be taken to provide satisfactory insulation for valves, flanges, vessel connections etc. with proper facility for maintenance and inspection.
- E. Insulated ducts crossing the floors shall have to be normally protected from damage and water splashing by providing suitable cladding up to 300 mm from the floor level.

6.11.02 Acoustic Insulation

All supply air ducts in the air conditioning system shall be insulated with Acoustic insulation of 25 mm thick open cell erosion resistant Nitrile Rubber foam of density min. 140 Kg/CuM provided in the ducting up to a length of 6 M from the Air Handling Unit / Precision Air Conditioner.

6.12.00 Precision / Split AC Units

6.12.01 Water Cooled Precision Air Conditioners

A. Compressor

The compressor shall be hermetically sealed scroll type medium speed, single acting type designed for R-407C/410A duty. The compressor shall be complete with crank case heater (to be energised when compressor is on off cycle).

The compressor shall have proper lubrication system. Safety devices viz. high-pressure switch, low-pressure switch, low oil pressure (if applicable) shall be provided and such devices shall be electronically operated. Manual reset on safety cut out shall be provided. The horsepower for the compressor motor shall be adequately sized or 110% of the rated power required for the unit including drive loss.

Capacity control shall be devised by providing at least two compressors.

B. Condenser

All condensers shall be of shell and tube type with water in the tubes and refrigerant in the shell.

The heat exchanger shall be designed for a minimum working pressure of 10.5 kg/cm² gauge on the water side and 19.0 / 27.0 kg/cm² for R-407C / 410A on the refrigerant side and shall generally conform to the latest ASME CODE for unfired pressure vessels Section- VIII. The design pressure shall have a reasonable margin over the maximum working pressure.

The average velocity of water in tubes shall not be more than 2.5 m/sec.

Water heads or refrigerant heads of the heat exchangers shall be as not to allow leakage of fluid from one pass to the other.

Tube supports of adequate strength shall be provided to prevent the tubes from sagging and vibrating.

The overall fouling factor for the condensers shall be $0.0002 \text{ Hr.M}^{20}\text{C/K.Cal.}$

The condensers shall be designed to provide at least 2°C sub cooling of refrigerant under rated design condition.

Testing and other design feature of the heat exchanger shall meet the requirements of TEMA Class-C heat exchangers or approved equal.

The heat exchangers shall have open able water boxes for ease in maintenance.

The tubes for the condensers shall also be copper with integral fins. The tube wall thickness at any point shall not be less than 18 SWG.

The baffle plates and the tube sheets shall be made of steel. The shell shall be made up of seamless tube or shall be fabricated from flange quality steel plate (ASTM-A285 Grade-C). The tube support plates shall be made of flange quality carbon steel plates and shall be as per TEMA Standard.

The heat exchangers shall be provided with vent valve, relief valve, and/or safety fusible plug on refrigerant side and vent valve and drain valve on water side (at every section of the baffled shell of heat exchanger).

The tenderer shall quote packaged units having compressor, condenser and evaporator assembly together in a single framework and mounted on a common base plate. Provision for refrigerant charging and chemical cleaning of water tubes shall be provided.

Each heat exchanger shall be provided with water flow switch. This shall be interlocked with the control of the individual refrigeration system/ corresponding compressor drive.

All the heat exchangers shall be provided, with standard connections like thermo wells, inspection valve and antifreeze thermostat and external equaliser connection for expansion valves. Insulation shall be terminated in such a manner that it will not be damaged during removal of bolts, covers etc. Separate covers similar to flange covers shall be constructed to facilitate easy removal.

The design pressure shall have a reasonable margin over the maximum working pressure.

C. Evaporator Cooling Coil

The cooling coil shall be direct expansion type with multi-row deoxidised copper tubes with aluminium fins. Air velocity across the coil shall be limited

to 2.5 m/sec. The coils shall be pressure tested and thoroughly dehydrated before assembling.

The coil shall be placed to make the system draw through type. Refrigerant feed control shall be by electronic expansion valve. Temperature control shall be through microprocessor based control panel. Insulated condensate drain pan of SS construction shall be provided within the unit.

The unit shall be factory assembled, wired, with inter connecting refrigerant piping and built-in microprocessor based control console and tested as per the relevant code.

The cooling coil shall be to produce the capacity required under specified coil condition and air quantity. Heat load calculation to check the system selection shall be carried out and submitted by the tenderer.

D. Evaporator Fan

The fan shall be heavy duty DIDW centrifugal type statically and dynamically balanced with forward/backward curve blade, directly driven by high efficiency EC motors. Fan wheels and casing shall be constructed of steel and mounted on steel shaft. The bearings shall be ball bearing type mounted on vibration absorbing rubber mounts. The fan motor shall be mounted within the cabinet. Motor horsepower shall be sized for 120% of the rated power required.

The supply fan shall be sized to deliver the required air quantity against the total external static pressure required for the system application, after taking care of all internal static pressure requirements of the units.

E. High Efficiency Filter

A set of High efficiency filters will be located inside the PAC unit cabinet. The filters shall be high efficiency of 99% down to 5 microns. The filters shall be of cleanable type construction of reinforced glass fiber or cotton fabric or fabric-like material sandwiched in between two galvanized wire netting arrangement in a uniformly corrugated form to increase the surface area.

The filters shall have G.I. frames of adequate thickness suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling them.

The filter panels shall be mounted on the ladder type angle iron holding frames. The frames shall be designed strong enough to take the load of double the pressure drop in dirty condition of the filters. Face velocity of air across the filters shall preferably not exceed 1.5 m/sec.

F. Humidifier

The humidifier shall be of Electrode type and shall be placed inside the PAC unit cabinet. The humidifier shall be electronically controlled through the built-in microprocessor based control panel of the unit. A provision of make-up water connection with the humidifier shall be kept with the Unit cabinet.

G. Electric Strip Heater

The PAC unit will be provided with built-in electric strip heater electronically controlled through the built-in microprocessor based control panel of the unit.

Such control includes both operating and safety controls with the sense of air temperature at the RA path and at the downstream side of the heater respectively.

H. Casing and Cabinet

All components shall be housed in a welded sheet metal cabinet of double skin of not less than 22 G thick MS powder coated sheets. The gap between two skins is filled up with at least 25mm thick PUF/ EPS insulation. Different sections will be constructed with framework and connected with each other in an airtight manner through gaskets, thermal barriers and sealant.

Removable panels shall be constructed of framed 1.6 mm sheet steel with angle iron framing. Units shall be provided with 316 L.S.S. fasteners for easy removal and access for servicing. Air handling section of evaporator shall be provided with an acoustic lining of 25 mm thick fiberglass covered with fiber glass cloth and perforated aluminium sheet on the inside surface of the unit casing.

The return air opening shall be on the front face with a matching grille of same colour finish.

6.12.02 Air Cooled Precision Air Conditioners

A Compressor

The compressor shall be hermetically sealed scroll type medium speed, single acting type designed for R-407C/410A duty. The compressor shall be complete with crank case heater (to be energised when compressor is on off cycle).

The compressor shall have proper lubrication system. Safety devices viz. high-pressure switch, low-pressure switch, low oil pressure (if applicable) shall be provided and such devices shall be electronically operated. Manual reset on safety cut out shall be provided. The horsepower for the compressor motor shall be adequately sized or 110% of the rated power required for the unit including drive loss.

Capacity control shall be devised by providing at least two compressors.

B Condenser (Outdoor Unit)

The Condenser shall be of Air Cooled type and shall be constructed of copper tube with aluminum fins. Tubes shall be designed for a minimum working pressure of 30 kg/ sq. cm. The condenser shall be complete with

fans with drive motors and shall be provided with charging connection, safety relief valve and standard accessories, all encased in a powder coated GI casing with built-in electrical items and supporting frame. The condenser shall have the matching capacity with the compressor. There shall be a provision of isolating switch for the fans.

C Evaporator Cooling Coil

The cooling coil shall be direct expansion type with multi-row deoxidised copper tubes with aluminium fins. Air velocity across the coil shall be limited

to 2.5 m/sec. The coils shall be pressure tested and thoroughly dehydrated before assembling.

The coil shall be placed to make the system draw through type. Refrigerant feed control shall be by electronic expansion valve. Temperature control shall be through microprocessor based control panel. Insulated condensate drain pan of SS construction shall be provided within the unit.

The unit shall be factory assembled, wired, with inter connecting refrigerant piping and built-in microprocessor based control console and tested as per the relevant code.

The cooling coil shall be to produce the capacity required under specified coil condition and air quantity. Heat load calculation to check the system selection shall be carried out and submitted by the tenderer.

D. Evaporator Fan

The fan shall be heavy duty DIDW centrifugal type statically and dynamically balanced with forward/backward curve blade, directly driven by high efficiency EC motors. Fan wheels and casing shall be constructed of steel and mounted on steel shaft. The bearings shall be ball bearing type mounted on vibration absorbing rubber mounts. The fan motor shall be mounted within the cabinet. Motor horsepower shall be sized for 120% of the rated power required.

The supply fan shall be sized to deliver the required air quantity against the total external static pressure required for the system application, after taking care of all internal static pressure requirements of the units.

E. High Efficiency Filter

A set of High efficiency filters will be located inside the PAC unit cabinet. The filters shall be high efficiency of 99% down to 5 microns. The filters shall be of cleanable type construction of reinforced glass fiber or cotton fabric or fabric-like material sandwiched in between two galvanized wire netting arrangement in a uniformly corrugated form to increase the surface area.

The filters shall have G.I. frames of adequate thickness suitable for long use in an industrial plant. The filters may be in panels of size about 600 x 600 for easy handling them.

The filter panels shall be mounted on the ladder type angle iron holding frames. The frames shall be designed strong enough to take the load of double the pressure drop in dirty condition of the filters. Face velocity of air across the filters shall preferably not exceed 1.5 m/sec.

F. Humidifier

The humidifier shall be of Electrode type and shall be placed inside the PAC unit cabinet. The humidifier shall be electronically controlled through the built-in

microprocessor based control panel of the unit. A provision of make-up water connection with the humidifier shall be kept with the Unit cabinet.

G. Electric Strip Heater

The PAC unit will be provided with built-in electric strip heater electronically controlled through the built-in microprocessor based control panel of the unit.

Such control includes both operating and safety controls with the sense of air temperature at the RA path and at the downstream side of the heater respectively.

H. Casing and Cabinet

All components shall be housed in a welded sheet metal cabinet of double skin of not less than 22 G thick MS powder coated sheets. The gap between two skins is filled up with at least 25mm thick PUF/ EPS insulation. Different sections will be constructed with framework and connected with each other in an airtight manner through gaskets, thermal barriers and sealant.

Removable panels shall be constructed of framed 1.6 mm sheet steel with angle iron framing. Units shall be provided with 316 L.S.S. fasteners for easy removal and access for servicing. Air handling section of evaporator shall be provided with an acoustic lining of 25 mm thick fiberglass covered with fiber glass cloth and perforated aluminium sheet on the inside surface of the unit casing.

The return air opening shall be on the front face with a matching grille of same colour finish.

6.12.03 Non-Duct able Split Type Air Conditioning Units

A. General

I. The split type room air conditioner consists of two units one Indoor unit (Evaporator) & an Outdoor unit (Condenser). It will be complete with all components to perform filtering and cooling of air in all seasons except winter. The refrigerant condenser will be air-cooled. The unit will be suitable for wall mounting.

- II. The unit shall have normal rating capacity as per the schedule mentioned elsewhere in the specification measured at a room temperature 24 °C DB and RH not exceeding 65% under design outside conditions specified elsewhere. The capacity variation should not be more than 5%.

B. Indoor Unit

- I. The indoor unit consists of panel type dry filter, cooling coil, evaporator fan etc.
- II. The filter is panel type dry having an efficiency of 90% down to 10-micron size Particles. The filter media shall be designed to hold dust, sand and prevent it from being dislodged by vibration or other cause and passing through filter. The face velocity of air across the filters shall not exceed 2.5 m / sec.
- III. Cooling coil will be direct expansion type made of seamless copper tubes with aluminum fins, number of fins as per manufacturer's standard but not more than 13 per inch & R22. The coils should be located at the suction side of the Evaporator Fans. Velocity of air across the coils shall be limited to 2.5 m/sec.
- IV. Piping accessories like Hot gas piping, cold gas piping and liquid refrigerant pipeline all made of copper complete with at least 26 mm thick Aluminium foil faced Nitrile rubber / XLPE or equivalent insulation interconnecting indoor and outdoor units, liquid line valves, liquid refrigerant piping, gauges and instruments, filter-drier, moisture indicator, isolating valves etc., shall be provided as may be required for safe and trouble free operation.
- V. The evaporator fan shall be Centrifugal, DIDW with forward Curved blades directly driven by TEFC squirrel cage induction motor operating in AC 240 V $\pm$ 10%, 1 Ph, 50 Hz $\pm$ 5% supply, with 3- step speed control. The evaporator fan shall be both statically and dynamically balanced.
- VI. Sheet metal casing with inspection facilities, made of Powder coated M.S. sheet and complete with suitable refrigerant pipe connections, insulated drain pan, insulated drain piping, supply and return air opening with decorative grilles with automatically swiveling louvers (for supply air grilles). The casing should be insulated inside to prevent condensation. This shall be provided from inside surface to limit the noise.

C. Outdoor Unit

- I. The outdoor unit shall consist of a compressor, air cooled condenser with liberally sized aluminium finned copper tube coil and low noise directly driven fan and totally enclosed weather proof motor housed in power coated MS casing.

- II. The Compressor shall be rotary type with R-22 refrigerant of specified capacity & motor. The compressor assembly shall be adequately designed for minimum vibration and noise disturbances. The compressor rotor assembly shall be dynamically balanced. The shaft seal shall be of proven design. The horsepower for the compressor motor shall be sized for 115% of rated power required for the unit including the drive loss.
- III. Accessories like Suction and discharge valves, safety valve, HP and LP cut out switches, powder coated sheet metal casing, vibration-isolating device, foundation bolts, built in Electricals like starters, switch fuse units, relays, contactors. The speed of the compressor should not exceed 1500 rpm.
- IV. Air-cooled condenser with directly driven axial flow fan & adequately sized drive motors (TEFC squirrel cage Induction type) with relief valve, hot gas connection, charging connection with valve, louver at the intake & exhaust of air, and other standard accessories. The condenser fan shall be both statically and dynamically balanced.
- V. The heat exchangers shall be designed for a minimum design test pressure of 20.33 Kg/m² on the refrigerant pipe. The design pressure shall have a reasonable margin over the maximum working pressure. Tube supports of adequate strength shall be provided to prevent the tubes from sagging and vibrating. The condensers shall be designed to provide at least 4°C sub cooling of refrigerant under rated design condition. The unit should be operating free from any vibration and noise.
- VI. The piping will be thermally insulated wherever required such that there is no condensation on the outside of the piping. The insulation will be of Aluminium foil faced XLPE or Nitrile rubber or equivalent.
- VII. Refrigerant piping shall be either of M.S. seamless (as per IS-1239, Part-I heavy grade) or copper tube (IS-5493) or ASA-9-31.5). Pressure drop in hot gas, liquid and suction lines should not exceed the value corresponding to 2 °F change in saturation temperature of the refrigerant. Velocity in the discharge and suction pipe of the refrigerant shall not be so high as to create undue vibration and noise, velocity in the vertical length of discharge and suction pipe of the refrigerant shall be high enough to carry the entrained oil in the refrigerant, even in case of unit running at lowest partial capacity. Instrument piping for gauges, switches etc. shall be of copper only.
- VIII. All the above equipment along with the electrical items like starter, contactor and other controls shall be encased in a powder coated MS casing. The casing shall be complete with supports fabricated out of MS angles, & sheets (duly painted), anchor bolts, nuts etc. The entire unit shall be installed with rubber pad type vibration isolators.

IX. All refrigerant valves as may be applicable shall have steel or brass body with flange connection or socket connection for welding or brazing to pipe. For copper pipes size 5/8" and below flare connection will be acceptable. It is preferable to have the stems of rising stems inside screw type. The valve body and bonnet connection shall have bolted or welded connection.

X. It is preferable to have Teflon gland packing for the valves. The construction of the discs of the valves shall be either globe or angle type. The valve seat shall have white metal lining or any equivalent soft replaceable lining. The valves shall be of tested quality. Leak tightness of the valves shall be tested at minimum 1.5 times the design pressure for the system.

6.13.00 Fresh Air System

6.13.01 For critical areas like control room, control equipment room etc., outside fresh air will be inducted into the AHU room/ PAC room through a Fresh Air system consisting of an inlet louver, dry panel type filter, a fan with a short duct (if necessary), SA register and mixed with the return air in AHU room/ PAC room.

For other non-critical areas like service building fresh air will be inducted in the AHU room through the wall mounted rain protection cowl with bird screen and a volume control damper.

6.14.00 Miscellaneous Items

6.14.01 Heater

A. Strip heater

I. Heating equipment wherever required shall be electrical type. All frame members, control box cover and associated sheet metal parts are to be heavy gauge steel with corrosion resistance treatment. Heating equipment may be required for winter heating as well as for reheating. Reheating heaters may be used for winter heating also.

II. Electric heaters will be fin-tube type of specified KW rating, with fins permanently brazed to metal sheath. The metal sheath and fins will be of G.I. sheet material.

III. Wherever electric heaters are installed in the ductwork, size of ducts should be suitably increased to offset the additional resistance created by the heaters. All heaters shall be mounted on such insulators that there shall be no leakage current under all weather condition including high humidity operation. The mounting frame shall be suitably grounded by earth wires / earth leads of two points.

IV. An air stat is to be installed such that in case there is no circulation of air over the heater coils the heaters will be de-energised. Wherever the heaters are installed in the ductwork the terminal block will be such positioned in a junction box that it will be outside the ductwork in an accessible position. The junction box will be vermin proof, rat proof and provided with a hinged cover. A caution plate as per I.E. rules will also be provided. Access door will be provided in the duct near the heating coil for easy inspection and removal / replacement / fixing of individual strip heaters. The capacity of heaters will be distributed over three phases.

V. In case of reheating the heater will be controlled by humidity sensor & humidity transmitter and in case of winter heaters it will be controlled by temperature sensor & temperature transmitter.

B. Electric Room Heater

Electric Room Heaters shall be with High / Low control.

Electric Room Heaters shall be suitable for AC 240 V $\pm$ 10%, 1 Ph, 50 Hz $\pm$ 5% supply.

6.14.02 Electrode Humidifier

A. Electrode humidifier consists of high temperature Polypropylene water tank, electrodes, auto flash cycle activated on demand from the microprocessor based control system with humidity sensor, located in the AHU / PAC room. Such Humidifier shall be controlled by its own stand-alone microprocessor based control panel. Alarm indication will be provided for low water level in the water tank.

B. Whenever the relative humidity of the conditioned space reaches the minimum allowable percentage of humidity, the humidifier shall be energized to restore the relative humidity. The humidifier shall be such controlled that it shall not exceed the maximum allowable limit of relative humidity in the conditioned space. The humidifier shall be sized and designed accordingly.

6.14.03 Non Chemical Water Treatment Equipment

A. The water treatment equipment is a 1 M long pipeline, which once installed, stops the formation of scale in the heat exchange zones completely.

B. The water treatment equipment consists of Metal Cell and Core and is installed on line after the pumps and before the heat exchange zone. The distance of the heat exchange zone should not be more than 30 M and there should not be any static area between the water treatment equipment and heat exchange area.

6.15.00 False Ceiling

6.15.01 Scope

The work under this Section shall include the supply and installation of suspended ceiling using GYPSUM boards together with the suspension system as shown on drawing or specified in Schedule with all materials labour and equipment. The work shall also include providing of openings in the ceiling for lighting, air conditioning diffusers etc. as shown on drawings or instructed by the Engineer.

6.15.02. Installation

A. Suspension System

General

Suspension system shall consist of the grid supporting the ceiling panels, intermediate runner supports for the grid if any and hangers, wall angles etc. required to suspend the grid or the runners from structural walls, slabs and beams or trusses.

All members of the suspension system shall be of sufficient strength and rigidity to carry the ceiling boards or sheets in a true and level plane without exceeding a deflection of 1/360th of their span. All joints in ceiling panels shall run straight and cross joint shall be securely fixed to walls. All drillings of structural concrete or welding to steel for installation of the suspension system shall be included in the rate. All M S sections used for supports etc. shall be given one coat of synthetic enamel paint over a coat of red lead primer.

Metal Grid Suspension System

Aluminium grid ceiling system shall be "Beadlock" as manufactured by W A Beard shell and Co. Pvt. Ltd. or approved equal. Steel grid ceiling system shall be jolly snap grid as manufactured by Anil Hardboards Ltd. or approved equal.

Angle cleats or other suitable fixing device shall be fixed to the structural beam or slab above for fixing of hangers. Main runners shall be hung by MS flats, angles or 12 g or heavier galvanized tie wire hangers at maximum 1.2 centres. Extra hangers shall be provided at light fixtures that are supported from the ceiling system. The spacing of main and cross runners shall be as shown on drawings.

The cross tees shall intersect main runners in pattern shown on drawing and positively looked together with intersection clips. All perimeter areas shall have angle mouldings fixed to vertical wall surfaces & end tees shall rest on the moulding, unless otherwise shown on drawings.

B. CEILING PANELS

Installation of Ceiling panels shall be strictly as per manufacturer's instruction.

For exposed grid ceiling system, tile hold down clips shall be used at the rate of minimum one per 1.2 meter length of perimeter. These shall however be omitted in access panels which shall be located as per the instruction of the Engineer.

For concealed grid ceiling system, tiles shall be fixed to the supporting grid in manner shown on drawing or as specified by the manufacturer. Where V-joints in tiles are called for in drawings, these shall be in true lines. Where flush surface is required, the joints shall be filled with approved filler material and finished to give a neat uniform surface. Where shown on drawings and

schedule of items, 6 mm thick cement: lime: sand surface of ceiling boards and finished in a true and even surface without undulations suitable for subsequent painting. Special care shall be taken to neatly finish the ceiling at junctions with walls, light fixtures, diffusers etc.

6.15.03 Acceptance Criteria

Finished ceiling shall be at the correct plane and present a pleasing and uniform appearance, free from sags, warps, figures or damaged boards. Joints, exposed grids etc. shall be in true lines and symmetrically placed in manner shown on drawings. Cut outs for light fixtures, diffusers etc. shall be of exact dimensions and in exact locations.

6.15.04 Rates

Shall be lump sum rates for complete items called for in the "Schedule of Items". No extra payment will be made for arrangement for lighting fixtures, air conditioning diffusers, access panels, etc. The rate shall include all cutting and wastage from standard size sheets, boards, runners, etc.

6.16.00 Electrical Items

6.16.01 General Electrical Specification

For detailed General Electrical Specification, relevant Electrical section, as applicable, shall be followed.

6.16.02 Drive Motor

For detailed technical specification of motors, relevant Electrical section, as applicable, shall be followed.

6.16.03 Local Push Button Station (LPBS)

For detailed technical specification of Local Push Button Station (LPBS) system relevant Electrical section, as applicable, shall be followed.

6.16.04 Power Distribution Board

For detailed technical specification of Power Distribution Board relevant Electrical section, as applicable, shall be followed.

- 6.16.05 Cables
- For detailed technical specification of Cables relevant Electrical section, as applicable, shall be followed.
- 6.16.06 Cable Trays and Racks
- For detailed technical specification of Cable Trays relevant Electrical section, as applicable, shall be followed.
- 6.16.07 Grounding
- For detailed technical specification of Grounding relevant Electrical section, as applicable, shall be followed.
- 6.16.08 DDC System
- For detailed technical specification of DDC System relevant part of the specification shall be referred to.
- 6.17.00 **Controls & Instrumentation**
- 6.17.01 Control System
- A. All control shall be electrical / electronic type depending upon the requirement & as specified under the specification.
- B. Chilled Water System Controls
- All safety controls against high refrigerant pressure, low refrigerant pressure, low oil pressure, high and low voltage, compressor over-load and protection against freezing of the water chiller, low flow condenser cooling water & chilled water shall be provided.
- All safety controls against antifreeze protection, pump cavitations, motor protection etc. shall be provided.
- Operating thermostat/ temperature sensor sensing outlet water temperature of chiller shall be provided for each compressor. This thermostat/ temperature sensor shall control the liquid line solenoid valve in conjunction with the capacity controller for Screw type. Automatically operated heaters with safety thermostats & automatic unloaded starting device shall be provided for the compressor. Antifreeze thermostat to trip off respective compressor shall be provided for each compressor.
- C. Direct Expansion System Controls
- All devices for automatic refrigerant flow control by thermostatic expansion valve sensed by the superheat in suction line, solenoid valves in the liquid line to operate in conjunction with automatic capacity control of compressor by room thermostat (as applicable) sensing from the inside temperature of the

conditioned space is to be provided. High pressure and low-pressure cut out, low oil pressure cut out (if applicable), high and low voltage protection, compressor motor overload protection shall be provided. Automatically operated crank case heater with safety thermostats shall be provided for reciprocating compressors.

D. Air Handling Unit Controls

The temperature of all conditioned spaces shall be maintained / controlled by a modulating type 3 way mixing valve. The modulating motor will be operated by getting sense from the temperature sensor and associated transmitter placed in the return air path. There shall also be control valves in the chilled water line (for chilled water units) for manual control of chilled water flow into the cooling coil. These control valves shall be flow regulating cum measuring type with precision adjustment arrangement.

E. Annunciations

Audio-visual alarm facility is envisaged of the system. Details of the annunciation system shall be as per mentioned elsewhere and as per requirement.

6.17.02 Miscellaneous Instruments

- A. The pressure indicators and temperature indicators shall have minimum 150 mm size dial. The pressure gauges shall be Bourdon type and complete with isolating/valves. The pressure gauge shall conform to IS: 3624 and temperature gauge as per BS: 1041.
- B. Water flow switch shall be vane actuator type or differential pressure type, with adjustable actuation set point. The level switch shall be ball float operated magnetic type complete with cage. The switch case shall be weather proof conforming to NEMA-4.
- C. Apart from the thermostat, pressure switches, level switches and level indicators specified in this tender document, the local instruments shall also be furnished as a part of the system as shown in drawings enclosed and as per functional requirement.
- D. The range of controls and instruments should be such that the operating ranges are preferably in the mid scale. The accuracy should not be less than + 1% of full scale deflection. The repeatability of readings shall be + 1%. The differential in controls should be such that the equipment is able to operate at desired settings or maintain desired condition.
- E. The scale of pressure indicators for refrigerants units will be in kg/cm². Saturation temperature of the refrigerant in use, at the corresponding

pressure should also be indicated in the scale. The suction and oil gauge shall be compound gauge. The scale of pressure indicator for pumps will be in meter. The temperature indicator's scale will be in °C. The range should be such that even when the equipment is idle and the temperature of the medium is at such variance, the indicator will not be damaged.

- F. All instruments should be such selected and installed that they are easily readable from the floor.

7.00.00 SPECIAL TOOLS

The supplier shall furnish a complete set of all special tools, wrenches etc. with necessary toolboxes as required for erection, operation & maintenance, overhaul or complete replacement of any equipment supplied under this specification. The supplier shall enclose a list of such tools recommended by them.

8.00.00 SPARE PARTS

- 8.01.00 The supplier shall furnish and quote the Mandatory spare parts for the complete Air Conditioning System Equipment as per the list attached in the other part of the specification.

9.00.00 TESTING AND INSPECITON AT MANUFACTURER'S WORKS

- 9.01.00 The manufacturer shall conduct all tests required to ensure that the equipment furnished shall conform to the requirements of this specification and in compliance with the requirement of the applicable codes.
- 9.02.00 Following tests shall be carried out during and after completion of different component parts as applicable and in accordance with the requirements of the applicable codes.
- 9.03.00 Material analysis and testing shall be carried out.
- 9.04.00 Hydraulic test for pressure parts including piping of VAM & its components, pumps, compressors & its components, vessels etc.
- 9.05.00 Dynamic balancing of all the rotating parts is to be done.
- 9.06.00 Performance test of Vapor Absorption Chiller, pump, compressors, condenser, cooling towers and air handling units shall be done as per code procedure.
- 9.07.00 Tests on motors as per Indian Standard IS-325 and IS-4029.
- 9.08.00 Other tests, as necessary and recommended by the manufacturer.

Test certificates and reports shall be made available to the Purchaser / Engineer on the above tests, for approval and before despatch of equipment.

The representatives of Purchaser / Engineer shall be given full access to all tests. The Tenderer shall inform the Purchaser within 21 days prior to important shop tests so that if the Purchaser / Engineer so desires, their representatives can witness the tests.

Cost of conducting all shop tests shall be borne by the supplier.

10.00.00 FIELD TEST

10.01.00 Overall performance of the air conditioning system with peak summer and monsoon outside conditions as well as individual equipment shall be tested after complete installation at site. Duration of such test shall be 72 hours. This test shall be carried out to determine whether the plant meets the performance requirements specified here in and shall include measurements of all parameters under various outside conditions and establishment of correct supply of equipment. All testing and calibrating instruments required for this purpose shall be supplied by the contractor.

10.02.00 Inspection and testing of duct work

All component and duct work supplied shall be subjected to inspection and testing as per relevant codes and standard.

10.03.00 All ductwork shall be carefully examined to determine their performance with the specification with respect of dimensions, materials, marking, leakage, workmanship and other requirement.

10.04.00 The contractor shall give assistance for all site tests of the equipment according to prescribed procedure laid down by the Manufacturer / Engineer.

11.00.00 PERFORMANCE GUARANTEE, TOLERANCE, PENALTY AND RECORDS

11.01.00 The Tenderer shall have to guarantee the performance of individual equipment. The Tenderer shall also guarantee maintenance of the inside conditions as indicated under “design criteria”.

11.02.00 Rectification of Deficient Performance

If the shop / site performance tests indicate the failure of the guaranteed performance of the equipment concerned, the tenderer will be given sometime to make good the deficiency at his own cost by incorporating the necessary modification, alteration and replacement.

11.03.00 Test Records

The certificates and records of the above mentioned tests should be submitted to the Purchaser for approval. The manufacturer shall maintain records of all tests required in the specification for at least 5 years. A list of records shall be submitted to the Purchaser on completion of the job. The Purchaser shall be able to obtain certified copies of such records at any time.

12.00.00 SPECIAL CLEANING, PROTECTION & PAINTING

12.01.00 Internal surface of all parts shall be cleaned to remove loose scale and dirt. The external surface of the motor and end shield shall be sand blasted to remove all rust, scale etc. All sharp edge shall also be removed. Welded rods, studs and other foreign objects shall be removed prior to final assembly. Excess oil and grease shall be removed by wiping.

12.02.00 All parts shall be painted with two (2) coats of rust preventing paint. One (1) coat of final paint shall be applied over and above the rust proof paint before despatch of material.

12.03.00 All equipment shall be boxed / crated or otherwise protected for shipment. Dry nitrogen desiccant and other protection shall be provided as may be necessary.

13.00.00 DOCUMENTS, DATA TO BE FURNISHED WITH TENDER PROPOSAL

13.01.00 Beside submitting the enclosed Proposal Exhibit Sheets duly filled in, the proposal shall also include the following drawings, curves and information wherever applicable.

Preliminary cooling and heating load calculation is to be furnished.

13.02.00 Preliminary equipment layout drawings of the air conditioning plant room, AHU room and preliminary ducting layout drawing are to be furnished.

13.03.00 Manufacturer's catalogue and literatures incorporating outline and sectional drawings and ducting data for the following equipment:

Screw Compressor
Water-cooled Condensers
Chiller
Air Handling Unit (Fan, cooling coil & filter)
Drive motors for various equipment as applicable
Condenser cooling & chilled water pumps
Cooling tower
Non chemical water treatment

Water-cooled precision air conditioner
Air-cooled precision air conditioner
Air-cooled Non Duct able Split Air-conditioner
Fan Coil Unit
Motor
Direct Digital Controller

- 13.04.00 Manufacturer's selection chart for the following equipment:
- Water-cooled Screw Chiller
AHU
Water-cooled precision air conditioner
Air-cooled precision air conditioner
Air-cooled Non Duct-able Split Unit
Pump
Cooling Tower
Fan
Fan Coil Unit
- 13.05.00 Manufacturer's catalogues and literatures on air conditioning system, instruments and controls.
- 13.06.00 Sectional drawings for air diffusers and grilles, as applicable.
- 13.07.00 Manufacturer's data sheets for filters and refrigerant.
- 13.08.00 Drive list
- 13.09.00 A detailed experience list about supply for system of similar type for similar application mentioning in each case the salient technical parameters, date of commissioning and name of customers.
- 13.10.00 A comprehensive write-up and / or brochure on details of manufacturing and testing facilities in the shop of the manufacturer.
- 13.11.00 Any other relevant data and particulars.
- 14.00.00 **POST AWARD DOCUMENTS, DATA TO BE FURNISHED**
- 14.01.00 Description of the system offered.
- 14.02.00 Sizing calculations for all equipment and accessories which include cooling and heating load calculations, system pressure drop calculations, duct sizing calculations, pump capacity calculation, calculations for AHUs/FCUs and fresh air fans.

-
- 14.03.00 Particulars of drawings, data, instruction manual and Drive List.
- 14.03.01 Equipment layout drawing for
- Packaged Screw Chiller
 - Air conditioning plant room
 - Air handling unit room
 - Cooling Tower
 - Pump
 - Expansion Tank
 - Make-up Water Tank
 - Water-cooled precision air conditioner
 - Air-cooled precision air conditioner
 - Air-cooled Non Duct-able Split Unit
 - Fan Coil Unit
- 14.03.02 Schematic flow and instrumentation diagram of the complete system indicating the limits of supply and erection.
- 14.03.03 Ducting layout drawing showing the details of duct sizes, duct joints, duct insulation, duct supports, diffusers, grilles, dampers etc.
- 14.03.04 Layout drawings showing the route of Steam piping, refrigerant piping and cooling water piping with details of insulation hangers, supports etc.
- 14.03.05 Outline drawings incorporating all principal dimensions, civil foundation drawings and weight etc. and also sectional drawings incorporating data of material of construction wherever applicable for following equipments:
- Water-cooled Screw Chilling Unit
 - Air handling unit
 - Water-cooled precision air conditioner
 - Air-cooled precision air conditioner
 - Air-cooled Non Duct-able Split Air conditioner
 - Drive motor for above equipment as applicable
 - Cooling tower
 - Expansion tank
 - Make-up Water Tank
 - Fan coil unit
- 14.03.06 Drawings and data sheets of each of Equipment and Instruments.
- 14.03.07 Drawings and data sheets for air filters, refrigerant / filter drier.
- 14.03.08 Write up on system interlock and / or interlock block diagram.
- 14.03.09 Electrical schematic and wiring diagram for control panel and the system as applicable with back-up write-up.
- 14.03.10 Control panel / Switchgear outline drawings, bill of instruments and drawings showing construction of control panel / switchgear.

- 14.03.11 Reflected False Ceiling Plan indicating detail of supports/ hangers, grids, fixing detail of Grilles and diffusers and lighting fixtures etc.
- 14.03.12 Fixing/ application detail of under deck insulation indicating type and thickness and weight of insulation.
- 14.03.13 Other drawings and data.
- 14.03.14 Material test certificates.
- 14.03.15 Shop test reports and certificates.
- 14.03.16 Operation, maintenance and overhauling manuals shall be provided as per following specification.

OPERATION AND MAINTENANCE MANUAL

The successful tenderer, shall prepare, during the project execution stage a manual giving details of operation and maintenance instructions. The manual will be comprehensive manual and will be provided by the Engineer. The manual shall cover but not limited to the following aspects:

- i) Equipment description with design particulars.
- ii) Installation and Maintenance Instruction including preventive maintenance requirements.
- iii) Instruction for pre-commissioning check-up, operation.
- iv) Trouble shooting.
- v) Spare Parts list.
- vi) Lubricant and lubrication schedule
- vii) Control logic and inter connection and calibration of controls.
- viii) System description
- ix) Necessary drawings, illustration
- x) List of manufacturer's name and catalogues
- xi) Safety instructions.

The manual shall be securely bound in hard back durable folder with proper indexing and separators.

15.00.00 List of Drawings

Sl. No.	Drawing No.	Description
01.	13A06-003-DWG-VA-001	Schematic Diagram of Package Screw Chiller Unit
02.	13A06-003-DWG-VA-002	Schematic Diagram of Water Cooled Precision Air Conditioner
03.	13A06-003-DWG-VA-003	Schematic Diagram for Common Chilled Water Type Air

		Conditioning System of Power House and Service Building
04.	13A06-003-DWG-VA-004	Schematic Diagram of Air Cooled Precision Air Conditioner
05.	13A06-003-DWG-VA-003	Schematic Diagram of Air Cooled Split AC Unit

Annexure III
to
Technical Specification for Air Conditioning System of
Switchyard Control building (Sec-II, Sub Section-C1)

VOLUME: V-A

SECTION-VII

**TECHNICAL SPECIFICATION
FOR
415V PMCC/MCC, 415V ACDB AND 220V DCDB**