

RENOVATION & RETROFITTING OF ESP PACKAGE FOR RAMAGUNDAM STPS, STAGE-I (3X200 MW)

**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS
DOC. NO. PE-TS-448-558-E002**

REVISION 0



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA**



TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

CONTENTS SHEET

RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)

REV. 0

DATE: 24.09.2019

SHEET 1 OF 1

CONTENTS

<u>S. NO.</u>	<u>DESCRIPTION</u>	<u>NO. OF SHEETS</u>
01	SECTION - I	
	COMPLIANCE CERTIFICATE	1
	SPECIFIC TECHNICAL REQUIREMENT	1
	ATTACHMENT I - DOCUMENTS REQUIRED AFTER AWARD OF LOI	1
	DATA SHEET-A	8
	SUB-VENDOR LIST	5
	DATA SHEET-C	9
02	SECTION - II	
	GENERAL TECHNICAL REQUIRMENTS	22
	QUALITY PLAN	4
	TOTAL NUMBER OF SHEETS INCLUDING COVER/SEPARATOR SHEET:	54



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

REV. 0

DATE: 24.09.2019

SHEET 1 OF 13

SECTION – I

SPECIFIC TECHNICAL REQUIREMENTS



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 2 OF 13

COMPLIANCE CERTIFICATE

The bidder shall confirm compliance to the following by signing/ stamping this compliance certificate and furnishing same with the offer.

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusion/ deviation with regard to same.
2. There is no deviation with respect to specification other than those furnished in the 'schedule of deviations'.
3. Only those technical submittals which are specifically asked for in NIT to be submitted at tender stage shall be considered as part of offer. Any other submission, even if made, shall not be considered as part of offer.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the description/ quantities from those given in BOQ-Cum-Price schedule of the specification shall not be considered (i.e. technical description & quantities as per specification shall prevail).



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)

REV. 0

DATE: 24.09.2019

SHEET 3 OF 13

1.0 SCOPE OF SUPPLY

- 1.1 Design, manufacture, assembly, inspection & testing at vendor's/ sub-vendor's works, proper packing and delivery to site of LIGHTING DB/ WELDING DB & LIGHTING PANELS as mentioned in different sections of this specification, complete with all accessories for efficient and trouble-free operation.
- 1.2 Standard technical requirements of LIGHTING DBs/ WELDING DBs & LIGHTING PANELS are indicated in Section-II. Project specific requirements/changes are listed in Section-I.
- 1.3 The stipulations of Section-I, followed by those of Data Sheet-A shall prevail and govern in case of conflict between the corresponding requirements of Section-I and Section-II.
- 1.4 Review of sub-vendor's documents by the vendor shall not relieve the vendor from the responsibility of design & supply.
- 1.5 The documents shall be in English language and MKS system of units.

2.0 BILL OF QUANTITIES:

- 2.1 Quantity requirements shall be as per BOQ-cum-price schedule as part of NIT.

3.0 SPECIFIC TECHNICAL REQUIREMENTS

S.No	Reference Clause No. of Section- II	Specific Requirement/ Change
1	3.2.1	• With ref. to the requirement furnished in clause 3.2.1 of Section-II, Bidder to consider the following: - • All LP shall be provided with provision of manual override. • Bus bars of DBs shall be sized to carry continuously the total running load of the system plus a 20% margin.
2	ADDITIONAL REQUIREMENT (FOR LDB & LP)	Interlock required to be provided between two incomer and Bus coupler of LDB/WDBs.
3	ADDITIONAL REQUIREMENT (FOR LDB & LP)	All LDB & LP shall be provided with two points for earthing.
4	ADDITIONAL REQUIREMENT (FOR LDB & LP)	Bus bar shall be electrolytic grade hard drawn aluminium, color coded for easy identification & designed for a maximum temperature of 90 degree C.



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 4 OF 13

4.0 DOCUMENTATION

4.1 Documents required after award of contract shall be as per Attachment-I (to be submitted by successful bidder).

ATTACHMENT – I

DOCUMENTS REQUIRED AFTER AWARD OF LOI

Sr.no	Drawing No	Title	Primary/Secondary	
1	PE-V0-448-558-E001	DATA SHEET OF LIGHTING DISTRIBUTION BOARDS	Primary	R-0 within 14 days from PO & subsequent revisions within 10 days of comments received from BHEL. BHEL shall furnish comments / approval on each submission within 18 days from receipt.
2	PE-V0-448-558-E002	GA DRAWING OF LIGHTING DISTRIBUTION BOARDS	Primary	
3	PE-V0-448-558-E003	SCHEME DRAWING OF LIGHTING DISTRIBUTION BOARDS	Primary	
4	PE-V0-448-558-E004	TYPE TEST REPORTS FOR LIGHTING DISTRIBUTION BOARDS	Secondary	
5	PE-V0-448-558-E904	QUALITY PLAN OF LIGHTING DISTRIBUTION BOARDS	Primary	
6	PE-V0-448-558-E005	DATA SHEET OF LIGHTING PANEL	Primary	
7	PE-V0-448-558-E006	GA DRAWING OF LIGHTING PANEL	Primary	
8	PE-V0-448-558-E007	SCHEME DRAWING OF LIGHTING PANEL	Primary	
9	PE-V0-448-558-E008	TYPE TEST REPORTS FOR LIGHTING PANELS	Secondary	
10	PE-V0-448-558-E905	QUALITY PLAN OF LIGHTING PANEL	Primary	
11	PE-V0-448-558-E009	GA DRAWING OF LIGHTING TRANSFORMER	Primary	
12	PE-V0-448-558-E906	QUALITY PLAN OF LIGHTING TRANSFORMER	Primary	
13	PE-V0-448-558-E010	TYPE TEST REPORTS FOR LIGHTING TRANSFORMER	Secondary	

Note:

1. The above list of drawings and documents is indicative.



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

REV. 0

DATE: 24.09.2019

SHEET 5 OF 13

DATA SHEET –A

S. No.	Description	Unit	Value
1.0	SYSTEM DESIGN DATA		
1.1	Design ambient	⁰ C	50
1.2	AC Supply		
a)	Rated voltage	V	415
b)	Rated frequency	Hz	50
c)	Voltage variation (permissible)	%	+10% to -10%
d)	Frequency variation (permissible)	%	+3% to -5%
e)	Combined voltage & frequency variation (sum of absolutes permissible)	%	10%
f)	System fault level & duration	kA, sec.	20kA for 1 sec.
2.0	APPLICABLE STANDARDS IS 60947 Low voltage switchgear and controlgear IS 11171 Dry type transformers IS 13703 Low voltage fuses for voltages not exceeding 1000V AC or 1500 V IS 10118 Code of practice for selection, installation and maintenance of switchgear and controlgear IS 60898 Electrical Accessories - circuit breakers for over protection for household and similar installations IS 1901 Visual indicator lamps IS 60079 Explosive atmospheres IS 5572 Classification of hazardous areas (other than mines) having flammable gases and vapours for electrical installation IS:2551 Danger notice plates		



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

RENOVATION & RETROFITTING OF ESP PACKAGE FOR RAMAGUNDAM STPS, STAGE-I (3X200 MW)

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 6 OF 13

3.0	LIGHTING/ WELDING DISTRIBUTION BOARDS		
3.1	Operational Front		Single Front
3.2	Type of execution of modules (functional unit)		☒ Fixed ☐ Draw out
3.3	Type of sheet steel		CRCA
3.4	Sheet metal thickness (minimum)		
a)	Non-load bearing covers	mm	1.6 mm
b)	Non-load bearing partitions	mm	1.6 mm
c)	Load bearing members	mm	2.0 mm
d)	Frames	mm	1.6 mm
e)	Door	mm	1.6 mm
f)	Withdrawable unit (if applicable)	mm	2.0 mm
3.5	Cable alley width (minimum)	mm	250mm (Cable terminations located in cable alley shall be designed to meet the Form IVb Type 7 (as per IEC 60439) for safety purpose.)
3.6	Bus bar material		☒ Aluminium grade E 91E (UL224 compliant)
3.7	Earth bus bar material		☒ GI Strip ☐ Aluminium ☐ Copper
3.8	Degree of Protection		
a)	Main Panel		IP-54
b)	Transformer cubicle		IP-42
3.9	Gland plate thickness	mm	3.0
3.10	AC LDB/ WDB		
a)	No. of Incomers		☐ One ☒ Two
b)	Bus coupler required		☒ Yes ☐ No
c)	Incomer and Bus coupler rating	A	As per transformer rating
d)	Type of Incomer and Bus coupler		☐ SFU ☒ MCCB



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 7 OF 13

e)	Type of Outgoing Feeders		☐ SFU ☒ MCCB
f)	Outgoing feeders rating	A	63
g)	Cable entry		☒ Bottom ☐ Top
3.11	Lighting Transformer		
a)	Rating	kVA	100 / 50
b)	Type of cooling		Air natural
c)	Voltage ratio	V	415/415
d)	Rated frequency	Hz	50
e)	No. of phases		3
f)	Vector group		Dyn11
g)	Off circuit taps		
	Tap range, steps	%	+5% to -5% in steps of 2.5%
	Voltage of each tap	V	As per manufacturer's data
h)	Impedance at rated current, frequency at 75 °C	%	As per IS
i)	Rated current		
	Primary	A	As per manufacturer's data
	Secondary	A	As per manufacturer's data
j)	Transformer type		☒ Cast resin / ☒ Encapsulated / ☐ Non-Encapsulated
k)	Transformer winding insulation		Class-F or better
l)	Transformer winding insulation temperature rise limit		AS PER Applicable Standard
n)	Type of ventilation arrangement provided for transformer enclosure		As per manufacturer's data
o)	Winding conductor material		Copper
p)	Iron loss at 50 Hz and 100% rated voltage	kW	As per manufacturer's data



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

REV. 0

DATE: 24.09.2019

SHEET 8 OF 13

q)	Copper loss at rated load at 75 °C	kW	As per manufacturer's data
r)	Regulation at full load at 75 °C and 0.8 p.f. lagging		As per manufacturer's data
s)	Weight	kg	As per manufacturer's data
4.0	LIGHTING PANELS		
4.1	Application		☐ Indoor ☐ Outdoor ☒ Both
4.2	Type of sheet steel		CRCA
4.3	Sheet metal thickness (minimum)		2.0
4.4	Degree of Protection		
a)	Indoor panel		IP-54
b)	Outdoor panel		IP-55, Weatherproof
c)	Canopy in outdoor panel		☒ Yes ☐ No
4.5	Bus bar material		☒ Aluminium ☐ Copper
4.6	Earth bus bar required		☒ Yes ☐ No
4.7	Earth bus bar material		☒ GI Strip ☐ Aluminium ☐ Copper
4.8	Gland Plate	mm	3.0
4.9	Earthing studs required		☒ Yes ☐ No
4.10	Hinged door with locking facility		☒ Yes ☐ No
4.11	AC Lighting Panel		
a)	Incomer rating	A	63A for LP
b)	Type of Incomer		☐ SFU ☒ MCCB
c)	Earth Leakage Circuit Breaker (ELCB) in incomer required		☒ Yes ☐ No
d)	Type of Outgoing Feeders (non-flameproof panel)		☒ SPN MCB ☐ TPN MCB
e)	Type of Outgoing Feeders (Flameproof panel)		☒ DP MCB ☐ TPN MCB
f)	Timer required for indoor panel		☒ Yes ☐ No



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

REV. 0

DATE: 24.09.2019

SHEET 9 OF 13

g)	Timer required for outdoor panel		[V] Yes [] No
h)	Outgoing feeders rating	A	20
5.0	COMPONENTS OF LIGHTING SYSTEM EQUIPMENT		
5.1	Moulded Case Circuit Breaker (MCCB)		N.A.
a)	Rated voltage	V	415V
b)	Number of poles		Refer Sl. No. 3 & 4
c)	Rated short circuit duty	kA	45KA
d)	Rated breaking capacity (rms)	kA	45KA
e)	Rated making current (peak)	kA	105KA
f)	Release with short circuit		[V] Yes [] No
g)	Release with overload		[V] Yes [] No
h)	Release with under voltage		[V] Yes [] No
i)	Auxiliary contacts		
	Numbers	NO+NC	1 NO and 1 NC
5.2	Switch-Fuse Unit		
a)	Utilisation category for main contacts		AC23
b)	Breaking Capacity: With conditions: a) Voltage b) Power Factor		3 times rated current 110% of rated voltage 0.3
5.3	Miniature Circuit Breaker		
a)	SPN MCB rating (min)	A	Refer Sl. No. 3 & 4
b)	Short time rating	kA	10
c)	Magnetic short circuit protection required		[V] Yes [] No
d)	Thermal overload protection required		[V] Yes [] No
5.4	Current Transformer		
a)	Type		Cast resin



TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS

RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 10 OF 13

b)	Secondary current rating	A	[V] 1 [] 5
c)	Burden	VA	10
d)	Accuracy class		1.0
e)	Instrument Safety Factor		<5
5.5	Voltage Transformer		
a)	Type		Cast resin
b)	Secondary terminal voltage (phase-phase)	V	110 V
c)	Burden	VA	10
d)	Accuracy class		1.0
e)	Winding configuration		Star/ Star
f)	System grounding		[V] Effective [] Non-effective
5.6	Indicating Meters		
5.6.1	Ammeter		
a)	Type		Analog
b)	Shape		Square
c)	Size		96mm x 96mm
d)	Accuracy		1.0
e)	Current coil rating	A	1
f)	Angle of deflection	deg	90
5.6.2	Voltmeter		
a)	Type		Analog
b)	Shape		Square
c)	Size		96mm x 96mm
d)	Accuracy		1.0
e)	AC voltage coil rating	V	0-500
f)	DC voltage coil rating	V	0-250
g)	Angle of deflection	deg	90



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 11 OF 13

5.7	Power Contactors		
a)	Coil voltage (nominal)		
	AC contactors	V	240
	DC contactors	V	220
b)	Current rating of contacts		
	Power	A	As per manufacturer data
	Control	A	As per manufacturer data
5.8	Under voltage relay		
a)	Type		☐ Electromagnetic ☐ Static
b)	Coil voltage rating	V	110
c)	Means for in-built testing provided		As per manufacturer data
5.9	Timer		
5.9.1	Time switch		
a)	Type		Digital synchronous
b)	Range	hr	0-24
c)	Coil voltage rating	V	240
5.10	Selector switch		
a)	Type of selector switch		☐ Stay put ☐ Wing knob
b)	Lockable		☐ Yes ☐ No
5.11	Push Button		
a)	Voltage grade	V	500
b)	Potential free contacts		2NO+2NC
5.12	Indicating Lamps		
a)	Lens Colour		
	ON condition		Red
	OFF condition		Green



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 12 OF 13

b)	Circuit voltage	V	240V
5.13	Cable Glands		By vendor for all incoming and outgoing cables
a)	Type		[V] Double compression [] Single compression
b)	Material		Heavy duty brass machine finished
c)	Nickel Plating provided		[V] Yes [] No
5.14	Cable Lugs		By vendor for all incoming and outgoing cables
a)	Type		Crimping type/ ring type
b)	Material		Tinned copper
6.0	PAINTING		
6.1	Paint shade		Powder coated
a)	LDBs (powder coated)		Finishing paint· shade for complete panels excluding end covers shall be RAL9002 & RAL5012 for extreme end covers of all boards.
b)	LPs (powder coated)		Finishing paint· shade for complete panels excluding end covers shall be RAL9002 & RAL5012 for extreme end covers of all boards.
c)	Interior colour		Glossy White as per IS-5
6.2	Paint Finish		
a)	Interior		[] Matt [V] Semi-glossy
b)	Exterior		[V] Semi-glossy [] Full-glossy
6.3	Paint Thickness	Microns	50



TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS

RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS, STAGE-I
(3X200 MW)

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - I

REV. 0

DATE: 24.09.2019

SHEET 13 OF 13

ANNEXURE-1

SUB-VENDOR LIST

Package Name	Pack Code	ITEM	ITEM CODE	VENDOR	ADDRESS
STATION LIGHTING SYSTEM	558-11000-A	AC CONTACTORS	ES1	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006
STATION LIGHTING SYSTEM	558-11000-A	AC MCCB	ES3	C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
STATION LIGHTING SYSTEM	558-11000-A	AMMETER	ES74	CROMPTON GREAVES	RAIL TRANSPORTATION SYSTEMS,VANDANA BUILDING, 11, TOLSTOY MARG, TOLSTOY MARG, NEW DELHI, DL 110001
				AUTOMATIC ELECTRIC LTD.	96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401
STATION LIGHTING SYSTEM	558-11000-A	AUXILIARY RELAYS	ES7	RISHABH INST.PVT LTD	RISHABH INSTRUMENTS PVT. LTD.F-31, MIDC, SATPURNASHIK - 422007,MAHARASHTRA INDIA
				ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003
				ALSTOM LTD	A-7, SEC-65, NOIDA
				JYOTI LTD.	JYOTI LIMITED, E&CS DIVISION,3/15, BIDC, GORWA,VADODARA - 390 016, E-MAIL ID: ECS@JYOTI.COM
				OEN INDIA LTD	29/1479, VYTILLA, COCHIN - 682 019KERALA, INDIA
STATION LIGHTING SYSTEM	558-11000-A	CABLE GLANDS	ES11	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				ALLIED TRADERS & EXPORTERS	C-124 A, SECTOR-2,NOIDA -201 301, UTTAR PRADESH, INDIA
				ARUP ENGG & FOUNDARY WORKS	391/119,PRINCE ANWAR SHAH ROAD, CALCUTTA-700068
				BALIGA LIGHTING EQPT PVT LTD	63A,CP RAMASWAMY ROAD, ALWARPET,P.B.No 6910, CHENNAI-600018
				COMMET BRASS PRODUCTS	NUTAN CHEMICAL COMPOUND, WALBHAT ROAD, GOREGAON, MUMBAI-400063
				DOWELLS	M/S. DOWELLS ELECTRICALS47/47A, SATGURU INDUSTRIAL ESTATE.OFF AAREY ROAD, GOREGOAN (EAST),MUMBAI 400 063.
				ELECTROMAC INDUSTRIES	27/28AF NEW EMPIRE IND.ESTT., R.KRISHNA MANDIR RD.JB NGR ,ANDHERI(E),MUMBAI-400059
STATION LIGHTING SYSTEM	558-11000-A	CABLE LUGS	ES12	INCAB	HARE STREET,KOLKATA,WEST BENGAL-700001
				DOWELLS	M/S. DOWELLS ELECTRICALS47/47A, SATGURU INDUSTRIAL ESTATE.OFF AAREY ROAD, GOREGOAN (EAST),MUMBAI 400 063.
STATION LIGHTING SYSTEM	558-11000-A	CONTROL SWITCHES/ SELECTOR SWITCH	ES21	UNIVERSAL MACHINES LTD.	4,B.B.D.BAG (EAST) 90,STEPHEN HOUSE,5TH FLR CALCUTTA-700001
				KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				ALSTOM LTD	A-7, SEC-65, NOIDA
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
STATION LIGHTING SYSTEM	558-11000-A	D.C. MCCB	ES13	Shrenik & Co.	39A/3, PANCHRATNA INDUSTRIAL ESTATE, SARKHEJ-BAVLA ROAD, CHANGODAR, AHMEDABAD – 382 213
				RECOM PVT. LTD.	M/S RECOM PVT. LTD.,16A , 2ND FLOOR A, WING RAJ INDUSTRIAL COMPLEX, MILITARY ROAD , MAROL ANDHERI (EAST),MUMBAI ,MAHARASHTRA STATE : 400059
				CROMPTON GREAVES	RAIL TRANSPORTATION SYSTEMS,VANDANA BUILDING, 11, TOLSTOY MARG, TOLSTOY MARG, NEW DELHI, DL 110001
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
STATION LIGHTING SYSTEM	558-11000-A	DC CONTACTORS	ES20	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				BHEL (BHOPAL)	HEAVY ELECTRICAL PLANT
				ELECTROMAC INDUSTRIES	27/28AF NEW EMPIRE IND.ESTT., R.KRISHNA MANDIR RD.JB NGR ,ANDHERI(E),MUMBAI-400059
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
STATION LIGHTING SYSTEM	558-11000-A			SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032

Package Name	Pack Code	ITEM	ITEM CODE	VENDOR	ADDRESS
STATION LIGHTING SYSTEM	558-11000-A	DC SWITCH	ES25	GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
STATION LIGHTING SYSTEM	558-11000-A	EARTH LEAKAGE CB	ES14	L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
				ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003
				INDO ASIAN	B-24, PHASE - II, NOIDA - 201305, U.P.
				MDS SWITCHGEAR LTD	314-317 SHAH NAHAR ESTATE
				S&S POWER SWITCHGEAR LTD,	NEW NO. 67, OLD NO. 19, DR. RANGA ROAD, MYLAPORE, CHENNAI - 600004
STATION LIGHTING SYSTEM	558-11000-A	FUSE BASE	ES28	INDO ASIAN	B-24, PHASE - II, NOIDA - 201305, U.P.
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003
				SPACEAGE SWITCHGEARS LTD.	68 & 13-A INDUSTRIAL DEVELOPMENT COLONY, MEHRAULI ROAD GURGAON, HARYANA-122001
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				ALSTOM LTD	A-7, SEC-65, NOIDA
STATION LIGHTING SYSTEM	558-11000-A	GI WIRE & FLAT	ES31	ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI
				Brahampuri Steels Limited	172 (F) Industrial Area, Jhotwara, Jaipur-302013
				INDIA ELECTRICALS SYNDICATE	Mr. Suresh Kumar Agarwal 55, Ezra Street, Kolkata-West Bengal-India Phone- 033-22354047 Pincode : 700001 Email : cabletray@vsnl.com
				INDMARK FORMTECH PVT. LTD.	Mr. Narendra R. Meher J Block, Plot No.-375, MIDC BHOSARI PUNE- MAHARASHTRA-INDIA Phone- 020-27130546 Pincode : 411026 Email : indmarkformtech@vsnl.net
				PREMIER POWER PRODUCTS (CAL) PVT. LTD.	Chatterjee International Centre, 33A, Jawaharlal Nehru Road, 6th Floor, Suit No. - 11A, Kolkata,-West Bengal-India Phone- 9331008739 Pincode : 700071 Email : hemantdaga@dagaventures.com
				Patny Systems (P) Ltd.	PATNY PLAZA 160, SARDAR PATEL ROAD SEUNDRABAD SECUNDRABAD-TELANGANA-INDIA Phone- 040-27902451 Pincode : 500003 Email : mr.mkt@patnysystems.com
				PASSIVE INFRA PROJECTS PVT. LTD.	MR. VARUN AGRAWAL 182, VAISHALI, PITAMPURA Delhi-DELHI-INDIA Phone- 9871183059 Pincode : 110088 Email : ATANU.SAHA@PASSIVEINFRA.COM
				RUKMANI ELECTRICAL & COMPONENTS PVT LTD	11A, MAHARISHI DEBENDRA ROAD 1ST FL, ROOM NO.4 KOLKATA-WEST BENGAL-INDIA Phone- Pincode : 700007 Email : maruthikabra@gmail.com
				RATAN PROJECTS & ENGINEERING CO. PVT.LTD.	MR. G.D. SINGHEE/MR. MAHESH SINGHEE 26, P.K. TAGORE STREET, MAIN BUILDING KOLKATA-WEST BENGAL-INDIA Phone- 9830177331 Pincode : 700006 Email : mahesh@ratans.com
				RABI ENGINEERING WORKS PVT. LTD.	MR. TAPAN KUMAR SEN/MR. SIDDHARTHA 327, R.N. GUHA ROAD, DUM DUM, KOLKATA-WEST BENGAL-INDIA Phone- 9748753002 Pincode : 700028 Email : rabiengineering@gmail.com
				RAJASTHAN METAL SMELTING CO.	Mr. R. K. Tibrewala D-80, Road No. 7, V.K.I.A., Jaipur-Rajasthan-India Phone- 0141-2332269 Pincode : 302013 Email : info@rmscoindia.com
				SARAL INDUSTRIES	Mr. Y.K. Gupta L-1, L-2, Industrial Area-1 Sultanpur Road Rae Bareilly-Uttar Pradesh-India Phone- 0535-2702474 Pincode : 229010 Email : saralindustries@gmail.com
				PARCO Engineers Pvt. Ltd.	401, skyline Epitom Building, Near to Jolly Gym Khana, Kirol Road, Vidhyavihar, MH 400086 India
				UNITECH FABRICATORS and ENGINEERS PVT LTD	INDRAPRASHTHA APARTMENT 24, M.B.RAOD, BIRATI KALABAGAN KOLKATA KOLKATA-WEST BENGAL-INDIA Phone- Pincode : 700051 Email : ufepl@vsnl.net; ufepl@rediffmail.com

Package Name	Pack Code	ITEM	ITEM CODE	VENDOR	ADDRESS
STATION LIGHTING SYSTEM	558-11000-A	HRC FUSES	ES29	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				ABB	14, MATHURA ROAD, FARIDABAD, HARYANA-121003
				SPACEAGE SWITCHGEARS LTD.	68 & 13-A INDUSTRIAL DEVELOPMENT COLONY, MEHRAULI ROAD GURGAON, HARYANA-122001
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				ALSTOM LTD	A-7, SEC-65, NOIDA
				ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI
STATION LIGHTING SYSTEM	558-11000-A	HUME PIPE	ES85	REPUTED MAKE	
STATION LIGHTING SYSTEM	558-11000-A	IND.POWER & WLDG SOCKETS	ES33	CROMPTON GREAVES	3RD FLOOR, EXPRESS BUILDING,9-10, BAHADUR SHAH ZAFAR MARG, NEAR ITO CROSSING,NEW DELHI-110002, INDIA
				CYCLO ELECTRIC DEVICE & SERV.CO.	: A-3, NEAR ANTHEM BIOSCIENCE, KSSIDC INDUSTRIAL AREA, BOMMASANDRA, BOMMASANDRA INDUSTRIAL AREA, BANGALORE, KARNATAKA 560099
				BCH	20/4, MATHURA ROAD, FARIDABAD - 121006, HARYANA, INDIA
				BEST & CROMPTON	Best & Crompton Engineering Ltd28C, Ambattur Industrial Estate (North)Ambattur, Chennai - 600 098
				AJMER INDUSTRIES & ENGG. WORKS	AJMER IND. AND ENGG. WORKS. AJMER HOUSE, A-61 / KHAIRANE MIDC. , TTC INDL. AREA, NAVI MUMBAI – 400705.
STATION LIGHTING SYSTEM	558-11000-A	INDICATING LAMPS	ES35	BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006
				C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
				ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI
				VAISHNO(HOTLINE SWGR.& CONTROL)	G-19, SECTOR - 11, NOIDA - 201301, UTTAR PRADESH, INDIA
				GE-POWER	KAMAK TOWER, 3RD FLOOR, PLOT NO. 12-A, TVK INDUSTRIAL ESTATE, EKKADUTHANGAL, GUINDY, CHENNAI-600032
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
STATION LIGHTING SYSTEM	558-11000-A	LIGHTING SWITCH , SOCKET & S/F UNIT	ES45	SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				ELEXPRO ELECTRICALS PVT/ LTD.	C 1/27 & 37 GIDC KABILPORE NAVSARI-396424
				ANCHOR	STEEL HOUSE, B WING, PLOT NO. 24, MAHAL INDUSTRIAL ESTATE, MAHAKALI CAVES ROAD, NEAR PAPER BOX, ANDHERI (E), MUMBAI, MAHARASHTRA- 400093
				KAYCEE	KAYCEE INDUSTRIES LTD., C/O-CMS COMPUTERS LTD., 35A, REAR BLDG., KILOKARI, NEW DELHI-110014
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
STATION LIGHTING SYSTEM	558-11000-A	LIGHTING TRANSFORMER	ES46	INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.
				AUTOMATIC ELECTRIC LTD.	ADDRESS : 96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401
				INDCOIL	PLOT NO. A- 150/ 151, 23RD U ROAD, WAGLE ESTATE, THANE WEST, CST RD, FRIENDS COLONY, HALLOW PUL, KURLA WEST, MUMBAI, MAHARASHTRA 400070
				POWER PACK ENTERPRISES	POWER PACK ENTERPRISES MR. NEHAL SHAH / MR. SHARAD SHAH (PARTNER) NO. 3, JAYSHREE SADAN, 1ST FLOOR, OLD NAGARDAS ROAD, ANDHERI EAST MUMBAI - 400069, MAHARASHTRA, INDIA
				VIJAY ELECTRICALS LTD.	6-3-648/1&2, OFF RAJ BHAVAN ROAD, SOMAJIGUDA, HYDERABAD - 500 082. ANDHRA PRADESH, INDIA.
				GILBERT & MAXWELL	WORKS PLOT G-28 , M.I.D.C., AMBAD NASHIK - 422010, MAHARASHTRA, INDIA
				KAPPA ELECTRICALS	KAPPA ELECTRICALS, KAPPA CONSOLIDATED PVT. LTD., SOUTHERN ELECTRIKS 14, CART TRACK ROAD, MADUVANKARAI, CHENNAI - 600 042, INDIA.
				Ames Impex Electricals Pvt. Ltd	C-1B/1207, PHASE IV, GIDC NARODA, AHMEDABAD, GUJARAT 382330

Package Name	Pack Code	ITEM	ITEM CODE	VENDOR	ADDRESS
STATION LIGHTING SYSTEM	558-11000-A	LT- CURRENT TRANSFORMER	ES23	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				AUTOMATIC ELECTRIC LTD.	96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401
				INDCOIL	PLOT NO. A- 150/ 151, 23RD U ROAD, WAGLE ESTATE, THANE WEST, CST RD, FRIENDS COLONY, HALLOW PUL, KURLA WEST, MUMBAI, MAHARASHTRA 400070
				KAPPA ELECTRICALS	KAPPA ELECTRICALS, KAPPA CONSOLIDATED PVT. LTD., SOUTHERN ELECTRIKS 14, CART TRACK ROAD, MADUVANKARAI, CHENNAI - 600 042, INDIA.
				PRAGATI ELECTRICALS	280/3,II POKHRAN RD
				PRECISE ELECTRICALS	47A-49A,CHAKALA ROAD ANDHERI(E),MUMBAI-99 MUMBAI, MAHARASHTRA, INDIA PIN-400 099
				SILKAANS ELECT.MFG.CO.PVT.LTD	PLOT NO: R-247, T.T.C. INDUSTRIAL AREA, M.I.D.C , RABALE, NAVI MUMBAI- 400 701INDIA
				PRAYOG ELECTRICALS PVT. LTD.	GROUND FLOOR, THAKORE INDUSTRIAL COMPUND, STATION ROAD, VIDYA VIHAR (W), NATHANI ROAD , OPP. AMIBIKA TEMPLE,MUMBAI Mumbai - 400086, Maharashtra, India
				C&S ELECTRIC LTD.	222, OKHLA IND. ESTATE, PH-III, NEW DELHI-110020
STATION LIGHTING SYSTEM	558-11000-A	LT- POTENTIAL TRANSFORMER	ES24	SIEMENS	RC-IN I S NR DEL AREA, JIL BUILDING, TOWER-B, PLOT NO. 78, SECTOR 18, GURGAON-122015, INDIA
				AUTOMATIC ELECTRIC LTD.	96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401
				INDCOIL	PLOT NO. A- 150/ 151, 23RD U ROAD, WAGLE ESTATE, THANE WEST, CST RD, FRIENDS COLONY, HALLOW PUL, KURLA WEST, MUMBAI, MAHARASHTRA 400070
				KAPPA ELECTRICALS	KAPPA ELECTRICALS, KAPPA CONSOLIDATED PVT. LTD., SOUTHERN ELECTRIKS 14, CART TRACK ROAD, MADUVANKARAI, CHENNAI - 600 042, INDIA.
				PRAGATI ELECTRICALS	280/3,II POKHRAN RD
				PRECISE ELECTRICALS	47A-49A,CHAKALA ROAD ANDHERI(E),MUMBAI-99 MUMBAI, MAHARASHTRA, INDIA PIN-400 099
				SILKAANS ELECT.MFG.CO.PVT.LTD	PLOT NO: R-247, T.T.C. INDUSTRIAL AREA, M.I.D.C , RABALE, NAVI MUMBAI- 400 701INDIA
				PRAYOG ELECTRICALS PVT. LTD.	GROUND FLOOR, THAKORE INDUSTRIAL COMPUND, STATION ROAD, VIDYA VIHAR (W), NATHANI ROAD , OPP. AMIBIKA TEMPLE,MUMBAI Mumbai - 400086, Maharashtra, India
STATION LIGHTING SYSTEM	558-11000-A	MCB	ES51	MDS SWITCHGEAR LTD	314-317SHAH NAHAR ESTATE
				INDO ASIAN	B-24, PHASE - II , NOIDA - 201305, U.P.
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				S&S POWER SWITCHGEAR LTD,	NEW NO. 67, OLD NO. 19, DR. RANGA ROAD, MYLAPORE, CHENNAI - 600004
STATION LIGHTING SYSTEM	558-11000-A	PHOTOELECTRIC SWITCH	ES86	REPUTED MAKE	
STATION LIGHTING SYSTEM	558-11000-A	PVC WIRES	ES80	BIS APPROVED MAKE	
STATION LIGHTING SYSTEM	558-11000-A	TERMINAL BLOCKS	ES62	WAGO-CONTROLS	C 27, GREATER NOIDA, SECTOR 58, C BLOCK, SECTOR 58, NOIDA, UTTAR PRADESH 201307
				CONNECT WELL	309A/4, 3RD FLOOR, KALKAJI, OKHLA IND AREA PH-2, GOVINDPURI, NEW DELHI, DL 110019
				ELMEX CONTROLS PVT. LTD.	12,G.I.D.C.ESTATE,MUKARPURA ROAD,VADODARA-390010
				ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI
				TECHNOPLAST	OPP.I.M.INTER COLLEGE, BEGUM SARAI KHURD ROAD, AMROHA - 244221, U.P.
STATION LIGHTING SYSTEM	558-11000-A	TIMERS - ELECTRONIC	ES64	PHOENIX MECANO LTD.,	388 BHARE, TALUKA MULSHI, POST GHOTAWADE, PIRANGOOT, INDUSTRIAL AREA, PUNE-412115
				ESSEN DEINKI	FLAT NO. 502, SKYLINE HOUSE 85, NEHRU PLACE NEW DELHI
				BCH	20/4, MATHURA ROAD, FARIDABAD, HARYANA-121006
				ALSTOM LTD	A-7, SEC-65, NOIDA
				L&T	32, SHIVAJI MARG, P.O. BOX- 6223, NEW DELHI-110015
				TELEMECHANIQUE/ SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
				SCHNEIDER ELECTRIC INDIA PVT. LTD.	9TH FLOOR, BLDG. NO. 10, TOWER-C, DLF CYBER CITY, PH-II, GURGAON-122002
STATION LIGHTING SYSTEM	558-11000-A	VOLTMETER	ES75	ELECTRONIC AUTOMATION PVT. LTD.	20, KHB INDUSTRIAL AREA YELAHANKA BANGLORE-560064
STATION LIGHTING SYSTEM	558-11000-A			AUTOMATIC ELECTRIC LTD.	96 AB LONAVLA INDUSTRIAL ESTATE NANGARGAON, LONAVLA-410401
				RISHABH INST.PVT LTD	RISHABH INSTRUMENTS PVT. LTD.F-31, MIDC, SATPURNASHIK - 422007MAHARASHTRA INDIA



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 1 OF 9

DATA SHEET –C

S. No.	Description	Unit	Value
1.0	SYSTEM DESIGN DATA		
1.1	Design ambient	°C	
1.2	AC Supply		
a)	Rated voltage	V	
b)	Rated frequency	Hz	
c)	Voltage variation (permissible)	%	
d)	Frequency variation (permissible)	%	
e)	Combined voltage & frequency variation (sum of absolutes permissible)	%	
f)	System fault level & duration	kA, sec.	
2.0	APPLICABLE STANDARDS IS 60947 Low voltage switchgear and controlgear IS 11171 Dry type transformers IS 13703 Low voltage fuses for voltages not exceeding 1000V AC or 1500 V IS 10118 Code of practice for selection, installation and maintenance of switchgear and controlgear IS 60898 Electrical Accessories - circuit breakers for over protection for household and similar installations IS 1901 Visual indicator lamps IS 60079 Explosive atmospheres IS 5572 Classification of hazardous areas (other than mines) having flammable gases and vapours for electrical installation IS:2551 Danger notice plates		
3.0	LIGHTING/ WELDING DISTRIBUTION BOARDS		
3.1	Operational Front		
3.2	Type of execution of modules (functional unit)		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 2 OF 9

3.3	Type of sheet steel		
3.4	Sheet metal thickness (minimum)		
a)	Non-load bearing covers	mm	
b)	Non-load bearing partitions	mm	
c)	Load bearing members	mm	
d)	Frames	mm	
e)	Door	mm	
f)	Withdrawable unit (if applicable)	mm	
3.5	Cable alley width (minimum)	mm	
3.6	Bus bar material		
3.7	Earth bus bar material		
3.8	Degree of Protection		
a)	Main Panel		
b)	Transformer cubicle		
3.9	Gland plate thickness	mm	
3.10	AC LDB/ WDB		
a)	No. of Incomers		
b)	Bus coupler required		
c)	Incomer and Bus coupler rating	A	
d)	Type of Incomer and Bus coupler		
e)	Type of Outgoing Feeders		
f)	Outgoing feeders rating	A	
g)	Cable entry		
3.11	Lighting Transformer		
a)	Rating	kVA	
b)	Type of cooling		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 3 OF 9

c)	Voltage ratio	V	
d)	Rated frequency	Hz	
e)	No. of phases		
f)	Vector group		
g)	Off circuit taps		
	Tap range, steps	%	
	Voltage of each tap	V	
h)	Impedance at rated current, frequency at 75 °C	%	
i)	Rated current		
	Primary	A	
	Secondary	A	
j)	Transformer type		
k)	Transformer winding insulation		
l)	Transformer winding insulation temperature rise limit		
n)	Type of ventilation arrangement provided for transformer enclosure		
o)	Winding conductor material		
p)	Iron loss at 50 Hz and 100% rated voltage	kW	
q)	Copper loss at rated load at 75 °C	kW	
r)	Regulation at full load at 75 °C and 0.8 p.f. lagging		
s)	Weight	kg	
4.0	LIGHTING PANELS		
4.1	Application		
4.2	Type of sheet steel		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 4 OF 9

4.3	Sheet metal thickness (minimum)		
3.4	Degree of Protection		
a)	Indoor panel		
b)	Outdoor panel		
c)	Canopy in outdoor panel		
4.5	Bus bar material		
4.6	Earth bus bar required		
4.7	Earth bus bar material (if applicable)		
4.8	Gland Plate	mm	
4.9	Earthing studs required		
4.10	Hinged door with locking facility		
4.11	AC Lighting Panel		
a)	Incomer rating	A	
b)	Type of Incomer		
c)	Earth Leakage Circuit Breaker (ELCB) in incomer required		
d)	Type of Outgoing Feeders (non-flameproof panel)		
e)	Type of Outgoing Feeders (Flameproof panel)		
f)	Type of Outgoing Feeders (Street Light panel)		
g)	Timer required for indoor panel		
h)	Timer required for outdoor panel		
i)	Timer required Street Light panel/ High mast feeder pillar		
j)	Photocell required for Street Light panel/ High mast feeder pillar		
k)	Outgoing feeders rating	A	
5.0	COMPONENTS OF LIGHTING SYSTEM EQUIPMENT		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 5 OF 9

5.1	Moulded Case Circuit Breaker (MCCB)		
a)	Rated voltage	V	
b)	Number of poles		
c)	Rated short circuit duty	kA	
d)	Rated breaking capacity (rms)	kA	
e)	Rated making current (peak)	kA	
f)	Release with short circuit		
g)	Release with overload		
h)	Release with under voltage		
i)	Auxiliary contacts		
	Numbers	NO+NC	
	Rating	A	
5.2	Switch-Fuse Unit		
a)	Utilisation category for main contacts		
5.3	Miniature Circuit Breaker		
a)	SPN MCB rating (min)	A	
b)	DP MCB rating (min)	A	
c)	TPN MCB rating (min)	A	
d)	Short time rating	kA	
e)	Magnetic short circuit protection required		
f)	Thermal overload protection required		
5.4	Current Transformer		
a)	Type		
b)	Secondary current rating	A	
c)	Burden	VA	
d)	Accuracy class		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 6 OF 9

e)	Instrument Safety Factor		
5.5	Voltage Transformer		
a)	Type		
b)	Secondary terminal voltage (phase-phase)	V	
c)	Burden	VA	
d)	Accuracy class		
e)	Winding configuration		
f)	System grounding		
5.6	Indicating Meters		
5.6.1	Ammeter		
a)	Type		
b)	Shape		
c)	Size		
d)	Accuracy		
e)	Current coil rating	A	
f)	Angle of deflection	deg	
5.6.2	Voltmeter		
a)	Type		
b)	Shape		
c)	Size		
d)	Accuracy		
e)	AC voltage coil rating	V	
f)	DC voltage coil rating	V	
g)	Angle of deflection	deg	
5.6.3	Energy meter (if applicable)		
a)	Type		
b)	Accuracy		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 7 OF 9

c)	Current coil rating	A	
d)	Voltage coil rating	V	
5.7	Power Contactors		
a)	Coil voltage (nominal)		
	AC contactors	V	
	DC contactors	V	
b)	Current rating of contacts		
	Power	A	
	Control	A	
5.8	Under voltage relay		
a)	Type		
b)	Coil voltage rating	V	
c)	Means for in-built testing provided		
5.9	Timer		
5.9.1	Time switch		
a)	Type		
b)	Range	hr	
c)	Coil voltage rating	V	
5.9.2	Timer for AC-DC changeover		
a)	No. of contacts		
	ON time delay	NO+NC	
	OFF time delay	NO+NC	
	Instantaneous	NO+NC	
b)	Coil voltage rating		
	AC timer	V	
	DC timer	V	
c)	Time delay range		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 8 OF 9

	AC timer	sec	
	DC timer	Sec	
5.10	Selector switch		
a)	Type of selector switch		
b)	Lockable		
5.11	Push Button		
a)	Voltage grade	V	
b)	Potential free contacts		
5.12	Indicating Lamps		
a)	Lens Colour		
	ON condition		
	OFF condition		
b)	Circuit voltage	V	
5.13	Cable Glands		
a)	Type		
b)	Material		
c)	Nickel Plating provided		
d)	Flameproof glands with flameproof equipment		
5.14	Cable Lugs		
a)	Type		
b)	Material		
6.0	PAINTING		
6.1	Paint shade		
a)	LDBs		
b)	LPs		



**TECHNICAL SPECIFICATION FOR
LIGHTING/WELDING DISTRIBUTION
BOARDS & LIGHTING PANELS**

**RENOVATION & RETROFITTING OF ESP
PACKAGE FOR RAMAGUNDAM STPS,
STAGE-I (3X200 MW)**

SPECIFICATION NO. PE-TS-448-558-E002

VOLUME II

SECTION - II

REV. 0

DATE: 24.09.2019

SHEET 9 OF 9

6.2	Paint Finish		
a)	Interior		
b)	Exterior		
6.3	Paint Thickness	Microns	



**TECHNICAL SPECIFICATION FOR
DISTRIBUTION BOARDS**

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 1 OF 22

SECTION – II

STANDARD TECHNICAL REQUIREMENTS



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 2 OF 22

1.0 INTENT OF SPECIFICATION

- 1.1 The requirements given in specification shall be fully complied with.
- 1.2 The “design” shall broadly cover the selection of components, materials, sizes etc. for the equipment of supply in vendor’s scope. Complete responsibility of establishing the correctness of equipment design rests with the vendor.
- 1.3 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing required function in a manner acceptable to Purchaser, who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgement is not in full accordance herewith.
- 1.4 Make of all equipment and components shall be to the approval of Purchaser.

2.0 CODES & STANDARDS

- 2.1 The material shall comply with all currently applicable safety codes and statutory regulations of India as well as of the locality where the material is to be installed.
- 2.2 The material, construction, manufacture, inspection and testing shall conform to the latest revisions of standards as specified in Data Sheet A.
- 2.3 In case of conflict between the applicable reference standard and this specification, stringent requirement shall govern.

3.0 DESIGN REQUIREMENTS

3.1 LIGHTING DISTRIBUTION BOARD (LDB) / WELDING DISTRIBUTION BOARD (WDB)

3.1.1 General Requirements of LDBs/ WDBs

- a) LDB/WDB shall be totally enclosed, modular in construction, indoor type and suitable for electrical system data as specified in Data Sheet-A. The LDB/ WDB shall be free standing type suitable for installation on cable trenches / floor.
- b) LDB/ WDB shall consist of dust and vermin proof cubicles without the use of louvers (except the transformer compartment, where applicable).
- c) Good quality synthetic rubber / neoprene gaskets shall be put around the door, cover edges and cut-out edges for push button, lamps etc. for protection against dust. The door when closed, shall compress the gasket uniformly.
- d) Cut-out edges for instruments, relays etc. shall have sufficient overlap surface to minimize the dust entry. The arrangement for the front mounting of switch



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 3 OF 22

handles shall render the LDB/ WDB reasonably dust free such that the normal operations are not affected.

- e) The LDB/ WDB shall be designed to prevent contact with live parts both within the modules and in the cable alley.
- f) The bidder shall be responsible to check and coordinate the MCB characteristic with back up fuses etc. provided.
- g) All equipment shall be constructed of non-hygroscopic and non-flammable materials.
- h) All components mounted in the LDB/ WDB shall be accessible and shall not impede access to wiring or terminals. All faults except busbar fault which may occur within any individual unit shall be confined within that unit only and shall not cause shutdown of any section of the board other than the affected unit itself. Maintenance and inspection shall be possible in any individual unit without affecting other units.
- i) Incoming unit shall comprise of either switch-fuse/ composite switch-fuse unit or MCCB as per Data Sheet A. Outgoing units shall be either switch-fuse/ composite switch-fuse unit or MCCB as per data Sheet A.
- j) Interlock between compartment door and modules shall be provided such that the door cannot be opened without switching off the power supply to the module.
- k) Defeat interlock shall be provided for the units comprising of switch or moulded case circuit breaker as a means of isolation device, such that it is possible to open the door with device ON. It shall not be possible to close the door till the interlock has been reinstated.
- l) Each LDB/ WDB shall be fitted with base frame made of angle or channel.
- m) All fixing nuts and bolts together with grounding bolts shall be provided.
- n) Lifting lugs shall be provided for each shipping section of LDB/ WDB. Removal of such lugs or hooks shall leave no opening in the LDB/ WDB.

3.1.2 LDB/ WDB with transformers (Additional Features)

- a) The LDB/ WDB shall be arranged in two adjacent but separate compartments, one compartment for the lighting transformer and the other for the incoming & outgoing feeders etc.
- b) The transformer shall be mounted on the base channel and it shall be possible to easily remove the transformer from the cubicle after opening the door. Necessary portable ramp made of mild steel shall be supplied along with each LDB/ WDB.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 4 OF 22

- c) Independent gasket hinged door with operating handle shall be provided for access to transformer & its taps. Operating handle shall have built-in key locking arrangement.
- d) Suitable ventilation arrangement for the transformer compartment to dissipate the heat of the transformer shall be provided. The arrangement shall be in the form of louvers and the same shall be provided with galvanised wire mesh with dust catchers on the inside.
- e) Connections between transformer secondary terminals and the busbars shall be made by using PVC insulated flexible copper cables or busbars.
- f) Warning plate shall be provided on transformer enclosure. The inscription of warning plate shall be as given below:
 - DO NOT OPEN DOORS WHEN ENERGISED
 - KEEP TAPS AT SAME POSITION FOR ALL PHASES
- g) Transformer enclosure shall be provided with a danger plate.

3.1.3 Lighting Transformer/ Welding Transformer

- a) Transformer, where specified, shall form an integral part of LDB/ WDB.
- b) Lighting transformer shall be dry type, natural air cooled and suitable for mounting inside the lighting distribution board. Transformer particulars shall be as specified in Data Sheet A.
- c) Rating of transformer shall be as per BOQ.
- d) Winding shall be of copper material and maximum winding temperature at full load and under site conditions shall not exceed 120 °C.
- e) Transformer shall be suitable for cable connections on the primary side and flexible cable or busbar connection on the secondary side.
- f) The secondary neutral of the transformer shall be brought out for getting a grounded 4 wire supply system.
- g) The transformer neutral shall be brought outside the LDB/ WDB for earthing. The neutral bus bar shall be insulated from the LDB/ WDB enclosure.
- h) Transformers shall be provided with the rollers, pulling holes, lifting lugs, jacking positions etc.

3.1.4 Busbars, Connections and Joints

- a) Busbars shall be supported on non-hygroscopic and non-inflammable insulators of material such as glass reinforced moulded plastic material, epoxy cast resin



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 5 OF 22

etc. Separate supports shall be provided for each phase of the busbars. Insulation level of neutral busbar shall be same as that of phase busbars.

- b) Busbars shall be contained in a separate vermin-proof compartment within the LDB/ WDB and shall have bolted sheet steel covers for providing suitable access.
- c) Busbar clearances in the air shall be as per applicable standard for 415V, 3 phase system.
- d) Temperature for busbars, droppers and connections shall not exceed 90 deg.C for an ambient of 50 deg.C while carrying maximum continuous current.
- e) The busbar, busbar connections and supports shall have sufficient strength to withstand thermal and electromechanical stresses produced by the specified short circuit level of the system.
- f) Busbars (including neutral busbar) shall be capable of carrying the short-time current specified in Data Sheet A. The duration of short-time current shall be 1 sec unless mentioned otherwise in Data Sheet A. For the specified current and duration, there shall be no damage to the equipment.
- g) The neutral bus shall be rated same as phase bus.
- h) Main busbars and connections shall be prominently marked and displaced for standard sequence counting from rear to front, top to bottom, or left to right as viewed from the switching device operating mechanism side.
- i) Busbars and connections shall be provided with colour coded PVC sleeves. All live parts shall be properly shrouded with insulating material.
- j) Earth busbar shall be provided separately.
- k) Busbar Joints
 - Busbar and tap off joints shall be bolted type.
 - Busbars shall be thoroughly cleaned before jointing. Suitable contact grease shall be applied to remove oxide film just before jointing.
 - For copper busbars, the connecting portion shall be tinned or silver plated.

3.1.5 Wiring and Terminals

- a) All internal wiring for connections to remote equipment shall be brought to terminal boards. Spare contacts of devices shall also be wired upto terminal board as per schemes. Wires shall not be jointed or teed-off except at terminal points.
- b) Wiring shall be made by 1100 volt grade three / seven strand PVC insulated copper wire having a cross-sectional area of not less than 1.5 sq.mm. All



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 6 OF 22

connections from CT leads upto instruments, terminals shall be made by copper wires of minimum 2.5 sq.mm size.

c) All wiring shall be made with the Colour Codes specified below :

i) 3 phase AC Connections

Phase 1 (R)	Red
Phase 2 (Y)	Yellow
Phase 3 (B)	Blue
Neutral	Black

ii) 1 phase AC Connections

Phase	Red / Yellow / Blue (as per associated circuit)
Neutral	Black

iii) DC Connections

Positive	White
Negative	Grey

iv) Earth Connection Green

d) Where wiring passes from one compartment to another, the aperture shall be 'Bushed' to prevent damage to wires against sheet metal edges. Bushes may comprise of good quality rubber / PVC grommets.

e) Every wire end shall be fitted with numbered ferrules of white or yellow colour having glossy finish with identification number engraved in black. Ferrules shall be made of moisture and oil resisting insulating material. Ferrules shall be of interlocked type or tight fitting type. Ferrules shall be so fitted that they will not get detached, when the wire is removed from the terminal.

f) System of marking of wiring shall be as per applicable standard.

g) All wires used internally shall have crimped on tinned copper lugs for terminations.

h) Terminal boards shall be stud type with insulating barriers of adequate height.

i) Terminal boards shall have separate terminals for incoming and outgoing wires with not more than two wires connected to any one terminal.

j) Terminal boards shall be mounted vertically or in the horizontal rows and properly spaced to have clean wiring arrangement, adequate access for putting ferrules, making terminations etc. It shall be possible to read the ferrule numbers when the wiring is complete. Where terminals may be live when the equipment is isolated from the main supply, these shall be clearly marked near the terminal boards.

3.1.6 Cable Terminations



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 7 OF 22

- a) All cables, either incoming or outgoing to the LDB/ WDB, shall be terminated in a cable chamber. For each panel, there shall be a cable chamber on the side. The door of cable chamber should open or be locked with the help of a tool. Unless stated otherwise in Data Sheet A, all cables shall enter from the bottom.
- b) Removable undrilled gland plates of sheet steel shall be provided in the cable chamber for entry of cables. Minimum thickness of gland plate shall be as per Data Sheet-A. The gland plate shall be of adequate size for connecting requisite number of cable glands for power and control cables.
- c) Heavy duty bolt-on termination tinned copper lugs of compression type shall be used for power cable termination. The tinned copper cable lugs for all incoming and outgoing power cables shall be supplied by the vendor.
- d) For supporting and clamping of cable cores at regular interval in cable alleys, suitable slotted angle upto the respective terminal blocks shall be provided.

3.1.7 Earthing

- a) An earth busbar of adequate size of shall be provided at the bottom for the entire length of the LDB/ WDB. Material of earth busbar shall be GI unless mentioned otherwise in Data Sheet A.
- b) Every metal part other than those forming parts of an electrical circuit shall be connected to the earth bus by means of high conductivity copper wire of size not less than 2.5 sq. mm. cross-sectional area.
- c) Doors shall have a flexible copper wire for earth connection to fixed unit.
- d) Each LDB/ WDB shall be fitted with two earthing studs located in accessible position on sides for connection of internal earth busbar to the external earthing connection.
- e) Earth busbar shall be brought outside LDB/ WDB for making external connections.

3.1.8 Types of LDB/ WDB

- a) The LDB/ WDB shall be of following type:
 - LDB/ WDB-H (n) - AC LDB/ WDB with 100 kVA transformer
 - LDB/ WDB-F (n) - AC LDB/ WDB with 50 kVA transformer
 - LDB/ WDB-N (n) - AC LDB/ WDB with no transformer
 - LDB-D (n) - DC LDB

NOTE: (n) indicates number of outgoing feeders.

- b) AC LDB/ WDB (LDB/ WDB-H, LDB/ WDB-F, LDB/ WDB-N)



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 8 OF 22

Each LDB/ WDB shall comprise of the following and comply with Data Sheet A :

- i. One lighting/welding transformer (LDB/WDB-H & LDB/WDB-F).
- ii. Incomer(s) of TP / TPN switch-fuse unit or MCCB / MCCB with neutral link as per Data Sheet A. It shall be provided on the primary side of transformer for LDB/WDB type LDB/WDB-H & LDB/WDB-F.
- iii. Set of busbars with 3 phase and neutral.
- iv. TPN switchfuse units or MCBs for each outgoing circuit.
- v. Three indicating lamps with fuses for indicating bus supply ON.
- vi. CT operated ammeter with selector switch.
- vii. VT operated voltmeter with selector switch.
- viii. Power & control terminals, earth-stud, earth busbar, designation labels, internal wiring, power cable lugs, glands etc. shall be provided to complete the LDB/ WDB in all respects.

c) DC LDB (LDB-D)

Each LDB shall comprise of following and comply with enclosed Data Sheet A :

- i. Incomer & Outgoing feeders shall be as per Datasheet-A.
- ii. Two pole DC contactor on the incoming circuit for changeover to DC in case of AC normal supply failure.
- iii. One under voltage relay of suitable range, if required.
- iv. One ON delay timer.
- v. One test push button.
- vi. Set of busbars for positive and negative.
- vii. Two indicating lamps with fuses for indicating bus supply ON.
- viii. Power & control terminals, earth-stud, earth busbar, designation labels, internal wiring, power cable lugs, glands etc. shall be provided to complete the LDB in all respects.

3.2 LIGHTING PANELS (LPs)



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 9 OF 22

3.2.1 General Requirements of Lighting Panels

- a) LPs shall be totally enclosed, suitable for electrical system data as specified in Data Sheet A. The LP shall be suitable for mounting on wall / column / structure.
- b) Panels shall be suitable for indoor / outdoor application as per Data Sheet A.
- c) All components of the LP shall be fully mounted inside the panel. LPs shall have only one operational front. Door shall be provided to give full access to all the components. Door shall have padlocking arrangement.
- d) LPs shall consist of dust and vermin proof cubicles without the use of louvers.
- e) Good quality synthetic rubber / neoprene gaskets shall be put around the door. The door when closed, shall compress the gasket uniformly.
- f) The LPs shall be designed to prevent contact with live parts when the front door is open.
- g) All busbars (phase, neutral, positive, negative as applicable) within a panel shall be of the same size.
- h) All control wiring inside the panels shall be carried out with 1100 V grade, PVC insulated flexible copper wire of 2.5 sq. mm size.
- i) The rated continuous current of the equipment and components shall be as given in Datasheet-A. These ratings shall be obtained with the components mounted in their housing as in service without exceeding the permissible temperature rise.
- j) Each LP shall be fitted with M.S. mounting brackets.
- k) Panel shall be suitable for top / bottom cable / conduit entries. However, outdoor LPs shall have bottom cable / conduit entry. Removable undrilled gland plate of sheet steel shall be provided for entry of cables. Minimum thickness of gland plate shall be as per Data Sheet-A. The gland plate shall be of adequate size having knock-outs for requisite number cable connections. Gland plate shall be provided with gasket.
- l) The lighting panel shall be complete with copper busbars, and shall incorporate incomer and outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.
- m) Each lighting panel shall be fitted with two GI earth studs located in accessible position on the outside of the panel on opposite sides.
- n) All metal parts of the panel except current carrying parts shall be bonded together electrically to the earthing stud.
- o) Each panel shall be fitted with phase barriers of fireproof insulating material in such a manner that it is not readily possible for personnel to touch the phase



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 10 OF 22

busbars. Insulating sheet shall be fitted around the MCBs such that only the surface and toggle of the MCBs are available on the front.

- p) The supply of cable lugs for power and control cable connections forms part of the supply of equipment.
- q) Each panel shall be provided with a circuit directory plate with inscriptions neatly typed and laminated, fitted on the inside of door.

3.2.2 Type of Lighting Panels

- a) LP-A (n) - AC Lighting Panel
- b) LP-D (n) - DC Lighting Panel
- c) LP-F (n) - Fancy Lighting Panel (Decorative)
- d) LP-S (n) - Street Lighting Panel

NOTE: (n) indicates number of outgoing circuits.

3.2.3 AC Lighting Panel (LP-A)

- a) LPs shall be provided with incomer and requisite number of outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.
- b) Separate neutral shall be available at terminal block for each outgoing circuit.
- c) Construction of AC Normal and AC Emergency panels shall be same.

3.2.4 DC Lighting Panels (LP-D)

- a) LPs shall be provided with incomer and requisite number of outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.

3.2.5 Decorative Type Lighting Panels (LP-A)

- a) Decorative lighting panels shall be designed for use in areas like administrative building, service building, canteen, residential premises etc.
- b) Thickness of sheet steel shall be as per manufacturer's practice.
- c) LPs shall be of tone colour with elegant finish.
- d) LPs shall be provided with incomer and requisite number of outgoing circuits as per Data Sheet-A. Number of outgoing circuits shall be as per BOQ.
- e) LPs shall be suitable for either surface or flush mounting. Flush mounted panels shall have the collared door suitable for matching with the wall.
- f) Lighting Panels may be provided with transparent acrylic cover for operation of MCBs.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 11 OF 22

g) LPs shall be provided with knockouts on the top, bottom and sides.

3.2.6 Street Lighting Panel (LP-S)

- a) Street Lighting Panels shall be provided for feeding power supply to luminaires of street light poles, flood lighting poles, lighting masts, watch towers etc.
- b) Each Street Lighting Panel shall comprise of the following :
 - i. One TPN door interlocked switch-fuse unit incomer. Interlock defeat feature shall also be provided.
 - ii. Three pole AC Contactor
 - iii. 0 - 24 hrs timer and/or photo-electric switch for automatic switching of contactor
 - iv. Three phase & neutral busbars
 - v. Single pole or three pole MCBs for each outgoing circuit as per Data Sheet A
 - vi. Two lamps for bus supply ON & OFF indications
 - vii. Complete wiring arrangement as per control scheme.
 - viii. Auto-Manual selector switch
 - ix. ON push button
 - x. OFF push button
- c) Switching ON and switching OFF shall be through both 0 - 24 hrs timer and light sensor in automatic mode.
- d) One number light sensor in weather proof enclosure having IP:55 degree of protection shall be supplied loose along with each SLP.
- e) Internal power wiring shall be done with PVC insulated Cu wire of suitable size. All control wiring inside the panel shall be carried out with 1100 V grade, PVC insulated flexible copper wires.
- f) Two nos. outgoing circuit in each panel shall be tapped before contactor for watch tower supply.

4.0 COMPONENTS OF LDB/WDB AND LIGHTING PANEL

4.1 MOULDED CASE CIRCUIT BREAKERS



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 12 OF 22

- a) Moulded case circuit breakers (MCCBs) shall be provided when called for in Data Sheet A for use in lieu of switch fuse. MCCB shall meet the requirements stipulated in Data Sheet A.
- b) MCCBs in AC circuits shall be of single throw, air break, heavy duty type triple pole construction arranged for simultaneous three pole manual closing and opening and for automatic tripping at short circuit and overload. Neutral link shall be provided for LDB/ WDB without transformers.
- c) Operating mechanism shall be quick make, quick break and trip free type.
- d) The ON, OFF & TRIP positions of the MCCB shall be clearly indicated so as to be visible to the operator when mounted as in service. Operating handle shall be provided on front of the LDB/ WDB.
- e) MCCBs shall be capable of withstanding the thermal stresses caused by overloads and short circuits. The maximum tripping time under short circuit shall not exceed 20 milli-seconds.
- f) MCCB terminals shall be shrouded and designed to receive cable lugs for cable sizes relevant to circuit ratings.
- g) Under voltage releases and other releases shall be provided as specified in data Sheet-A.

4.2 SWITCH-FUSE UNITS

- a) These units shall preferably comprise of switches having integral fuses, called composite units. Alternatively, combination units of separate switch and fuse may also be acceptable.
- b) These units shall be provided for general purpose i.e. incoming or outgoing units.
- c) The units shall be of the air break air insulated type and designed to ensure safety to operating personnel.
- d) Composite units shall have integral fuses i.e. fuse carrier with fuse link (fuse link forming the moving contact). The design shall ensure that the moving contact is not live when switch is open i.e. in OFF position, so as to facilitate removal of fuse.
- e) The switch shall be capable making and carrying the system prospective fault current, but limited in magnitude and duration by the cut off characteristics of the largest HRC fuse link that may be fitted to that unit.
- f) The fixed contact shall be so shrouded that maintenance of the unit can be carried out in safety with the busbars live.
- g) Where one isolating switch is used as the incoming device, the incoming side fixed contacts shall be shrouded to ensure that maintenance can be carried out with the remote fuse and switch closed.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 13 OF 22

- h) Composite switch-fuse or the combination of switch and fuse shall meet the requirements of its components as follows:

Isolating Switch

- i. Switches shall be air-break, quick make, and quick break heavy duty type conforming to applicable standard.
- ii. All switches shall have visible ON / OFF position indication and shall be padlockable in any (ON / OFF) position.
- iii. Switches shall be door interlocked such that it shall not be possible to gain access to inside the unit unless the isolating switch is in OFF position.
- iv. The switches shall be suitable for independent manual operation.
- v. The switch contacts shall be of silver alloy or silver plated copper and springs of non-corrosive material.
- vi. Inter-phase barriers shall be provided to prevent possibilities of phase to phase fault in the switch. The switch shall also be shrouded from all sides to prevent access to live parts on the switch after opening the unit door. The barriers and shrouding shall extend upto the height of switch to fully enclose both side terminals of the device. The arrangement shall permit easy maintenance.

High Rupturing Capacity (HRC) Fuses

- i. The fuse serving as the short-circuit protective device in isolating fuse-switch units shall be of HRC cartridge, current limiting and plug-in non-deteriorating type.
- ii. The fuse carriers shall be easily withdrawable for replacement of fuse. Insulated fuse pullers shall be provided where fuses are not mounted in insulating carriers to remove and replace fuses in live conditions.
- iii. Fuses shall preferably be fitted with a device to indicate operation (i.e. when the fuse has blown).
- iv. Live terminals of fuse bases shall be shrouded to prevent contact with personnel where fuse links are not mounted in carriers and are directly plugged into the fuse base. Inter-phase barriers extending throughout the length of the fuse base shall be provided to prevent inter-phase short circuit. They shall be shrouded from all sides to prevent accidental contact.
- v. Fuse carriers and bases shall be of good quality moulded insulating material. Porcelain fuse bases and carriers will not be accepted.
- vi. The rating and characteristics of fuse links shall be chosen appropriately for short circuit protection of circuits downstream.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 14 OF 22

4.3 MINIATURE CIRCUIT BREAKERS

- a) The use of miniature circuit breakers (MCBs) combining thermal overload and magnetic short circuit protection shall be application for the outgoing circuits of Lighting Panels.
- b) MCBs shall have suitable rating as specified in Data Sheet A.
- c) MCBs shall be suitable for housing in the lighting panel and for connection of copper link bus bar at the incoming and copper lugs at the outgoing ends.
- d) The terminals of MCB and ON/OFF positions shall be clearly and indelibly marked.

4.4 CURRENT TRANSFORMERS

- a) CTs shall be air insulated having insulation class E or better, cast resin type and shall be capable to withstand the thermal and mechanical stresses resulting from maximum short circuit.
- b) The short time current duration for CTs shall be one second.
- c) CT primary current shall not be less than the full load thermal rating of the associated circuit. CT secondary current shall be as specified in Data Sheet A. Polarity shall be marked in a suitable manner. The ratings shall be adequate to cater for the burden of connected instruments.
- d) CTs shall be of bar primary / wound primary / ring type capable of carrying the rated primary current.

4.5 VOLTAGE TRANSFORMER

- a) Voltage transformers (VT) shall be dry, cast resin type comprising of single phase or three phase units. They shall have their primary windings protected by current limiting fuses with interrupting capacity corresponding to that of the lighting board / panel.
- b) VT secondary windings shall be earthed in LDB/ WDB / LP through link, which can be removed for insulation testing.
- c) Three phase voltage transformers shall be as per Data Sheet A.

Single phase VTs shall have voltage rating of (Nominal System Voltage / $\sqrt{3}$) V / (110 / $\sqrt{3}$) V so that secondary voltage shall be 110 volts phase to phase when the secondary winding is star connected.

- d) VTs shall have an output rating adequate to cater to the burden connected to them.

4.6 INDICATING METERS



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 15 OF 22

- a) Meters shall be panel mounted, flush type and suitable for rear terminal connection.
- b) Meters and instruments shall be enclosed in dust proof, moisture resistant black finished cases and shall be suitable for tropical use. Instruments shall be suitable for operation from the secondary windings of CTs and VTs.
- c) All instruments shall be calibrated to enable direct reading of primary quantities. Instruments shall be adjusted and calibrated at manufacturer's works and shall have means of calibration, checking and zero adjustment at site.
- d) All the divisions and the quantity to be measured shall be clearly marked. Instruments shall conform to applicable standard having black numerals and lettering on white anti-parallax dial with knife edge pointer. Indicating instruments shall be of moving iron type for AC and moving coil type for DC circuits.
- e) Instruments having metallic cases shall be fitted with earthing terminals.

4.7 CONTACTORS

- a) Contactors shall be of the air break type, electromagnetic type fitted with arc shields.
- b) The operating coil shall be suitable for satisfactory operation in the range of 85% - 110% of nominal voltage specified under the Data Sheet A. The coil shall be tropicalized having insulation not less than class 'E'.
- c) Electrically independent auxiliary contacts not less than 2NO + 2NC for interlocking and indication shall be fitted to individual power contactor.
- d) All springs shall be made out of a corrosion proof material.

4.8 RELAYS

- a) Relays shall be provided on the various circuits as per schemes. Relays shall be flush mounted on front of the board. Relay case shall be painted with dull black or egg shell black enamel and with back connected terminals. Metal cases and frames of relay shall be earthed.
- b) All relays shall be of withdrawable type with built-in testing facilities, with provision for inspection, maintenance and replacement. Where built-in test facility is not provided for a particular relay, separate suitable test block shall be provided on the board for this purpose.
- c) Relay performance shall not alter due to mechanical shock or vibration or external magnetic field which may be present at the place of mounting.
- d) Each relay shall not have less than two independent pairs of contacts.

4.9 TIMERS



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 16 OF 22

4.9.1 Time Switch

- a) Time switch shall be suitable for automatic switching ON and OFF of street lighting / flood lighting circuits.
- b) Time switch have 00 - 24 hrs clock base.
- c) Time switch shall indicate actual time and shall permit accurate time setting.
- d) Time switch shall be rugged, independent of normal fluctuations of voltage / frequency and free from maintenance.
- e) Contact rating, clock accuracy, rated voltage rating and frequency rating of timer shall be suitable to its application.
- f) Time switch shall be provided with Ni-Cd battery.
- g) Time switch shall be suitable for mounting inside the panel.

4.9.2 On/Off Delay Timer

- a) On delay timer shall be required for continuation of DC supply for a limited duration when the AC Emergency supply has been restored and DG set is under stabilisation.
- b) Timer shall be fully static and suitable for operation on normal frequency and system voltage.
- c) Timer shall have high setting accuracy, high repeat accuracy, low reset time and low power consumption.
- d) Timer shall have the time setting range as mentioned in Data Sheet A.
- e) Timer shall be suitable for mounting inside the panel.

4.10 SELECTOR SWITCHES

- a) The rating and other features of the switches shall be suitable for the application. The number of positions and the number of contacts required for each switch shall be as indicated in the schemes
- b) Selector switches shall be stay put type, provided with properly designated escutcheon plates clearly marked to show operating position.
- c) Terminals carrying potential above 120 Volts shall be shrouded to prevent accidental contact with personnel.
- d) Ammeter selector switches shall have make before break contacts.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 17 OF 22

- e) The switches shall be suitable for semi-flush mounting with the front plate and operating handle projecting out. All connection to the switches shall be from the back.
- f) The arrangement for front mounting of these devices shall be such as to make them reasonably dust free so as not to interfere with normal operation.

4.11 PUSH BUTTONS

- a) Push button shall be heavy duty, flush mounted suitable for the application.
- b) Push button shall be provided with integral escutcheon plates marked with its function identified as per schemes.
- c) Colour shall be appropriate to the function.
- d) Minimum number of contacts shall be 2 NO + 2 NC or as per the requirements of control scheme.

4.12 INDICATION LAMPS

- a) Indication lamps shall be complete with lens covers and holders.
- b) Each lamp shall be fitted with a durable resistance integrally wired in series with the lamp. Alternatively, lamps with built in transformers are acceptable.
- c) The lamp cover (lens) shall be translucent of appropriate colour.
- d) Bulbs and covers shall be interchangeable, easily replaceable from the front without the need for any special means.
- e) Terminals having potential above 120V shall be shrouded to prevent contact with personnel.
- f) Terminals shall be suitable for ring type copper cable lugs of size depending upon the circuit rating.

4.13 CABLE GLANDS

- a) Whether specifically mentioned or not, cable glands of suitable sizes shall be supplied along with each equipment for power and control cables.
- b) Rubber components used in the gland shall be of neoprene.
- c) Name / trade name of manufacturer, type no. and applicable range of outer diameter of cable shall be engraved / indelibly printed on the cable gland.

4.14 CABLE LUGS

- a) All equipment shall be supplied with the power and control cable lugs of suitable size, whether specifically mentioned or not.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 18 OF 22

- b) Name / trade name and size of lug shall be engraved/ indelibly printed on each cable lug.

4.15 TERMINALS

- a) Terminals shall be stud type of copper material.
- b) Terminals shall be provided with transparent cover(s).
- c) Separate terminals shall be available for each termination of loop-in and loop-out power connections.

5.0 LABELING

- 5.1 Labels to identify all the Main assemblies, Sub-assemblies and components of the LDB/ WDB and LPs shall be provided.
- 5.2 Name and rating plate / marking shall be provided as required by relevant standard applicable to each component / assembly to be identified.
- 5.3 Labels shall be of two colour, three layer plastic material with matt or semi matt finish or of the anodised aluminium sheet.
- 5.4 All labels other than “Danger” or “Warning” labels shall have black lettering on a white background. Danger labels shall be as per applicable standard and shall not be affixed on to removable parts.
- 5.5 All labels shall be securely fixed on to the equipment by means of self tapping screws or other approved means.
- 5.6 Stick-on type labels of good quality and permanent mounting shall be acceptable for internally mounted components only.
- 5.7 A list of all such items to be labeled and text and type of labels to be provided is given below:

a) BOARD DESIGNATION (MAIN EQUIPMENT LABEL)

i. **Inscription :**

Designation & LDB/ WDB number for LDB/ WDB.
Designation and LP number for LPs.

ii. **Location :**

Top centre in the front of the LDB/ WDB.
Top centre in the front of the LP.

iii. **Material :**

3 Layer plastic material, fixation by self tapping, non-rusting screws, black inscription on white back ground.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 19 OF 22

b) OUTGOING - FEEDER DESIGNATION

- i. **Inscription** : Module number, LP number / purpose.
- ii. **Material** :
Black engraving on white anodised aluminium plate of thickness 1.6 mm or more. Plate to be secured with screws.

c) COMPONENT DESIGNATION

- i. **Inscription** : Letter symbol / Legend as assigned in schemes.
- ii. **Location** : Near or on the component
- iii. **Material** : Stick-on type

5.8 CIRCUIT DIAGRAM / DIRECTORY PLATE

- a) A diagram is to be prepared for fixing to the inside cover of every lighting panel giving details of the points controlled by each circuit.
- b) The circuit list shall be typed or printed stating the location of the equipment served, rating of the protective unit and the circuit loadings.
- c) The list shall be mounted on the inside of the cover door and shall be protected by an acrylic sheet cover to be easily removable to permit circuit modifications.

6.0 SURFACE TREATMENT

- 6.1 All metal parts and the surfaces (exterior & interior) of equipment, unless stated otherwise in case of reflectors, shall be degreased by dipping in hot alkaline solution and rubbed with wire brush to remove oil & scale from them & then rinsed in water. Alternatively, they may be shot / sand blasted.
- 6.2 Parts shall be pickled by dipping in hydrochloric acid tank to remove the rust from the surfaces formed during storage of sheets & then rinsed to remove traces of the acid. The cleaning and pretreatment of all metal parts shall be as per applicable standard.
- 6.3 The surfaces to be painted shall then be prepared by phosphatizing to protect them from further rusting & to create a good bond with the paint. The pretreatment shall conform to the applicable standard.
- 6.4 All parts shall then be subjected to a coat of red oxide primer paint.
- 6.5 All inside and outside surfaces of panel shall be spray painted with synthetic enamel of the shade and minimum thickness as per Data Sheet A.
- 6.6 Electrostatic or powder painting shall be acceptable subject to purchaser's approval.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 20 OF 22

- 6.7 Wherever possible, finished parts shall be coated with peelable compound by spraying method to protect the finished product from scratches, grease, dirty and oily spots during handling and transportation.

7.0 PACKING

- 7.1 Packing procedure shall conform to the following :

- a) The equipment shall be properly packed before dispatch. The packing shall prevent damage to the contents while handling and lengthy period of outdoor storage.
- b) The equipment shall be wrapped in weather proof packing using polythene sheets/ air bubble sheets/ thermocol sheets and then secured in wooden packing cases. Wood for wooden packing cases/ crates shall be chemically treated to prevent deterioration due to fungi and attack by termites, borers, and any other kind of infection.
- c) The equipment shall be secured by fixing base plate/ frame with the help of bolt and nuts etc. to bottom frame of the wooden packing cases/ crates. Suitable cushioning material like rubberised coir (min. 50 mm thick & 100 mm wide) shall be provided on the bottom support. Gap between the panel and casing shall be filled with rubberised coir with distance between consecutive supports less than 500mm.

- 7.2 Specification for the sea worthy packing, if enclosed, for the export jobs shall form part of the specification.

8.0 INSPECTION & TESTING

- 8.1 Bidder shall confirm compliance with the BHEL Standard Quality Plan (PE-QP-999-558-E005) without any deviations. At contract stage, the successful bidder shall submit the same QP for BHEL/ ultimate customer's approval. In case bidder has reference QP agreed with ultimate customer, same can be submitted for specific project after award of contract for BHEL/ ultimate customer's approval. There shall be no commercial implication to BHEL on account of any changes in QP during contract stage.
- 8.2 All the components and completely assembled equipment shall be tested as per the latest edition of standards. Charges for these tests shall be deemed to be included in equipment price.
- 8.3 All the specified type and routine tests shall be carried out to verify the rating and performance of the equipment. Where valid type test certificates in evidence of equipment performance claimed are available & approved by purchaser, the requirements for conducting type tests may be waived. The general arrangement of object under test shall be to purchaser's approval.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 21 OF 22

- 8.4 Functional testing shall be carried out for Lighting/Welding Distribution Boards/ Lighting Panels.
- 8.5 All manufacturing processes viz. machining, sheet forming, electroplating, wire routing, cleating & crimping, assembly, surface preparation shall conform to good manufacturing practices.
- 8.6 Inspection for dimensional & visual checks especially of the following, with respect to contract drawings, documents & standards shall be conducted:
- a) General sturdiness & rigidity of equipment.
 - b) Surface finishing.
 - c) Gasketting.
 - d) Inter-changeability.
 - e) Constructional features viz. location, accessibility & marking of components, segregation, accessibility to live parts (shrouding) etc.
 - f) Completeness of scope.
- 8.7 Safety interlocking verification shall be done.
- 8.8 Each lighting transformer shall be routine tested and one transformer of each rating shall be type tested in accordance with relevant standard in case type test certificates of similar transformers are not available / not acceptable to the purchaser.
- 8.9 Equipment shall be liable for rejection if tolerances on the values of dimensions, power consumption, impedances, temperature rise etc. exceed the specified values by purchaser and / or standards.

9.0 TOOLS AND TACKLE

- 9.1 Tools & tackle which are essential to facilitate assembly, adjustments, erection, maintenance & dismantling of equipment shall be provided as part of equipment supplied.
- 9.2 The above tools shall be supplied along with the initial consignment of equipment so as to be available prior to erection but may not be used for erection purposes.
- 9.3 Vendor shall also submit a list of recommended tools and tackle. Acceptance of these tools and tackle shall not be a binding on the purchaser.
- 9.4 Schedule of tools & tackle shall be filled up by bidder.

10.0 SPARES

- 10.1 Mandatory spares (if applicable) are indicated in BOQ-cum-price schedule.



TECHNICAL SPECIFICATION FOR DISTRIBUTION BOARDS

SPECIFICATION NO. PE-SS-999-558-E005

VOLUME II

SECTION II

REVISION: 0

DATE: 28.12.2016

SHEET 22 OF 22

10.2 Erection & commissioning spares are included in the bidder's scope of supply. Bidder to furnish list of E&C spares in the relevant schedules of the Bid Form and Price Schedules.

Indicative list of checks and tests

ATTRIBUTES / CHARACTERISTICS															
ITEMS/COMPONENTS / SUB SYSTEMS	Dimension	Paint shade, paint thickness, adhesion	Pre-treatment of sheet	IP protection	Proof load*	Surface finish	Deflection test*	HV & IR	Galvanise Test (If Applicable)	Functional	Bought out items/Bill of material	Routine tests as per relevant standard & specification	Acceptance tests as per relevant standard & specification	Constructional feature as per NTPC Specification	
Wall Mounted-Lighting Panel (IS-513, IS:5, IS:2629, 2633, 6745)	Y	Y	Y	Y		Y		Y		Y	Y	Y	Y	Y	
Switch box/junction box/ Receptacles Panel (IS-513, IS:5, IS:2629, 2633, 6745)	Y	Y	Y	Y		Y		Y	Y	Y	Y	Y	Y	Y	
Cable glands(BS-6121)	Y													Y	
Cable lug	Y													Y	
Lighting wire (IS-694)	Y											Y			
Flexible conduits	Y											Y		Y	
Conduits (Galvanise & Epoxy) IS-9537 & IS-2629, 2633, 6745	Y		Y						Y			Y		Y	
RCC Hume Pipe (IS-458)												Y			
Cable termination & straight through joint (IS 13573)	Y											Y		Y	
Cable Trays, bends, tees, crosses, Flexible supports system & accessories IS-513, 2629,2633,6745	Y		Y		Y	Y	Y		Y			Y	Y	Y	
Trefoil clamp	Y													Y	
GI flats for earthing & lighting protection (IS 2062, 2629, 6745,2633)	Y		Y						Y			Y		Y	
GI wire (IS-280)	Y											Y			
Fire Sealing System (BS -476)												Y	Y	Y	
.Note: 1. This is an indicative list of tests /checks. The manufacturer is to furnish a detailed Quality Plan indicating the practice and procedure along with relevant supporting documents.															

Indicative list of checks and tests

Item Components Sub System Assembly Attributes Characteristics	Make, Type, Rating/ TC	Dimension	Pre-Treatment of sheat	Paint Shade Thickness Adhesion & Finish	Galvanization Tests	IP Test	Bought Out Items/ Bill of Material	HV & IR	Functional Check as per spec.	Constructional Feature as per NTPC spec.	Routine Test as per relevant std and spec	Acceptance Test as per relevant std and spec	Item to conform to relevant standard
Luminaries (IS-10322 Part-5 Sec.I (non -LED type)	Y					Y		Y			Y	Y	Y
Electronic Ballast	Y										Y	Y	Y
Lighting Wire (IS-694)	Y										Y		
Fans (IS-374)	Y										Y		
Pole (IS-2713)	Y			Y						Y	Y	Y	
Lamps (IS-9800, IS-9974)	Y										Y	Y	
Lighting Mast (with raise & lower lantern type)	Y	Y			Y					Y	Y	Y	
Wall Mounted Lighting Panel (IS-513, IS-5)	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
Switch Box/ Junction Box/Receptacles/ Local Push Button-Station / Lighting Panel (IS-513, 2629, 2633, 4759, 6745)	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
Cable Gland (BS-6121)	Y	Y									Y		
Cable Lug (IS-8309)	Y	Y									Y		
Flexible Conduit	Y										Y		
Lighting Transformer (IS-H171)	Y									Y	Y		
Epoxy & Galvanised Conduit (IS-9537, 2629, 2633, 4759, 6745)	Y	Y									Y		Y