



BHARAT HEAVY ELECTRICALS LIMITED

TRANSMISSION BUSINESS HVDC ENGINEERING & SYSTEMS

COPYRIGHT AND CONFIDENTIALITY
The information on this document is the property of BHARAT HEAVY ELECTRICALS LTD.
It must not be used directly or indirectly in anyway detrimental to the interest of the company

DOCUMENT No.	TB-409-557-023	Rev. No.	00	Prepared	Checked	Approved
TYPE OF DOC.	TECHNICAL SPECIFICATION	SIGN				
TITLE		NAME	NS	SKS	AG	
PLCC Equipment		DATE	07/05/2020	07/05/2020	07/05/2020	
		GROUP	HVDC	W.O. No	Awaited	
CUSTOMER	POWERGRID FATEHGARH TRANSMISSION LIMITED- A 100% wholly owned subsidiary of Power Grid Corporation of India Limited					
PROJECT	Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route					
NOA NO.	FTL/765kV/SS02/NOAI/2(I) For Supply of Goods Contract Dated 05-11-19 & FTL/765kV/SS02/NOAII/2(II) For Supply of Service Contract Dated 05-11-2019					
Station	Fatehgarh-2 & Bhadla-2, Rajasthan					
CONTENTS						
Section	Description					No of Sheets
1	Scope, Bill of Quantity, Specific Technical Requirement					6
2	Equipment Specification					1+23+4
3	Project Details and General Technical Requirements					1+38
4	GTP - To be submitted during contract execution stage as per TS requirement.					1
5.	Checklist					10
Rev No.	Date	Altered	Checked	Approved	REVISION DETAILS	
Distribution			To	HVDC	TBMM	TBQM Vendor
			Copies	1	1	1 4



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

SECTION-1

Scope, Bill of Quantity, Specific Technical Requirements

1.1 Scope

This technical specification covers the requirements of system design and engineering, manufacture, testing at works, packing and dispatch, supervision of pre-commissioning, & supervision of site testing and commissioning of PLCC equipment. The bidder shall be responsible for coordinating the equipment supplied by him with the already existing carrier equipment at the respective sub-stations. Bidder shall also be responsible for collecting all the necessary information/data from the respective substations/concerned state Electricity boards for the installation of the equipment. No deviation from the requirements specified in various clauses of this specification shall be allowed. A certificate to this effect shall have to be furnished along with the offer.

The fitments offered shall be of POWERGRID approved make or its subsequent approval from PGCIL shall be bidder's responsibility, with no commercial implications to BHEL. If any of the make offered by the bidder is not acceptable to M/s POWERGRID, the bidder has to supply alternate POWERGRID approved make, meeting the specification, with no commercial implications to BHEL.

Wherever bidder offers any item/spare in lieu of the same being "Built-in feature" of any fitment or the same being "Not applicable" is subject to approval by Powergrid. No price implication will be entertained by BHEL at contract stage if any separate item is insisted by POWERGRID to meet the contract requirement.

The equipment is required for the following project:

Name of the customer : **POWERGRID FATEHGARH TRANSMISSION LIMITED- A 100% wholly owned subsidiary of Power Grid Corporation of India Limited**

Name of the project : **Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route**

Site : **Bhadla-II, Rajasthan & Fatehgarh-II, Rajasthan**



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

***Note: The terms used in this specification namely, “Employer” refers to PowerGrid , “POWERGRID” refers to BHEL/POWERGRID, “Contractor” refers to Bidder, “GTR” refers to “section-3”.**

In case of any conflict among the various sections of this specification, the order of precedence shall be section 1, section 2 & the section 3.

1.2 Bill of Quantities

1.2.1 Main Supply:

S. No.	Item Description	Unit	Quantity	
			Fatehgarh II	Bhadla II
1	SUPPLY- PLCC : COUPLING DEVICE PHASE TO PHASE (2LMU WITH 1BT)	No	2	2
2	SUPPLY- PLCC : POWER LINE CARRIER TERMINAL SINGLE CHANNEL ANALOGUE TYPE FOR SPEECH + PROTECTION AND SPEECH +DATA	No	2	2
3	SUPPLY- PLCC : ANALOG PROTECTION COUPLER 4 COMMAND	No	2	2
4	SUPPLY- PLCC : DIGITAL PROTECTION COUPLER 4 COMMAND (refer note 1)	No	2	2
5	SUPPLY- PLCC : 4 WIRE EXPRESS TELEPHONE INSTRUMENT ALONGWITH ASSOCIATED ACCESSORIES, WIRING ETC	No	1	1
6	SUPPLY- PLCC : HF CABLE 75OHMS UNBALANCED	km	0.5	0.5
7	SUPPLY- PLCC : TESTING & MAINTENANCE EQUIPMENT (PRINT TEST KIT)	No	1	1
8	SERVICES- PLCC : SYSTEM	LOT	1	1



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

	ENGINEERING INCLUDING COMPUTER STUDY , FREQ. PLANNING AND SNR CALCULATIONS			
9	SERVICES- PLCC : SUPERVISION OF PRE-COMMISSIONING (PANEL WISE)	No	4	4
10	SERVICES- PLCC : SUPERVISION OF TESTING AND COMMISSIONING (LINK WISE)	No	2	2

Notes –

1. Digital Protection Coupler shall be Suitable for interfacing with E1 port of SDH equipment.
2. Quantity Variation: Total PO value may vary by $\pm 30\%$, however individual items can vary to any extent

1.3 Specific Technical Requirements

1.3.1 Refer Section – 2 for specific technical requirements.

1.3.2 Technical Pre-Qualifying Requirements for analog and digital PLCC panels (765kV)

- (i) The manufacturer whose PLCC panels are offered, must have designed, manufactured, tested, supplied and commissioned PLCC panels for 400kV system or above [applicable for 765 kV & 400 kV substation] and the same must have been in satisfactory operation# for atleast two (2) years as on the date of NOA.
- (ii) Alternatively, the manufacturer, who have established manufacturing and testing facilities in India and not meeting the requirement stipulated in (i) above, can also be considered provided that
 - a) PLCC panels must have been manufactured in the above Indian works based on technological support of collaborator, type tested (as per IEC/IS standard) and supplied as on the date of NOA.
 - b) collaborator shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s) and this performance guarantee shall be in addition to contract performance guarantee to be submitted by the contractor.



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV
Bhadla-2 (PG) S/s Extension under Transmission System
Associated With LTA applications from Rajasthan SEZ
Part-B (Rajasthan SEZ Part-B Project) through Tariff
Based Competitive Bidding (TBCB) Route.
PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

c) The collaborator meets the requirements stipulated in (i) above. A valid collaboration agreement for technology transfer/license to design, manufacture, test and supply PLCC panels in India, shall be submitted.

Notes:

#: satisfactory operation means certificate issued by the Employer/Utility certifying the operation without any adverse remark.

Date of NOA is 05 Nov 2019.

1.3.3 Type Tests

- i. All equipment being supplied shall conform to type tests as per technical specification and shall be subject to routine tests in accordance with requirements stipulated under respective sections.
- ii. The reports for all type tests as per technical specification shall be furnished by the Bidder along with equipment / material drawings. However, type test reports of similar equipments/ material already accepted in POWERGRID shall be applicable for all projects with similar requirement. The type tests conducted earlier should have either been conducted in accredited laboratory (accredited based on ISO / IEC Guide 25 / 17025 or EN 45001 by the national accreditation body of the country where laboratory is located) or witnessed by POWERGRID or representative authorized by POWERGRID or Utility or representative of accredited test lab.

Unless otherwise specified elsewhere, the type test reports submitted shall be of the tests conducted on or after 05-Nov-2009. In case the test reports are of the test conducted earlier than 05-Nov-2009, the bidder shall repeat these test(s) at no extra cost to the BHEL/Employer.

Further, in the event of any discrepancy in the test reports i.e. any test report not acceptable due to any design/manufacturing changes or due to non-compliance with the requirement stipulated in the Technical Specification or any/all type tests not carried out, same shall be carried out without any additional cost implication to the BHEL/Employer.

The Bidder shall intimate the Employer/BHEL the detailed program about the type tests atleast two (2) weeks in advance in case of domestic supplies & six (6) weeks in advance in case of foreign supplies.

- iii. The Employer reserves the right to witness any or all the type tests. The Employer shall bear all expenses for deputation of Employer's representative(s) for witnessing the type tests.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

- iv. The list of makes of various items, for which Type test reports are not required to be submitted are specified in Compendium of Vendors (COV).

1.3.4 Supervision of Commissioning & Site Testing

Supervision of commissioning & site testing of the equipment's are under present scope of work. The respective dates of commencement of erection, testing and commissioning activities by BHEL will be intimated to the equipment supplier from time to time, so that arrangements for supervising the activity can be made accordingly by the manufacturer.

1.3.5 Drawings & Engineering Documents

The successful bidder shall have to extend all possible supports like timely submission/resubmission of drawings, visit to end customer to facilitate documents approval without any commercial implications to BHEL. Acceptance of bidder's documents shall be subject to end customer approval.

Date of Submission of first lot of drawings will be counted only from the date of submission of reasonably correct drawings. List of drawings required for technical clearance of manufacturing are as follows:

1. Approved GTP
2. Approved GA/Drawings/BOM.
3. Approved Type Test Reports.

1.3.6 Special Tools and Tackles

The bidder shall include in his proposal the deployment of all special tools and tackles required for erection, testing, commissioning and maintenance of the equipment. The Special tools and tackles shall only cover items which are specifically required for the equipment offered and are proprietary in nature. A list of all such devices shall be furnished by the bidder.

1.3.7 Quality Plan

Bidder should have POWERGRID approved and valid SMQP by the date of technical bid opening.



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

1.3.8 Deviations

The bidder shall list all the deviation from the specification separately. Offers without specific deviation will be deemed to be totally in compliance with the specification and NO DEVIATION on any account will be entertained at a later date.



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

SECTION-2

Refer document

**Tech Specification, Section : PLCC C/ENGG/SPEC/ PLCC REV NO:05 (23 Sheets) + 4 Sheets
DPC Annexure II.**



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

SECTION-3

Refer document



General Technical Requirements: TB-409-316-000 Rev 00.



BHARAT HEAVY ELECTRICALS LIMITED
TRANSMISSION BUSINESS HVDC & SYSTEMS

COPYRIGHT AND CONFIDENTIALITY

The information on this document is the property of BHARAT HEAVY ELECTRICALS LTD.
It must not be used directly or indirectly in anyway detrimental to the interest of the company

DOCUMENT No.	TB-409-316-000	Rev. No.	00	Prepared	Checked	Approved		
TYPE OF DOC.	TECHNICAL SPECIFICATION			SIGN	  			
GENERAL TECHNICAL REQUIREMENTS-SECTION 3				NAME	NS	SKS	AG	
				DATE	18.12.19	18.12.19	18.12.19	
				GROUP	HVDC	W.O. No	Awaited	
CUSTOMER	Powergrid Corporation of India Ltd. (POWERGRID)							
PROJECT	Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route							
NOA NO.	FTL/765kV/SS02/NOAI/2(I) For Supply of Goods Contract Dated 05-11-19 & FTL/765kV/SS02/NOAII/2(II) For Supply of Service Contract Dated 05-11-2019							
Station	Fatehgarh-2, Rajasthan and Bhadla-2, Rajasthan							
S.No.	Description					Sheet		
1	General Technical Requirements – Site Information					1		
2	General Technical Requirements					2-30		
3	Annexure -A					2 Sheets		
4	Annexure -B					1 Sheets		
5	Annexure -C					23 Sheets		
6	Annexure -G					3 Sheets		
Rev No.	Date	Altered	Checked	Approved	REVISION DETAILS			
Distribution				To	HVDC	TBMM	TBQM	Supplier
				Copies	1	1	1	4



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

GENERAL TECHNICAL REQUIREMENTS-SECTION 3

Site Information

S.No.	Particular	Details
a)	Owner	Fatehgarh-II Transco Limited- a 100% wholly owned subsidiary of Power Grid Corporation of India Limited
b)	Customer	Fatehgarh-II Transco Limited- a 100% wholly owned subsidiary of Power Grid Corporation of India Limited
c)	Project Title	Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
d)	Location	Fatehgarh-2, Rajasthan Bhadla-2, Rajasthan
e)	Transport Facilities	Road/Train Nearest Rail Head For Fatehgarh-2: Fatehgarh Nearest Rail Head For Bhadla-2: Nokha
SITE CONDITIONS		
a)	Max. ambient air temp.	50°C
b)	Min. ambient air temp.	0°C
c)	Max. design ambient temp.	50°C
d)	Design reference temp.	50°C
e)	Average Humidity	Max. 100%
f)	Special corrosion conditions	No
g)	Solar Radiation	1.2kW/sqmtr
h)	Atmospheric UV radiation	High
i)	Altitude above sea level	Less than 1000 meter above mean sea level (MSL)
j)	Pollution Severity	High Pollution level
k)	Seismic Zone	As per IS 1893 but not less than 0.3g horizontal
WIND DATA		
	Wind velocity	As per IS-875
	Average No. of thunderstorm days per annum	As per IS
Main Electrical Parameters:		
	Fault Levels:	765kV: 40kA for 1 sec
	Creepage Distance	25mm/kV for All Equipment i.e BPI/Bushings, CB, Isolator, CT, CVT, LA, WT, NCT etc. 31mm/kV for string insulators



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

GENERAL TECHNICAL REQUIREMENTS-SECTION 3

INDEX

Clause No.	Item	Page No.
1.0	Foreword	4
2.0	General Requirement	4
3.0	Standards	5
4.0	Services to be performed by the Equipment being furnished	6
5.0	Engineering Data and Drawings	7
6.0	Material/Workmanship	10
7.0	Design Improvements/Coordination	12
8.0	Quality Assurance Programme	13
9.0	Type Testing & Clearance Certificates	19
10.0	Deleted.	20
11.0	Packaging & Protection	20
12.0	Finishing of Metal Surfaces	20
13.0	Deleted	22
14.0	Tools	22
15.0	Auxiliary Supply	23
16.0	Support Structure	23
17.0	Clamps and Connectors including Terminal Connectors	23
18.0	Control Cabinets, Junction Boxes, Terminal Boxes & Marshalling Boxes for Outdoor Equipment	25
19.0	Deleted	26
20.0	Terminal Blocks and Wiring	26
21.0	Lamps and Sockets	27
22.0	Bushings, Hollow Column Insulators, Support Insulators	28
23.0	Motors	29
Annexure-A	Corona and Radio Interference Voltage (RIV) Test	2 sheets
Annexure-B	Seismic Withstand Test Procedure	1 sheet
Annexure-C	List of General Standards and Codes	23 sheets
Annexure-G	MQP & Inspection Level Requirement	3 sheets



GENERAL TECHNICAL REQUIREMENTS-SECTION 3

1.0 FOREWORD

The provisions under this section are intended to supplement requirements for the materials, equipments and services covered under other sections of tender documents and are not exclusive.

The Supplier shall note that the standards mentioned herein are not mutually exclusive or complete in themselves, but are intended to complement each other, with minimum repetition, to define the requirements of the Specification. In the event of a conflict between requirements of any two clauses of the Specification/ documents or requirements of different codes/ standards specified, the more stringent requirement as per the interpretation of the owner shall apply, unless confirmed otherwise by the owner in writing based on a written request from the Supplier.

In case of conflicting requirements between this document (General Technical Requirement Section 3) and equipment specification (Section 1 & Section 2), equipment specification shall prevail.

When specific requirements stipulated in the Specification exceed or change those required by the applicable standards, the stipulations of the Specification shall take precedence.

Unless specifically agreed to by the Purchaser prior to Award of Contract, the Work shall be in accordance with the standards indicated and the requirements of the Specification. The Supplier shall be held responsible for any deviation.

In case of conflict between the various standards, the decision of owner shall be binding & final.

2.0 GENERAL REQUIREMENT

The following words and expressions shall have the meanings hereby assigned to them throughout this document

"Employer/Owner" means Power Grid Corporation of India Ltd.

"Purchaser" means Bharat Heavy Electricals Limited

"Supplier/Manufacturer/Bidder" means the person or persons, firm or company assigned to execute the works as defined by the scope of supply, described here.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

"Specification" refers to this document.

The supplier should be approved by Power Grid. If not, it is the responsibility of the vendor to be assessed and approved by Power Grid, before placement of order by BHEL. Any cost involved in vendor assessment/approval must be borne by the vendor himself.

- 2.1 The Supplier/Manufacturer shall furnish catalogues, engineering data, technical information, design documents, drawings etc., fully in conformity with the technical specification during detailed engineering.
- 2.2 It is recognised that the Bidder may have standardised on the use of certain components, materials, processes or procedures different from those specified herein. Alternate proposals offering similar equipment based on the manufacturer's standard practice will also be considered provided such proposals meet the specified designs, standard and performance requirements and are acceptable to Employer.
- 2.3 Wherever a material or article is specified or defined by the name of a particular brand, Manufacturer or Vendor, the specific name mentioned shall be understood as establishing type, function and quality and not as limiting competition.
- 2.4 Equipment furnished shall be complete in every respect with all mountings, fittings, fixtures and standard accessories normally provided with such equipment and/or needed for erection, completion and safe operation of the equipment as required by applicable codes though they may not have been specifically detailed in the Technical Specifications unless included in the list of exclusions. Materials and components which are minor in nature and incidental to the requirement but not specifically stated in the specification, which are necessary for commissioning and satisfactory operation of the switchyard/ substation unless specifically excluded shall be deemed to be included in the scope of the specification and shall be supplied without any extra cost. All similar standard components/parts of similar standard equipment provided, shall be inter-changeable with one another.
- 2.5 Deleted.
- 2.6 Deleted.

3.0 STANDARDS

- 3.1 The works covered by the specification shall be designed, engineered, manufactured, built, tested and commissioned in accordance with the Acts, Rules, Laws and Regulations of India.
- 3.2 The equipment to be furnished under this specification shall conform to latest issue with all amendments (as on the originally scheduled date of bid opening) of standard specified under Annexure-C of this section, unless specifically mentioned in the specification.
- 3.3 The Bidder shall note that standards mentioned in the specification are not mutually exclusive or complete in themselves, but intended to compliment each other.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 3.4 The Bidder shall also note that list of standards presented in this specification is not complete. Whenever necessary the list of standards shall be considered in conjunction with specific IS/IEC.
- 3.5 When the specific requirements stipulated in the specifications exceed or differ than those required by the applicable standards, the stipulation of the specification shall take precedence.
- 3.6 Other internationally accepted standards which ensure equivalent or better performance than that specified in the standards specified under Annexure-C/individual sections for various equipments shall also, be accepted, however the salient points of difference shall be clearly brought out during detailed engineering along with English language version of such standard. The equipment conforming to standards other than specified under Annexure-C/ individual sections for various equipments shall be subject to Employer's approval.

4.0 SERVICES TO BE PERFORMED BY THE EQUIPMENT BEING FURNISHED

- 4.1 The 800kV system is being designed to limit the switching surge over voltage of 1.9 p.u. and the power frequency over voltage of 1.4 p.u. The equipment furnished under this specification shall perform all its functions and operate satisfactorily without showing undue strain, restrike etc under such over voltage conditions.
- 4.2 All equipments shall also perform satisfactorily under various other electrical, electromechanical and meteorological conditions of the site of installation.
- 4.3 All equipment shall be able to withstand all external and internal mechanical, thermal and electromechanical forces due to various factors like wind load, temperature variation, ice & snow, (wherever applicable) short circuit etc for the equipment.
- 4.4 The bidder shall design terminal connectors of the equipment taking into account various forces that are required to withstand.
- 4.5 The equipment shall also comply to the following:
- a) To facilitate erection of equipment, all items to be assembled at site shall be "match marked".
- b) All piping, if any between equipment control cabinet/operating mechanism to marshalling box of the equipment, shall bear proper identification to facilitate the connection at site.

4.6 System Parameter

765kV, 400kV & 220kV System

SL No	Description of parameters	765kV System
1.	System operating voltage	765kV
2.	Maximum operating voltage of the system (rms)	800kV
3.	Rated frequency	50HZ
4.	No. of phase	3
5.	Rated Insulation levels	
i)	Full wave impulse withstand voltage (1.2/50	2100kVp



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

	microsec.)	
ii)	Switching impulse withstand voltage (250/2500 micro sec.) dry and wet	1550kVp
iii)	One minute power frequency dry withstand voltage (rms)	830kV
SL No	Description of parameters	765kV System
iv)	One minute power frequency dry and wet withstand voltage (rms)	-
6.	Corona extinction voltage	508 kV
7.	Max. radio interference voltage for frequency between 0.5 MHz and 2 MHz	2500 μ V at 508 kV rms
8.	Minimum creepage distance - for Equipment other than Insulator string	20000 mm
	Minimum creepage distance - for Insulator String	24800 mm
9	Min. clearances	
i.	Phase to phase	7600mm (for conductor conductor configuration) 9400mm (for rod-conductor configuration)
ii.	Phase to earth	4900mm (for conductor structure) 6400mm (for rod- structure)
iii.	Sectional clearances	10300 mm
10.	Rated short circuit current for 1 sec. duration	40kA
11.	System neutral earthing	Effectively earthed

Notes:

1. The above parameters are applicable for installations up to an altitude of 1000m above mean sea level. For altitude exceeding 1000m, necessary altitude correction factor shall be applicable as per relevant IEC.
2. The insulation and RIV levels of the equipments shall be as per values given in the Technical Specification of respective equipment.
3. Corona and radio interference voltage test and seismic withstand test procedures for equipments shall be in line with the procedure given at **Annexure-A** and **Annexure-B** respectively.

5.0 ENGINEERING DATA AND DRAWINGS

5.1 Deleted.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 5.2 The Bidder shall submit 4 (four) sets of drawings/ design documents /data / detailed bill of quantity and 1 (one) set of test reports for the approval of the Employer. The bidder shall also submit the softcopy of the above documents in addition to hardcopy.

5.3 Drawings

- 5.3.1 All drawings submitted by the Bidder shall be in sufficient detail to indicate the type, size, arrangement, material description, Bill of Materials, weight of each component, break-up for packing and shipment, dimensions, internal & the external connections, fixing arrangement required and any other information specifically requested in the specifications.
- 5.3.2 Drawings submitted by the Bidder shall be clearly marked with the name of the Employer, the unit designation, the specifications title, the specification number and the name of the Project. POWERGRID has standardized a large number of drawings/documents of various make including type test reports which can be used for all projects having similar requirements and in such cases no project specific approval (except for list of applicable drawings along with type test reports) is required. However, distribution copies of standard drawings/documents shall be submitted as per provision of the contract. All titles, noting, markings and writings on the drawing shall be in English. All the dimensions should be in SI units.
- 5.3.3 The review of these data by the Employer will cover only general conformance of the data to the specifications and documents, interfaces with the equipment provided under the specifications, external connections and of the dimensions which might affect substation layout. This review by the Employer may not indicate a thorough review of all dimensions, quantities and details of the equipment, materials, any devices or items indicated or the accuracy of the information submitted. This review and/or approval by the Employer shall not be considered by the Bidder, as limiting any of his responsibilities and liabilities for mistakes and deviations from the requirements, specified under these specifications and documents.
- 5.5 All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawings shall be at the Bidder's risk. The Bidder may make any changes in the design which are necessary to make the equipment conform to the provisions and intent of the Contract and such changes will again be subject to approval by the Employer. Approval of Bidder's drawing or work by the Employer shall not relieve the bidder of any of his responsibilities and liabilities under the Contract.
- 5.6 All engineering data submitted by the Bidder after final process including review and approval by the Employer shall form part of the Contract Document and the entire works performed under these specifications shall be performed in strict conformity, unless otherwise expressly requested by the Employer in Writing.

5.7 Approval Procedure

The following schedule shall be followed generally for approval and for providing final documentation.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

i) Approval/comments/ by Employer on initial submission	As per schedule
ii) Resubmission (whenever required)	As per contract
iii) Approval or comments	As per contract
iv) Furnishing of distribution copies (2 hard copies to each substation and one scanned copy (pdf format)	2 weeks from the date of approval
v) Furnishing of distribution copies of test reports (a) Type test reports (one scanned softcopy in pdf format to each substation plus one for corporate centre & one hardcopy per substation)	2 weeks from the date of final approval
(b) Routine Test Reports (one copy for each substation)	-do-
vi) Furnishing of instruction/ operation manuals (2 copies per substation and one softcopy (pdf format) for corporate centre & per substation)	On completion of Engineering
(vii) As built drawings (two sets of hardcopy per substation & one softcopy (pdf format) for corporate centre & per substation)	On completion of entire works

NOTE :

(1) The bidder may please note that all resubmissions must incorporate all comments given in the earlier submission by the Employer or adequate justification for not incorporating the same must be submitted failing which the submission of documents is likely to be returned.

(2) All drawings should be submitted in softcopy form, however substation design drawings like SLD, GA, all layouts etc. shall also be submitted in AutoCAD Version. SLD, GA & layout drawings shall be submitted for the entire substation in case of substation extension also.

(3) The instruction Manuals shall contain full details of drawings of all equipment being supplied under this contract, their exploded diagrams with complete instructions for storage, handling,



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

erection, commissioning, testing, operation, trouble shooting, servicing and overhauling procedures.

(4) If after the commissioning and initial operation of the substation, the instruction manuals require any modifications/additions/changes, the same shall be incorporated and the updated final instruction manuals shall be submitted by the Bidder to the Employer.

(5) The Bidder shall furnish to the Employer catalogues of spare parts.

(6) All As-built drawings/documents shall be certified by site indicating the changes before final submission.

6.0 MATERIAL/ WORKMANSHIP

6.1 General Requirement

- 6.1.1 Where the specification does not contain references to workmanship, equipment, materials and components of the covered equipment, it is essential that the same must be new, of highest grade of the best quality of their kind, conforming to best engineering practice and suitable for the purpose for which they are intended.
- 6.1.2 In case where the equipment, materials or components are indicated in the specification as "similar" to any special standard, the Employer shall decide upon the question of similarity. When required by the specification or when required by the Employer the Bidder shall submit, for approval, all the information concerning the materials or components to be used in manufacture. Machinery, equipment, materials and components supplied, installed or used without such approval shall run the risk of subsequent rejection, it is to be understood that the cost as well as the time delay associated with the rejection shall be borne by the Bidder.
- 6.1.3 The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be designed to be consistent with its duty and suitable factors of safety, subject to mutual agreements. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfil their required function. In general, screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from the Employer.
- 6.1.4 Whenever possible, all similar part of the Works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall also be interchangeable and shall be made of the same materials and workmanship as the corresponding parts of the Equipment supplied under the Specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.
- 6.1.5 Deleted.
- 6.1.6 The Bidder shall apply oil and grease of the proper specification to suit the machinery, as is necessary for the installation of the equipment. Lubricants used for installation purposes shall be



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

drained out and the system flushed through where necessary for applying the lubricant required for operation. The Bidder shall apply all operational lubricants to the equipment installed by him.

- 6.1.7 All oil, grease and other consumables used in the Works/Equipment shall be purchased in India unless the Bidder has any special requirement for the specific application of a type of oil or grease not available in India. If such is the case, he shall declare in the proposal, where such oil or grease is available. He shall help Employer in establishing equivalent Indian make and Indian Bidder. The same shall be applicable to other consumables too.

6.2 Provisions For Exposure to Hot and Humid climate

Outdoor equipment supplied under the specification shall be suitable for service and storage under tropical conditions of high temperature, high humidity, heavy rainfall and environment favourable to the growth of fungi and mildew. The indoor equipments located in non-air conditioned areas shall also be of same type.

6.2.1 Space Heaters

- 6.2.1.1 The heaters shall be suitable for continuous operation at 240V as supply voltage. On-off switch and fuse shall be provided.
- 6.2.1.2 One or more adequately rated thermostatically connected heaters shall be supplied to prevent condensation in any compartment. The heaters shall be installed in the compartment and electrical connections shall be made sufficiently away from below the heaters to minimize deterioration of supply wire insulation. The heaters shall be suitable to maintain the compartment temperature to prevent condensation.

6.2.2 FUNGI STATIC VARNISH

Besides the space heaters, special moisture and fungus resistant varnish shall be applied on parts which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interfere with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application of the varnish.

6.2.3 Ventilation opening

Wherever ventilation is provided, the compartments shall have ventilation openings with fine wire mesh of brass to prevent the entry of insects and to reduce to a minimum the entry of dirt and dust.

6.2.4 Degree of Protection

The enclosures of the Control Cabinets, Junction boxes and Marshalling Boxes, panels etc. to be installed shall comply with following degree of protection as detailed here under:

- a) Installed out door: IP- 55
- b) Installed indoor in air conditioned area: IP-31
- c) Installed in covered area: IP-52



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

d) Installed indoor in non-air conditioned area where possibility of entry of water is limited: IP-41.

e) For LT Switchgear (AC & DC distribution Boards): IP-52

The degree of protection shall be in accordance with IS:13947 (Part-I)/IEC-60947 (Part-I)/IS 12063/IEC-60529. Type test report for IP-55 or higher degree of protection test, shall be submitted for approval.

6.3 RATING PLATES, NAME PLATES AND LABELS

6.3.1 Each main and auxiliary item of substation is to have permanently attached to it in a conspicuous position a rating plate of non-corrosive material upon which is to be engraved manufacturer's name, year of manufacture, equipment name, type or serial number together with details of the loading conditions under which the item of substation in question has been designed to operate, and such diagram plates as may be required by the Employer. The rating plate of each equipment shall be according to IEC requirement.

6.3.2 All such nameplates, instruction plates, rating plates of transformers, reactors, CB, CT, CVT, SA, Isolators, C & R panels and PLCC equipments shall be bilingual with Hindi inscription first followed by English. Alternatively two separate plates one with Hindi and the other with English inscriptions may be provided.

6.4 FIRST FILL OF CONSUMABLES, OIL AND LUBRICANTS

All the first fill of consumables such as oils, lubricants, filling compounds, touch up paints, soldering/brazing material for all copper piping of circuit breakers and essential chemicals etc. which will be required to put the equipment covered under the scope of the specifications, into operation, shall be furnished by the Bidder unless specifically excluded under the exclusions in these specifications and documents.

7.0 DESIGN IMPROVEMENTS / COORDINATION

7.1 Deleted.

7.2 Deleted.

7.3 The Bidder shall be responsible for the selection and design of appropriate equipments to provide the best co-ordinated performance of the entire system. The basic design requirements are detailed out in this Specification. The design of various components, sub-assemblies and assemblies shall be so done that it facilitates easy field assembly and maintenance.

7.4 The Bidder has to coordinate designs and terminations with the agencies (if any) who are Consultants/Bidder for the Employer. The names of agencies shall be intimated to the successful bidders.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 7.5 The Bidder will be called upon to attend design co-ordination meetings with the Engineer, other Bidder's and the Consultants of the Employer (if any) during the period of Contract. The Bidder shall attend such meetings at his own cost at POWERGRID Corporate Centre, Gurgaon (Haryana) or at mutually agreed venue as and when required and fully cooperate with such persons and agencies involved during those discussions.

8.0 QUALITY ASSURANCE PROGRAMME

- 8.1 To ensure that the equipment and services under the scope of this Contract, whether manufactured or performed within the Bidder's Works or at his Sub-Bidder's premises or at the Employer's site or at any other place of Work as applicable, are in accordance with the specifications, the Bidder shall ensure suitable quality assurance programme to control such activities at all points necessary. A quality assurance programme of the Bidder shall be in line with ISO requirements & shall generally cover the following:

- a) The organisation structure for the management and implementation of the proposed quality assurance programme.
- b) System for Document and Data Control.
- c) Qualification and Experience data of Bidder's key personnel.
- d) The procedure for purchases of materials, parts, components and selection of sub- Bidder's services including vendor analysis, source inspection, incoming raw material inspection, verification of material purchases etc.
- e) System for shop manufacturing and site erection controls including process controls, fabrication and assembly control.
- f) System for Control of non-conforming products including deviation dispositioning, if any and system for corrective and preventive actions based on the feedback received from the Customers and also internally documented system for Customer complaints.
- g) Inspection and test procedure both for manufacture and field activities.
- h) System for Control of calibration of testing and measuring equipment and the indication of calibration status on the instruments.
- i) System for indication and appraisal of inspection status.
- j) System of Internal Quality Audits, Management review and initiation of corrective and Preventive actions based on the above.
- k) System for authorising release of manufactured product to the Employer.
- l) System for maintenance of records.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

m) System for handling, storage and delivery.

n) A quality plan detailing out the specific quality control measures and procedure adopted for controlling the quality characteristics relevant to each item of equipment furnished and /or service rendered.

o) System for various field activities i.e. unloading, receipt at site, proper storage, erection, testing and commissioning of various equipment and maintenance of records. In this regard, the Employer has already prepared Standard Field Quality Plan for transmission line/substation equipments as applicable, Civil/erection Works which is required to be followed for associated works.

The Employer or his duly authorised representative reserves the right to carry out quality audit and quality surveillance of the system and procedure of the Bidder/his vendor's quality management and control activities.

8.2 Quality Assurance Documents

The Bidder shall ensure availability of the following Quality Assurance Documents:

i) All Non-Destructive Examination procedures, stress relief and weld repair procedure actually used during fabrication, and reports including radiography interpretation reports.

ii) Welder and welding operator qualification certificates.

iii) Welder's identification list, welding operator's qualification procedure and welding identification symbols.

iv) Raw Material test reports on components as specified by the specification and in the quality plan.

v) The Manufacturing Quality Plan (MQP) indicating Customer Inspection Points (CIPs) at various stages of manufacturing and methods used to verify that the inspection and testing points in the quality plan were performed satisfactorily.

vi) Factory test results for testing required as per applicable quality plan/technical specifications/GTP/Drawings etc.

vii) Stress relief time temperature charts/oil impregnation time temperature charts, wherever applicable.

8.3 INSPECTION, TESTING & INSPECTION CERTIFICATE

8.3.1 Bidder shall procure bought out items from sub-vendors as per the list in "Compendium of Vendors" available on POWERGRID web-site www.powergridindia.com after ensuring compliance to the requirements/conditions mentioned therein. Bidder shall explore first the possibilities of procuring the bought out items from POWERGRID approved existing vendors. In case of their



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

unavailability / non-response, Bidder may approach POWERGRID for additional sub-vendor approval. In that case, the assessment report of proposed sub vendor by Bidder along with the enclosures as per Annexure-F shall be submitted within 60 days of the award. The proposal shall be reviewed and approval will be accorded based on the verification of the document submitted and/or after the physical assessment of the works as the case may be. The physical assessment conducted by POWERGRID, if required, shall be on chargeable basis. Charges shall be as per the POWERGRID norms prevailing at that time, which shall be intimated by POWERGRID separately. If proposal for sub-vendor is submitted after 60 days, the Bidder's proposal normally will not be considered for current LOA. However, POWERGRID may process the case for developing more vendors for referred items, if found relevant. In all cases, It is the responsibility of the Bidder that Project activities do not suffer on account of delay in approval/non approval of a new sub-vendor.

The responsibility and the basis of inspection for various items & equipment is placed at Annexure-G along with the requirement of MQP (Manufacturing Quality Plan), ITP(Inspection & Test Plan), FAT(Factory Acceptance Test) which should be valid & POWERGRID approved and Level of inspection envisaged against each item.

Bidder shall ensure that order for items where MQP/ITP/FAT is required will be placed only on vendors having valid MQP/ITP/FAT and where the supplier's MQP/ITP/FAT is either not valid or has not been approved by POWERGRID, MQP shall be generally submitted as per POWERGRID format before placing order.

Items not covered under MQP/ITP/FAT shall be offered for inspection as per POWERGRID LOA/technical Specifications/POWERGRID approved data sheets/POWERGRID approved drawings and relevant Indian/International standards. Inspection Levels: For implementation of projects in a time bound manner and to avoid any delay in deputation of POWERGRID or its authorized representative, involvement of POWERGRID for inspection of various items / equipment will be based on the level below:

Level –I: Bidder to raise all inspection calls and review the report of tests carried out by the manufacturer, on his own, as per applicable standards/ POWERGRID specification, and submit to concerned POWERGRID inspection office/Inspection Engineer. CIP/MICC will be issued by POWERGRID based on review of test reports/certificates of manufacturers.

Level – II: Bidder to raise all inspection calls and carry out the inspection on behalf of POWERGRID on the proposed date of inspection as per applicable standards/specification. However, in case POWERGRID wishes to associate itself during inspection, the same would be intimated to Bidder and CIP/MICC will be issued by POWERGRID. Else, Bidder would submit their test reports/certificates to POWERGRID. CIP/MICC will be issued by POWERGRID based on review of test reports/certificates.

Level - III: Bidder to raise inspection calls for both, stage (as applicable) & final inspection and carry out the stage inspections (if applicable) on behalf of POWERGRID on the proposed date of inspection as per applicable standards/specification. However, in case POWERGRID wishes to associate itself during stage inspection, the same would be intimated to Bidder and CIP will be issued by POWERGRID. Else, Bidder would submit the test reports / certificates of stage inspection after their own review and CIP will be issued by POWERGRID based on review of test



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

reports / certificates. Final inspection will be carried out by POWERGRID and CIP/MICC will be issued by POWERGRID.

Level – IV: Bidder to raise inspection calls for both, stage (as applicable) & final inspections. POWERGRID will carry out the inspection for both stage & final inspection as per applicable standards/specification and CIP/MICC will be issued by POWERGRID.

- 8.3.2 Bidder shall ensure that to implement the above inspection levels, particularly for the quality control and inspection at sub-vendor's works, they would depute sufficient qualified & experienced manpower in their Quality Control and Inspection department. Further, to assure quality of construction, Bidder shall have a separate workforce having appropriate qualification & experience and deploy suitable tools and plant for maintaining quality requirement during construction in line with applicable Field Quality Plan (FQP).
- 8.3.3 The Employer, his duly authorised representative and/or outside inspection agency acting on behalf of the Employer shall have at all reasonable times access to the Bidder's premises or Works and shall have the power at all reasonable times to ensure that proper Quality Management practices / norms are adhered to, inspect and examine the materials & workmanship of the Works, to carry out Quality/Surveillance Audit during manufacture or erection and if part of the Works is being manufactured or assembled at other premises or works. The Bidder shall obtain for the Employer and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Bidder's own premises or works. The item/equipment, if found unsatisfactory with respect to workmanship or material is liable to be rejected. The observations for improvements during product/ process inspection by POWERGRID shall be recorded in Quality Improvement Register (available & maintained at works) for review & timely compliance of observations.
- 8.3.4 Bidder shall submit inspection calls over internet through POWERGRID website. The required vendor code and password to enable raising inspection call will be furnished to the main Bidder within 30 days of award of contract on submission of documents by Bidder. After raising the inspection calls, Bidder shall then proceed as per the message of that particular call which is available on the message board.
- 8.3.5 The Employer reserves the right to witness any or all type, acceptance and routine tests specified for which the Bidder shall give the Employer/Inspector Twenty one (21) days written notice of any material being ready for testing for each stage of testing as identified in the approved quality plan as customer inspection point(CIP) for indigenous inspections. All inspection calls for overseas material shall be given at least forty five (45) days in advance. Such tests shall be to the Bidder's account except for the expenses of the Inspection Engineer. The Employer/inspector, unless witnessing of the tests is waived by Employer, will attend such tests within Twenty one (21) days of the date of which the equipment is notified as being ready for test/inspection, failing which the Bidder may proceed with the test which shall be deemed to have been made in the Inspector's presence and he shall forthwith forward to the Inspector three copies of tests, duly certified. Bidder shall ensure, before giving notice for type test, that all drawings and quality plans have been got approved. The equipment shall be dispatched to site only after approval of Routine and Acceptance test results and Issuance of Dispatch Clearance in writing by the Employer. CIP/Material Inspection clearance certificate (MICC) shall be issued by the Employer after inspection of the equipment or review of test reports as applicable. Employer may waive off the



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

presence of Employer's inspecting engineer. In that case test will be carried out as per approved QP and test certificate will be furnished by the supplier for approval. CIP/MICC will be issued only after review and approval of the test reports.

- 8.3.6 Bidder shall generally offer material for inspection as per supply bar chart approved by POWERGRID and not before 30 days from schedule indicated in the bar chart. In case Bidder offers material(s) for inspection prior to 30 days from the scheduled date with necessary approval of POWERGRID, POWERGRID shall inspect the material and issue CIP only. However, in such an exceptional case, MICC shall be issued only as per provision of original / revised approved supply schedule.
- 8.3.7 Bidder shall minimize the number of inspection calls by offering optimum quantities in each inspection call at the respective manufacturer's works.
- 8.3.8 Bidder shall inspect the material themselves and only after they are fully convinced about the Quality, they shall offer the material for POWERGRID inspection and shall also ensure that relevant portion of LOA/NOA, approved drawing and data sheets along with applicable Quality Plans are available at the works of Bidder or their Sub-vendor before the material is offered for inspection.
- 8.3.9 Bidder shall ensure that material which has been cleared for dispatch after inspection will be dispatched within 30 days in case of domestic supplies and within 60 days in case of Off-shore supplies from the date of issuance of CIP. Material which is not dispatched within stipulated time as above will be reoffered for POWERGRID inspection or specific approval of POWERGRID QA&I shall be obtained for delayed dispatch.
- 8.3.10 The Employer or IE shall give notice in writing to the Bidder, of any objection either to conformance to any drawings or to any equipment and workmanship which in his opinion is not in accordance with the Contract. The Bidder shall give due consideration to such objections and shall either make the modifications that may be necessary to meet the said objections or shall confirm in writing to the Employer/Inspection Engineer giving reasons therein, that no modifications are necessary to comply with the Contract.
- 8.3.11 All Test Reports and documents to be submitted in English during final inspection of equipment by POWERGRID or as and when required for submission.
- 8.3.12 When the factory tests have been completed at the Bidder's or Sub-Bidder's works, the Employer/Inspection Engineer (IE) shall issue a certificate to this effect within fifteen (15) days after completion of tests & submission of documents by Bidder/manufacturer but if the tests are not witnessed by the Employer/IE, the certificate shall be issued within fifteen (15) days of receipt of the Bidder's Test certificate by the Employer/IE. Bidder shall, on completion of all tests, submit test reports within Ten (10) days to POWERGRID IE. Failure of the Employer/IE to issue such a certificate shall not prevent the Bidder from proceeding with the Works. The completion of these tests or the issue of the certificate shall not bind the Employer to accept the equipment should, it, on further tests after erection, be found not to comply with the Contract.
- 8.3.13 In all cases, where the Contract provides for tests whether at the premises or works of the Bidder or of any Sub- Bidder, the Bidder, except where otherwise specified, shall provide free of charge



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

such items as labour, materials, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the Employer/Inspector or his authorised representative to carry out effectively such tests of the equipment in accordance with the Contract and shall give facilities to the Employer/Inspection Engineer or to his authorised representative to accomplish testing.

- 8.3.14 The inspection and acceptance by Employer and issue of Inspection Certificate thereon shall in no way limit the liabilities and responsibilities of the Bidder in respect of the agreed quality assurance programme forming a part of the Contract, or if such equipment is found to be defective at a later stage.
- 8.3.15 The Employer will have the right of having at his own expenses any other test(s) of reasonable nature carried out at Bidder's premises or at site or in any other place in addition of aforesaid type and routine tests, to satisfy that the material comply with the specification.
- 8.3.16 The Employer reserves the right for getting any additional field tests conducted on the completely assembled equipment at site to satisfy that material complies with specifications.
- 8.3.17 Rework/ Re-engineering, if any, on any item/equipment shall be carried out only after mutual discussions and in accordance with mutually agreed procedure. Bidder shall submit Joint Inspection Report of equipments under Re-Work/Re-Engineering alongwith procedure for the same to POWERGRID for approval, before taking up the Re-Work/Re-Engineering, failing which POWERGRID reserves the right to reject the equipment.
- 8.3.18 Bidder may establish a field test Laboratory to execute Civil Construction testing requirements at site with the condition that all testing equipment shall be calibrated from POWERGRID approved accredited Testing laboratories, with calibration certificates kept available at site and all testing personnel employed in the Field Testing Laboratories to be qualified and experienced Engineers or testing to be carried out at POWERGRID approved Third Party Laboratories.
- 8.3.19 Bidder shall ensure that all possible steps are taken to avoid damages to the equipment during transport, storage and erection.
- 8.3.20 Bidder shall implement additional stringent quality checks and preparation during installation of GIS at site (if applicable) as per POWERGRID approved guidelines/Technical specifications.
- 8.3.21 Bidder shall ensure commissioning of all CSDs along with Circuit Breakers wherever applicable.
- 8.3.22 For EHV transformers/reactors:

Insulation oil shall be as per POWERGRID Technical specifications and same grade shall be used for impregnation of the active part & testing at the works of Transformer/Reactor Manufacturer and as well as for filling the Transformer/Reactors at site. Bidder to ensure that windings for Transformer/Reactors are made in air conditioned environment. Core-coil assembly shall be performed in positive pressurized dust controlled environment. Dust measurements shall be monitored regularly at Transformer / Reactor Manufacturer works. Bidder shall ensure that respective civil foundations & Fire walls for Transformer/Reactors units to be commissioned, shall be made ready at concerned sites before receipt of Transformer/Reactors units. All the requisite material for Neutral & Delta Bus formation required for charging of complete bank of



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

765KV class 1-ph Transformer/Reactor units shall be made available at the concerned sites before receipt of the Transformer/Reactor units at site.

- 8.3.23 The Employer reserves the right to increase or decrease their involvement in inspections at Bidder's Works or at his Sub-Bidder's premises or at the Employer's site or at any other place of Work based on performance of Bidder/sub-Bidder.

9.0 TYPE TESTING & CLEARANCE CERTIFICATE

- 9.1 All equipment being supplied shall conform to type tests as per technical specification and shall be subject to routine tests in accordance with requirements stipulated under respective sections.
- 9.2 The reports for all type tests as per technical specification shall be furnished by the Bidder alongwith equipment / material drawings. However, type test reports of similar equipments/ material already accepted in POWERGRID shall be applicable for all projects with similar requirement. The type tests conducted earlier should have either been conducted in accredited laboratory (accredited based on ISO / IEC Guide 25 / 17025 or EN 45001 by the national accreditation body of the country where laboratory is located) or witnessed by POWERGRID or representative authorized by POWERGRID or Utility or representative of accredited test lab.

Unless otherwise specified elsewhere, the type test reports submitted shall be of the tests conducted on or after 05-Nov-2009. In case the test reports are of the test conducted earlier than 05-Nov-2009, the bidder shall repeat these test(s) at no extra cost to the BHEL/Employer.

Further, in the event of any discrepancy in the test reports i.e. any test report not acceptable due to any design/manufacturing changes or due to non-compliance with the requirement stipulated in the Technical Specification or any/all type tests not carried out, same shall be carried out without any additional cost implication to the BHEL/Employer.

The Bidder shall intimate the Employer the detailed program about the type tests atleast two (2) weeks in advance in case of domestic supplies & six (6) weeks in advance in case of foreign supplies.

- 9.3 The Employer intends to repeat those type tests which are indicated in the price schedule and the same shall be payable as per provision of contract. The price of conducting type tests shall be included in Bid price and break up of these shall be given in the relevant schedule of Bid Proposal Sheets. These Type test charges would be considered in bid evaluation. In case Bidder does not indicate charges for any of the type tests or does not mention the name of any test in the price schedules, it will be presumed that the particular test has been offered free of charge. Further, in case any Bidder indicates that he shall not carry out a particular test, his offer shall be considered incomplete and shall be liable to be rejected. The Employer reserves the right to waive the repeating of type tests partly or fully and in case of waiver, test charges for the same shall not be payable.
- 9.4 The Employer reserves the right to witness any or all the type tests. The Employer shall bear all expenses for deputation of Employer's representative(s) for witnessing the type tests.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 9.5 The list of makes of various items, for which Type test reports are not required to be submitted are specified in Compendium of Vendors (COV).

10.0 Deleted.

11.0 PACKAGING & PROTECTION

- 11.1 All the equipments shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at Site till the time of erection. On request of the Employer, the Bidder shall also submit packing details/associated drawing for any equipment/material under his scope of supply, to facilitate the Employer to repack any equipment/material at a later date, in case the need arises. While packing all the materials, the limitation from the point of view of availability of Railway wagon sizes in India should be taken into account. The Bidder shall be responsible for any loss or damage during transportation, handling and storage due to improper packing. Any demurrage, wharfage and other such charges claimed by the transporters, railways etc. shall be to the account of the Bidder. Employer takes no responsibility of the availability of the wagons.
- 11.2 All coated surfaces shall be protected against abrasion, impact, discolouration and any other damages. All exposed threaded portions shall be suitably protected with either a metallic or a non-metallic protecting device. All ends of all valves and pipings and conduit equipment connections shall be properly sealed with suitable devices to protect them from damage.

12.0 FINISHING OF METAL SURFACES

- 12.1 All metal surfaces shall be subjected to treatment for anti-corrosion protection. All ferrous surfaces for external use unless otherwise stated elsewhere in the specification or specifically agreed, shall be hot-dip galvanized after fabrication. All steel conductors including those used for earthing/grounding (above ground level) shall also be galvanized according to IS: 2629.

12.2 HOT DIP GALVANISING

- 12.2.1 The minimum weight of the zinc coating shall be 610 gm/sq.m and minimum average thickness of coating shall be 86 microns for all items having thickness 6mm and above. For items lower than 6mm thickness requirement of coating thickness shall be as per relevant ASTM. For surface which shall be embedded in concrete, the zinc coating shall be 610 gm/sq.m minimum.
- 12.2.2 The galvanized surfaces shall consist of a continuous and uniform thick coating of zinc, firmly adhering to the surface of steel. The finished surface shall be clean and smooth and shall be free from defects like discoloured patches, bare spots, unevenness of coating, spelter which is loosely attached to the steel globules, spiky deposits, blistered surface, flaking or peeling off, etc. The presence of any of these defects noticed on visual or microscopic inspection shall render the material liable to rejection.
- 12.2.3 After galvanizing, no drilling or welding shall be performed on the galvanized parts of the equipment excepting that nuts may be threaded after galvanizing. Sodium dichromate or alternate approved treatment shall be provided to avoid formation of white rust after hot dip galvanization.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 12.2.4 The galvanized steel shall be subjected to four numbers of one minute dips in copper sulphate solution as per IS-2633.
- 12.2.5 Sharp edges with radii less than 2.5 mm shall be able to withstand four immersions of the Standard Preece test. All other coatings shall withstand six immersions. The following galvanizing tests should essentially be performed as per relevant Indian Standards.
- Coating thickness
 - Uniformity of zinc
 - Adhesion test
 - Mass of zinc coating
- 12.2.6 Galvanised material must be transported properly to ensure that galvanised surfaces are not damaged during transit. Application of touch-up zinc rich paint at site shall be allowed with approval of Engineer Incharge.

12.3 PAINTING

- 12.3.1 All sheet steel work shall be degreased, pickled, phosphated in accordance with the IS- 6005 "Code of practice for phosphating iron and sheet". All surfaces, which will not be easily accessible after shop assembly, shall beforehand be treated and protected for the life of the equipment. The surfaces, which are to be finished painted after installation or require corrosion protection until installation, shall be shop painted with at least two coats of primer. Oil, grease, dirt and swarf shall be thoroughly removed by emulsion cleaning. Rust and scale shall be removed by pickling with dilute acid followed by washing with running water, rinsing with slightly alkaline hot water and drying.
- 12.3.2 After phosphating, thorough rinsing shall be carried out with clean water followed by final rinsing with dilute dichromate solution and oven drying. The phosphate coating shall be sealed with application of two coats of ready mixed, stoving type zinc chromate primer. The first coat may be "flash dried" while the second coat shall be stoved.
- 12.3.3 After application of the primer, two coats of finishing synthetic enamel paint shall be applied, each coat followed by stoving. The second finishing coat shall be applied after inspection of first coat of painting.
- 12.3.4 The exterior and interior colour of the paint in case of new substations shall preferably be RAL 7032 for all equipment, marshalling boxes, junction boxes, control cabinets, panels etc. unless specifically mentioned under respective sections of the equipments. Glossy white colour inside the equipments /boards /panels/junction boxes is also acceptable. The exterior colour for panels shall be matching with the existing panels in case of extension of a substation. Each coat of primer and finishing paint shall be of slightly different shade to enable inspection of the painting. A small quantity of finishing paint shall be supplied for minor touching up required at site after installation of the equipments.
- 12.3.5 In case the bidder proposes to follow his own standard surface finish and protection procedures or any other established painting procedures, like electrostatic painting etc., the procedure shall be submitted during detailed engineering for Employer's review & approval.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

12.3.6 The colour scheme as given below shall be followed for Fire Protection and Air Conditioning systems

S.No.	PIPE LINE	Base colour	Band colour
Fire Protection System			
1	Hydrant and Emulsifier system pipeline	FIRE RED	-
2	Emulsifier system detection line – water	FIRE RED	Sea Green
3	Emulsifier system detection line –Air	FIRE RED	Sky Blue
4	Pylon support pipes	FIRE RED	-
Air Conditioning Plant			
5	Refrigerant gas pipeline – at compressor suction	Canary Yellow	-
6	Refrigerant gas pipeline – at compressor discharge	Canary Yellow	Red
7	Refrigerant liquid pipeline	Dark Admiralty Green	-
8	Chilled water pipeline	Sea Green	-
9	Condenser water pipeline	Sea Green	Dark Blue

The direction of flow shall be marked by → (arrow) in black colour.



Base Colour Direction of flow Band Colour

12.3.7 For aluminium casted surfaces, the surface shall be with smooth finish. Further, in case of aluminium enclosures, the surface shall be coated with powder (coating thickness of 60 microns) after surface preparation for painting. For stainless steel surfaces, no painting is envisaged.

13.0 Deleted

14.0 TOOLS

14.1 Deleted

14.2 SPECIAL TOOLS AND TACKLES

The bidder shall supply all special tools and tackles required for Operation and maintenance of equipment. The special tools and tackles shall only cover items which are specifically required for the equipment offered and are proprietary in nature. The list of special tools and tackles, if any, shall be finalized during detail engineering and the same shall be supplied without any additional cost implication to the Employer.

14.3 Deleted

15.0 AUXILIARY SUPPLY



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 15.1 The auxiliary power for station supply, including the equipment drive, cooling system of any equipment, air-conditioning, lighting etc shall be designed for the specified Parameters as under. The DC supply for the instrumentation and PLCC system shall also conform the parameters as indicated in the following table:

Normal Voltage	Variation in Voltage	Frequency in HZ	Phase/Wire	Neutral connection
415V	±10%	50 ± 5%	3/4 Wire	Solidly Earthed.
240V	±10%	50 ± 5%	1/2 Wire	Solidly Earthed.
220V	190V to 240V	DC	Isolated 2 wire System	-
110V	95V to 120V	DC	Isolated 2 wire System	-
48V	--	DC	2 wire system (+) earthed	-

Combined variation of voltage and frequency shall be limited to + 10%.

16.0 SUPPORT STRUCTURE

- 16.1 The equipment support structures shall be suitable for equipment connections at the first level i.e 14.0 meter, 8.0 meter, 5.9 meter and 4.6 meter from plinth level for 765kV, 400kV, 220kV and 132kV substations respectively. All equipment support structures shall be supplied alongwith brackets, angles, stools etc. for attaching the operating mechanism, control cabinets & marshalling box (wherever applicable) etc.
- 16.2 The minimum vertical distance from the bottom of the lowest porcelain part of the bushing, porcelain enclosures or supporting insulators to the bottom of the equipment base, where it rests on the foundation pad shall be 2.55 metres.

17.0 CLAMPS AND CONNECTORS INCLUDING TERMINAL CONNECTORS

- 17.1 All power clamps and connectors shall conform to IS: 5561 or other equivalent international standard and shall be made of materials listed below:

S.No.	Description	Materials
a)	For connecting ACSR conductors/AAC conductors/ Aluminium tube	Aluminum alloy casting, conforming to designation A6 of IS:617 and all test shall conform to IS:617
b)	For connecting equipment terminals mad of copper with ACSR conductors/AAC conductors/ Aluminium tube	Bimetallic connectors made from aluminum alloy casting, conforming to designation A6 of IS:617 with 2mm thick bimetallic liner/strip and all test shall conform to IS:617
c)	For connecting G.I	Galvanised mild steel shield wire
d)	Bolts, nuts & plain washers	Electro-galvanised for sizes below M12, for others hot dip galvanised.
e)	Spring washers	Electro-galvanised mild steel suitable for atleast service condition-3 as per IS:1573



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 17.2 Necessary clamps and connectors shall be supplied for all equipment and connections. If corona rings are required to meet these requirements they shall be considered as part of that equipment and included in the scope of work.
- 17.3 Where copper to aluminum connections are required, bi-metallic clamps shall be used, which shall be properly designed to ensure that any deterioration of the connection is kept to a minimum and restricted to parts which are not current carrying or subjected to stress.
- 17.4 Low voltage connectors, grounding connectors and accessories for grounding all equipment as specified in each particular case, are also included in the scope of Work.
- 17.5 No current carrying part of any clamp shall be less than 10 mm thick. All ferrous parts shall be hot dip galvanised. Copper alloy liner/strip of minimum 2 mm thickness shall be cast integral with aluminum body or 2 mm thick bi-metallic liner/strips shall be provided for Bi-metallic clamps.
- 17.6 All casting shall be free from blow holes, surface blisters, cracks and cavities. All sharp edges and corners shall be blurred and rounded off.
- 17.7 Flexible connectors, braids or laminated straps made for the terminal clamps for bus posts shall be suitable for both expansion or through (fixed/sliding) type connection of IPS AL tube as required. In both the cases the clamp height (top of the mounting pad to centre line of the tube) should be same.
- 17.8 Current carrying parts (500A and above) of the clamp/connector shall be provided with minimum four numbers of bolts preferably for 132kV & above.
- 17.9 All current carrying parts shall be designed and manufactured to have minimum contact resistance.
- 17.10 Power Clamps and connectors shall be designed to control corona as per requirement.
- 17.11 Tests**
- Clamps and connectors should be type tested as per IS: 5561 and shall also be subjected to routine tests as per IS: 5561. Following type test reports shall be submitted for approval. Type test once conducted shall hold good. The requirement of test conducted within last ten years, shall not be applicable.
- i) Temperature rise test (maximum temperature rise allowed is 35°C over 50°C ambient)
 - ii) Short time current test
 - iii) Corona (dry) [for 400kV and above] and RIV (dry) test [for 132kV and above voltage level clamps]
 - iv) Resistance test and tensile test
- 18.0 CONTROL CABINETS, JUNCTION BOXES, TERMINAL BOXES & MARSHALLING BOXES FOR OUTDOOR EQUIPMENT**



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 18.1 All types of boxes, cabinets etc. shall generally conform to & be tested in accordance with IS-5039/IS-8623, IEC-60439, as applicable, and the clauses given below:
- 18.2 Control cabinets, junction boxes, Marshalling boxes & terminal boxes shall be made of stainless steel of atleast 1.5 mm thick or aluminum enclosure of atleast 1.6 mm thick and shall be dust, water and vermin proof. Stainless steel used shall be of grade SS304 or better. The box shall be properly braced to prevent wobbling. There shall be sufficient reinforcement to provide level surfaces, resistance to vibrations and rigidity during transportation and installation. In case of aluminium enclosed box the thickness of aluminum shall be such that it provides adequate rigidity and long life as comparable with sheet steel of specified thickness.
- 18.3 A canopy and sealing arrangements for operating rods shall be provided in marshalling boxes / Control cabinets to prevent ingress of rain water.
- 18.4 Cabinet/boxes shall be provided with double hinged doors with padlocking arrangements. The distance between two hinges shall be adequate to ensure uniform sealing pressure against atmosphere.
- 18.5 All doors, removable covers and plates shall be gasketed all around with suitably profiled EPDM/Neoprene/PU gaskets. The gasket shall be tested in accordance with approved quality plan, IS:11149 and IS:3400. Ventilating Louvers, if provided, shall have screen and filters. The screen shall be fine wire mesh made of brass.
- Further, the gasketing arrangement shall be such that gaskets are pasted in slots (in door fabrication/gasket itself) in order to prevent ingress of dust and moisture inside the panels so that no internal rusting occurs in panels during the operation of the equipment.
- 18.6 All boxes/cabinets shall be designed for the entry of cables by means of weather proof and dust-proof connections. Boxes and cabinets shall be designed with generous clearances to avoid interference between the wiring entering from below and any terminal blocks or accessories mounted within the box or cabinet. Suitable cable gland plate above the base of the marshalling kiosk/box shall be provided for this purpose along with the proper blanking plates. Necessary number of cable glands shall be supplied and fitted on this gland plate. Gland plate shall have provision for some future glands to be provided later, if required. The Nickel plated glands shall be dust proof, screw on & double compression type and made of brass. The gland shall have provision for securing armour of the cable separately and shall be provided with earthing tag. The glands shall conform to BS:6121.
- 18.7 A 240V, single phase, 50 Hz, 15 amp AC plug and socket shall be provided in the cabinet with ON-OFF switch for connection of hand lamps. Plug and socket shall be of industrial grade.
- 18.8 LED based illumination of minimum 9 watts shall be provided. The switching of the fittings shall be controlled by the door switch.

For junction boxes of smaller sizes such as lighting junction box, manual operated earth switch mechanism box etc., plug socket, heater and illumination is not required to be provided.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 18.9 All control switches shall be of MCB/rotary switch type and Toggle/piano switches shall not be accepted.
- 18.10 Earthing of the cabinet shall be ensured by providing two separate earthing pads. The earth wire shall be terminated on to the earthing pad and secured by the use of self etching washer. Earthing of hinged door shall be done by using a separate earth wire.
- 18.11 The bay marshalling kiosks shall be provided with danger plate and a diagram showing the numbering/connection/feruling by pasting the same on the inside of the door.
- 18.12 The following routine tests alongwith the routine tests as per IS:5039 shall also be conducted:
i) Check for wiring
ii) Visual and dimension check
- 18.13 The enclosure of bay marshalling kiosk, junction box, terminal box and control cabinets shall conform to IP-55 as per IS:13947 including application of 2KV rms for 1 (one) minute, insulation resistance and functional test after IP-55 test.
- 19.0 DELETED**
- 20.0 TERMINAL BLOCKS AND WIRING**
- 20.1 Control and instrument leads from the switchboards or from other equipment will be brought to terminal boxes or control cabinets in conduits. All interphase and external connections to equipment or to control cubicles will be made through terminal blocks.
- 20.2 Terminal blocks shall be 650V grade and have continuous rating to carry the maximum expected current on the terminals and non-breakable type. These shall be of moulded piece, complete with insulated barriers, stud type terminals, washers, nuts and lock nuts. Screw clamp, overall insulated, insertion type, rail mounted terminals can be used in place of stud type terminals. But the terminal blocks shall be non-disconnecting stud type except for the secondary junction boxes of Current Transformer and Voltage Transformer.
- 20.3 Terminal blocks for current transformer and voltage transformer secondary leads shall be provided with test links and isolating facilities. The current transformer secondary leads shall also be provided with short circuiting and earthing facilities.
- 20.4 The terminal shall be such that maximum contact area is achieved when a cable is terminated. The terminal shall have a locking characteristic to prevent cable from escaping from the terminal clamp unless it is done intentionally.
- 20.5 The conducting part in contact with cable shall preferably be tinned or silver plated however Nickel plated copper or zinc plated steel shall also be acceptable.
- 20.6 The terminal blocks shall be of extensible design, multilayer terminal arrangement is not allowed in any junction box (Common MB, Individual MB, JB etc.). There should be sufficient space at both sides of terminals so that ferrule number of wires / TB numbers are clearly visible during wire removal or insertion.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 20.7 The terminal blocks shall have locking arrangement to prevent its escape from the mounting rails.
- 20.8 The terminal blocks shall be fully enclosed with removable covers of transparent, non-deteriorating type plastic material. Insulating barriers shall be provided between the terminal blocks. These barriers shall not hinder the operator from carrying out the wiring without removing the barriers.
- 20.9 Unless otherwise specified terminal blocks shall be suitable for connecting the following conductors on each side.
- a) All circuits except Minimum of two of 2.5 sq mm CT/PT circuits copper flexible.
 - b) All CT/PT circuits Minimum of 4 nos. of 2.5 sq mm copper flexible.
- 20.10 The arrangements shall be in such a manner so that it is possible to safely connect or disconnect terminals on live circuits and replace fuse links when the cabinet is live.
- 20.11 Atleast 20 % spare terminals shall be provided on each panel/cubicle/box and these spare terminals shall be uniformly distributed on all terminals rows.
- 20.12 There shall be a minimum clearance of 250 mm between the First/bottom row of terminal block and the associated cable gland plate for outdoor ground mounted marshalling box and the clearance between two rows of terminal blocks shall be a minimum of 150 mm.
- 20.13 The Bidder shall furnish all wire, conduits and terminals for the necessary interphase electrical connections (where applicable) as well as between phases and common terminal boxes or control cabinets. For equipments rated for 400 kV and above the wiring required in these items shall be run in metallic ducts or shielded cables in order to avoid surge over-voltages either transferred through the equipment or due to transients induced from the EHV circuits.
- 20.14 All input and output terminals of each control cubicle shall be tested for surge withstand capability in accordance with the relevant IEC Publications, in both longitudinal and transverse modes. The Bidder shall also provide all necessary filtering, surge protection, interface relays and any other measures necessary to achieve an impulse withstand level at the cable interfaces of the equipment.

21.0 LAMPS & SOCKETS

21.1 Lamps & Sockets

All lamps shall use a socket base as per IS-1258, except in the case of signal lamps. All sockets (convenience outlets) shall be suitable to accept both 5 Amp & 15 Amp pin round Standard Indian plugs. They shall be switched sockets with shutters.

21.2 Hand Lamp:

A 240 Volts, single Phase, 50 Hz AC plug point shall be provided in the interior of each cubicle with ON-OFF Switch for connection of hand lamps.

21.3 Switches and Fuses:



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

- 21.3.1 Each panel shall be provided with necessary arrangements for receiving, distributing, isolating and fusing of DC and AC supplies for various control, signalling, lighting and space heater circuits. The incoming and sub-circuits shall be separately provided with miniature circuit breaker / switch fuse units. Selection of the main and Sub-circuit fuse ratings shall be such as to ensure selective clearance of sub-circuit faults. Potential circuits for relaying and metering shall be protected by HRC fuses.
- 21.3.2 All fuses shall be of HRC cartridge type conforming to IS: 9228 mounted on plug-in type fuse bases. Miniature circuit breakers with thermal protection and alarm contacts will also be accepted. All accessible live connection to fuse bases shall be adequately shrouded. Fuses shall have operation indicators for indicating blown fuse condition. Fuse carrier base shall have imprints of the fuse rating and voltage.
- 22.0 Bushings, Hollow Column Insulators, Support Insulators:**
- 22.1 Bushings shall be manufactured and tested in accordance with IS:2099 & IEC-60137 while hollow column insulators shall be manufactured and tested in accordance with IEC-62155/IS:5621. The support insulators shall be manufactured and tested as per IS:2544/IEC-60168 and IEC-60273. The insulators shall also conform to IEC-60815 as applicable. The bidder may also offer composite hollow insulators, conforming to IEC-61462.
- 22.2 Support insulators, bushings and hollow column insulators shall be manufactured from high quality porcelain. Porcelain used shall be homogeneous, free from laminations, cavities and other flaws or imperfections that might affect the mechanical or dielectric quality and shall be thoroughly vitrified tough and impervious to moisture.
- 22.3 Glazing of the porcelain shall be uniform brown in colour, free from blisters, burrs and similar other defects.
- 22.4 Support insulators/bushings/hollow column insulators shall be designed to have ample insulation, mechanical strength and rigidity for the conditions under which they will be used.
- 22.5 When operating at normal rated voltage there shall be no electric discharge between the conductors and bushing which would cause corrosion or injury to conductors, insulators or supports by the formation of substances produced by chemical action. No radio interference shall be caused by the insulators/bushings when operating at the normal rated voltage.
- 22.6 Bushing porcelain shall be robust and capable of withstanding the internal pressures likely to occur in service. The design and location of clamps and the shape and the strength of the porcelain flange securing the bushing to the tank shall be such that there is no risk of fracture. All portions of the assembled porcelain enclosures and supports other than gaskets, which may in any way be exposed to the atmosphere shall be composed of completely non hygroscopic material such as metal or glazed porcelain.
- 22.7 All iron parts shall be hot dip galvanised and all joints shall be air tight. Surface of joints shall be trued up porcelain parts by grinding and metal parts by machining. Insulator /bushing design shall be such as to ensure a uniform compressive pressure on the joints.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

22.8 Tests

In bushing, hollow column insulators and support insulators shall conform to type tests and shall be subjected to routine tests in accordance with IS:2099 & IS:2544 & IS:5621.

22.9 Deleted

23.0 MOTORS

Motors shall be "Squirrel Cage" three phase induction motors of sufficient size capable of satisfactory operation for the application and duty as required for the driven equipment and shall be subjected to routine tests as per applicable standards. The motors shall be of approved make.

23.1 Enclosures

a) Motors to be installed outdoor without enclosure shall have hose proof enclosure equivalent to IP-55 as per IS: 4691. For motors to be installed indoor i.e. inside a box, the motor enclosure, shall be dust proof equivalent to IP-44 as per IS: 4691.

b) Two independent earthing points shall be provided on opposite sides of the motor for bolted connection of earthing conductor.

c) Motors shall have drain plugs so located that they will drain water resulting from condensation or other causes from all pockets in the motor casing.

d) Motors weighing more than 25 Kg. shall be provided with eyebolts, lugs or other means to facilitate lifting.

23.2 Operational Features

a) Continuous motor rating (name plate rating) shall be at least ten (10) percent above the maximum load demand of the driven equipment at design duty point and the motor shall not be over loaded at any operating point of driven equipment that will rise in service.

b) Motor shall be capable at giving rated output without reduction in the expected life span when operated continuously in the system having the particulars as given in Clause 15.0 of this Section.

23.3 Starting Requirements:

a) All induction motors shall be suitable for full voltage direct-on-line starting. These shall be capable of starting and accelerating to the rated speed alongwith the driven equipment without exceeding the acceptable winding temperature even when the supply voltage drops down to 80% of the rated voltage.

b) Motors shall be capable of withstanding the electrodynamic stresses and heating imposed if it is started at a voltage of 110% of the rated value.

c) The locked rotor current shall not exceed six (6) times the rated full load current for all motors, subject to tolerance as given in IS:325.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route
General Technical Requirements- Section 3
Doc. No. : TB-409-316-000 Rev 00

d) Motors when started with the driven equipment imposing full starting torque under the supply voltage conditions specified under Clause 15.0 shall be capable of withstanding atleast two successive starts from cold condition at room temperature and one start from hot condition without injurious heating of winding. The motors shall also be suitable for three equally spread starts per hour under the above referred supply condition.

e) The locked rotor withstand time under hot condition at 110% of rated voltage shall be more than starting time with the driven equipment of minimum permissible voltage by at least two seconds or 15% of the accelerating time whichever is greater. In case it is not possible to meet the above requirement, the Bidder shall offer centrifugal type speed switch mounted on the motor shaft which shall remain closed for speed lower than 20% and open for speeds above 20% of the rated speed. The speed switch shall be capable of withstanding 120% of the rated speed in either direction of rotation.

23.4 Running Requirements:

- a) The maximum permissible temperature rise over the ambient temperature of 50 degree C shall be within the limits specified in IS: 325 (for 3-phase induction motors) after adjustment due to increased ambient temperature specified.
- b) The double amplitude of motor vibration shall be within the limits specified in IS: 4729. Vibration shall also be within the limits specified by the relevant standard for the driven equipment when measured at the motor bearings.
- c) All the induction motors shall be capable of running at 80% of rated voltage for a period of 5 minutes with rated load commencing from hot condition.

23.5 TESTING AND COMMISSIONING

An indicative list of tests is given below. Bidder shall perform any additional test based on specialities of the items as per the field Q.P./Instructions of the equipment Bidder or Employer without any extra cost to the Employer. The Bidder shall arrange all instruments required for conducting these tests along with calibration certificates and shall furnish the list of instruments to the Employer for approval.

- (a) Insulation resistance.
- (b) Phase sequence and proper direction of rotation.
- (c) Any motor operating incorrectly shall be checked to determine the cause and the conditions corrected.

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C****LIST OF GENERAL STANDARDS AND CODES**

CODES	TITLE
--	India Electricity Rules
--	Indian Electricity Act
--	Indian Electricity (Supply) Act
--	Indian Factories Act
IS-5	Colors for Ready Mixed Paints and Enamels
IS-335	New Insulating Oils
IS-617	Aluminium and Aluminium Alloy Ingots and Castings for General Engineering Purposes
IS-1448 (P1 to P 145)	Methods of Test for Petroleum and its Products
IS-2071 (P1 to P3)	Methods of High Voltage Testing
IS-12063	Classification of degrees of protection provided by enclosures of electrical equipment
IS-2165 ; P1:1997, P2:1983	Insulation Coordination
IS-3043	Code of Practice for Earthing
IS-6103	Method of Test for Specific Resistance (Resistivity) of Electrical Insulating Liquids
IS-6104	Method of Test for Interfacial Tension of Oil against Water by the Ring Method
IS-6262	Method of test for Power factor & Dielectric Constant of Electrical Insulating Liquids
IS-6792	Method for determination of electric strength of insulating oils
IS-5578	Guide for marking of insulated conductors
IS-11353	Guide for uniform system of marking & identification of conductors & apparatus terminals.
IS-8263	Methods for Radio Interference Test on High voltage Insulators
IS-9224 (Part 1,2&4)	Low Voltage Fuses
IEC-60060 (Part 1 to P4)	High Voltage Test Techniques
IEC 60068	Environmental Test
IEC-60117	Graphical Symbols
IEC-60156	Method for the Determination of the Electrical Strength of Insulation Oils
IEC-60270	Partial Discharge Measurements
IEC-60376	Specification and Acceptance of New Sulphur Hexafluoride
IEC-60437	Radio Interference Test on High Voltage Insulators
IEC-60507	Artificial Pollution Tests on High Voltage Insulators to be used on AC Systems
IEC-62271-1	Common Specification for High Voltage Switchgear & Control gear Standards
IEC-60815	Guide for the Selection of Insulators in respect of Polluted Conditions

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C**

CODES	TITLE
IEC-60865 (P1 & P2)	Short Circuit Current - Calculation of effects
ANSI-C.1/NFPA.70	National Electrical Code
ANSI-C37.90A	Guide for Surge Withstand Capability (SWC) Tests
ANSI-C63.21, C63.3	Specification for Electromagnetic Noise and Field Strength Instrumentation 10 KHz to 1 GHZ
C36.4ANSI-C68.1	Techniquet for Dielectric Tests
ANSI-C76.1/EEE21	Standard General Requirements and Test Procedure for Outdoor Apparatus Bushings
ANSI-SI-4	Specification for Sound Level Meters
ANSI-Y32-2/C337.2	Drawing Symbols
ANSI-Z55.11	Gray Finishes for Industrial Apparatus and Equipment No. 61 Light Gray
NEMA-107T	Methods of Measurements of RIV of High Voltage Apparatus
NEMA-ICS-II	General Standards for Industrial Control and Systems Part ICSI-109
CISPR-1	Specification for CISPR Radio Interference Measuring Apparatus for the frequency range 0.15 MHz to 30 MHz
CSA-Z299.1-1978h	Quality Assurance Program Requirements
CSA-Z299.2-1979h	Quality Control Program Requirements
CSA-Z299.3-1979h	Quality Verification Program Requirements
CSA-Z299.4-1979h	Inspection Program Requirements
TRANSFORMERS AND REACTORS	
IS:10028 (Part 2 & 3)	Code of practice for selection, installation & maintenance of Transformers (P1:1993), (P2:1991), (P3:1991)
IS-2026 (P1 to P4)	Power Transformers
IS-3347 (part 1 to Part 8)	Dimensions for Porcelain transformer Bushings for use in lightly polluted atmospheres
IS-3639	Fittings and Accessories for Power Transformers
IS-6600	Guide for Loading of oil immersed Transformers
IEC-60076 (Part 1 to 5)	Power Transformers
IEC-60214	On-Load Tap-Changers
IEC-60289	Reactors
IEC- 60354	Loading Guide for Oil - Immersed power transformers
IEC-60076-10	Determination of Transformer and Reactor Sound Levels
ANSI-C571280	General requirements for Distribution, Power and Regulating Transformers
ANSI-C571290	Test Code for Distribution, Power and Regulation Transformers
ANSI-C5716	Terminology & Test Code for Current Limiting Reactors
ANSI-C5721	Requirements, Terminology and Test Code for Shunt Reactors Rated Over 500 KVA
ANSI-C5792	Guide for Loading Oil-Immersed Power Transformers upto and including 100 MVA with 55 deg C or 65 deg C Winding Rise

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C**

CODES	TITLE
ANSI-CG,IEEE-4	Standard Techniques for High Voltage Testing
IEC 60076	Power transformers
IEC 60076-1	Part 1: General
IEC 60076-2	Part 2: Temperature rise
IEC 60076-3	Part 3: Insulation levels, dielectric tests and external clearances in air
IEC 60076-4	Part 4: Guide to the lightning impulse and switching impulse testing - Power transformers and reactors
IEC 60076-3-1	Part 3-1: Insulation Levels and Dielectric Tests –External Clearances in Air
IEC 60076-5	Part 5: Ability to withstand short circuit
IEC 60076-6	Part 6: Reactors
IEC 60076-7	Part 7: Loading guide for oil-immersed power transformers
IEC 60076-8	Part 8: Application guide
IEC 60076-10	Part 10: Determination of sound levels
IEC 60076-10-1	Part 10-1: Determination of sound levels - Application guide
IEC 60076-11	Part 11: Dry-type transformers
IEC 60076-12	Part 12: Loading guide for dry-type power transformers
IEC 60076-13	Part 13: Self-protected liquid-filled transformers
IEC 60076-14	Part 14: Design and application of liquid-immersed power transformers using high-temperature insulation materials
IEC 60076-15	Part 15: Gas-filled power transformers
IEC 60076-16	Part 16: Transformers for wind turbine applications
IEC 60076-18	Part 18: Measurement of frequency response
IEC 60076-19	Part 19: Rules for the determination of uncertainties in the measurement of losses in power transformers and reactors
IEC 60076-21	Part 21: Standard requirements, terminology, and test code for step-voltage regulators
IEC 60044, BS 3938	Current transformers
IEC 60050	International Electrotechnical Vocabulary
IEC 60050(421)	International Electrotechnical vocabulary- Chapter 421 : Power Transformers and Reactors
IEC 60060	High Voltage test techniques
IEC 60060-1	General definitions and test requirements
IEC 60060-2	Measuring systems
IEC 60071	Insulation co-ordination
IEC 60071-1	Part 1: Definitions, principles and rules
IEC 60071-2	Part 2 : Application guide
IEC 60137	Bushing for alternating voltage above 1000V
IEC 60214	On-Load Tap changers
IEC 255-21-3	Relays vibration

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C**

CODES	TITLE
IS:3156- (P1 to P4)	Voltage Transformers
IS-4379	Identification of the Contents of Industrial Gas Cylinders
IEC-61869 (Part-1)	Instrument transformers - Part 1: General requirements
IEC-61869 (Part-2)	Instrument transformers - Part 2: Additional requirements for current transformers
IEC-61869 (Part-3)	Instrument transformers - Part 3: Additional requirements for inductive voltage transformers
IEC-61869 (Part-4)	Instrument transformers - Part 4: Additional requirements for combined transformers
IEC-61869 (Part-5)	Instrument transformers - Part 5: Additional requirements for capacitor voltage transformers
IEC-61869 (Part-6)	Instrument transformers - Part 6: Additional general requirements for low-power instrument transformers
IEC-61869 (Part-9)	Instrument transformers - Part 9: Digital interface for instrument transformers
IEC-61869 (Part-102)	Instrument transformers - Part 102: Ferroresonance oscillations in substations with inductive voltage transformers
IEC-61869 (Part-103)	Instrument transformers - The use of instrument transformers for power quality measurement
BUSHING	
IS-2099	Bushings for Alternating Voltages above 1000V
IEC-60137	Insulated Bushings for Alternating Voltages above 1000V
SURGE ARRESTERS	
IS-3070 (PART2)	Lightning arresters for alternating current systems : Metal oxide lightning arrestors without gaps
IEC-60099-4	Metal oxide surge arrestors without gaps
IEC-60099-5	Selection and application recommendation
ANSI-C62.1	IEE Standards for S A for AC Power Circuits
NEMA-LA 1	Surge Arresters
CUBICLES AND PANELS & OTHER RELATED EQUIPMENTS	
IS-722, IS-1248	Electrical relays for power system
IS-3231, 3231 (P-3)	Protection
IS:5039	Distributed pillars for Voltages not Exceeding 1000 Volts
IEC-60068.2.2	Basic environmental testing procedures Part 2: Test B: Dry heat
IEC-60529	Degree of Protection provided by enclosures
IEC-60947-4-1	Low voltage switchgear and control gear
IEC-61095	Electromechanical Contactors for household and similar purposes
IEC-60439 (P1 & 2)	Low Voltage Switchgear and control gear assemblies
ANSI-C37.20	Switchgear Assemblies, including metal enclosed bus
ANSI-C37.50	Test Procedures for Low Voltage Alternating Current Power

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C**

CODES	TITLE
	Circuit Breakers
ANSI-C39	Electric Measuring instrument
ANSI-C83	Components for Electric Equipment
IS: 8623: (Part I to 3)	Specification for Switchgear & Control Assemblies
NEMA-AB	Moulded Case Circuit and Systems
NEMA-CS	Industrial Controls and Systems
NEMA-PB-1	Panel Boards
NEMA-SG-5	Low voltage Power Circuit breakers
NEMA-SG-3	Power Switchgear Assemblies
NEMA-SG-6	Power switching Equipment
NEMA-5E-3	Motor Control Centers
1248 (P1 to P9)	Direct acting indicating analogue electrical measuring instruments & their accessories
Disconnecting switches	
IEC-62271-102	High-voltage switchgear and control gear - Part 102: Alternating current disconnectors and earthing switches
IEC-60265 (Part 1 & 2)	High Voltage switches
ANSI-C37.32	Schedule of preferred Ratings, Manufacturing Specifications and Application Guide for high voltage Air Switches, Bus supports and switch accessories
ANSI-C37.34	Test Code for high voltage air switches
NEMA-SG6	Power switching equipment
PLCC and line traps	
IS-8792	Line traps for AC power system
IS-8793	Methods of tests for line traps
IS-8997	Coupling devices for PLC systems
IS-8998	Methods of test for coupling devices for PLC systems
IEC-60353	Line traps for A.C. power systems
IEC-60481	Coupling Devices for power line carrier systems
IEC-60495	Single sideboard power line carrier terminals
IEC-60683	Planning of (single Side-Band) power line carrier systems
CIGRE	Teleprotection report by Committee 34 & 35
CIGRE	Guide on power line carrier 1979
CCIR	International Radio Consultative Committee
CCITT	International Telegraph & Telephone Consultative Committee
EIA	Electric Industries Association
Protection and control equipment	
IEC-60051: (P1 to P9)	Recommendations for Direct Acting indicating analogue electrical measuring instruments and their accessories
IEC-60255 (Part 1 to 23)	Electrical relays
IEC-60297 (P1 to P4)	Dimensions of mechanical structures of the 482.6mm (19 inches)

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**ANNEXURE-C**

CODES	TITLE
	series
IEC-60359	Expression of the performance of electrical & electronic measuring equipment
IEC-60387	Symbols for Alternating-Current Electricity meters
IEC-60447	Man machine interface (MMI) - Actuating principles
IEC-60521	Class 0.5, 1 and 2 alternating current watt hour metres
IEC-60547	Modular plug-in Unit and standard 19-inch rack mounting unit based on NIM Standard (for electronic nuclear instruments)
ANSI-81	Screw threads
ANSI-B18	Bolts and Nuts
ANSI-C37.1	Relays, Station Controls etc
ANSI-C37.2	Manual and automatic station control, supervisory and associated telemetering equipment
ANSI-C37.2	Relays and relay systems associated with electric power apparatus
ANSI-C39.1	Requirements for electrical analog indicating instruments
MOTORS	
IS-325	Three phase induction motors
IS-4691	Degree of protection provided by enclosure for rotating electrical machinery
IEC-60034 (P1 to P19:)	Rotating electrical machines
IEC-Document 2	Three phase induction motors
(Central Office) NEMA-MGI	Motors and Generators
Electronic equipment and components	
MIL-21B, MIL-833 & MIL-2750	Environmental testing
EC-60068 (P1 to P5)	Printed boards
IEC-60326 (P1 to P2)	Material and workmanship standards
IS-1363 (P1 to P3)	Hexagon head bolts, screws and nuts of product grade C
IS-1364 (P1 to P5)	Hexagon head bolts, screws and nuts of products grades A and B
IS-3138	Hexagonal Bolts and Nuts (M42 to M150)
ISO-898	Fasteners: Bolts, screws and studs
ASTM	Specification and tests for materials
Clamps & connectors	
IS-5561	Electric power connectors
NEMA-CC1	Electric Power connectors for sub station
NEMA-CC 3	Connectors for Use between aluminium or aluminum-Copper Overhead Conductors
Bus hardware and insulators	
IS: 2121	Fittings for Aluminum and steel cored Al conductors for overhead

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)**Annexure-G**

Sl. No.	Item / Equipment	Requirement of MQP/ITP/FAT	Inspection Level
33	D. G. Set	No	II
34	Split A.C/window A.C.	No	I
35	Substation Automation system	No	III
36	Telephone wires	No	I
37	Telephone sockets	No	I
38	Aluminium ladder	No	I
39	Occupancy sensors for control of lighting	No	I
40	Sub Station Structure (lattice/pipe type)	Yes	III
41	HG fuse	No	II
42	PLCC equipment Viz PLCC Terminal ,Carrier equipment, Protection Coupler , Coupling Device but excluding EPAX / HF Cable/ SDH Equipment	Yes	III
43	HF Cable / GPS Clock	No	I
44	EPAX	No	I
45	Cable Glands / Joints /Clamps/ Termination	No	I
46	Video Monitoring System	No	II
47	Controller for switching	No	IV
48	Solar based street lighting pole including solar panel as per technical specification	No	III
49	Event Logger	No	III
50	Lighting transformers	Yes	II
51	String Hardware	Yes	IV
52	Test Equipment	No	I *
53	GS Earthwire	Yes	IV
54	Oil Storage Tank	Yes	III
55	Insulating Oil	No	III
56	Flow sensitive conservator isolation valve	No	II **
57	On-Line insulating oil drying system	No	II **
58	On line DGA & Moisture Analyzer	No	II **
59	WAMS-(PMU & Accessories)	Yes	III
60	FO Cable	Yes	III
61	Re-rollers of MS/HT Angle Section and galvanized tower parts.	Yes	IV
62	Hardware fittings & Earthwire Accessories	Yes	IV
63	OPGW & H/W	Yes	III
64	Bolts & Nuts Gr up to 5.6/5	Yes	II
65	Bolts & Nuts of Gr 8.8 / 8	Yes	IV
66	D-shackle/ Hanger / Links	Yes	IV
67	Danger Plate /Phase Plate / Number Plate / Circuit plate	No	I
68	Pipe Type & Counter Poise Earthing	No	II
69	Spring Washer	No	II
70	ACD & Barbed wire for ACD/Bird guard	No	II

SECTION-GENERAL TECHNICAL REQUIREMENTS (GTR)

Annexure-G

Sl. No.	Item / Equipment	Requirement of MQP/ITP/FAT	Inspection Level
71	Span Marker & Obstruction Light	No	III
72	GIS including spares	Yes	IV
73	GIS Bus Duct	Yes	IV
74	GIS Bushing	Yes	IV
75	SF6 Gas processing Unit	No	II
76	Partial Discharge Monitoring System	No	II
77	STATCOM including Valve, valve base electronics, DC capacitor, series reactor and all accessories	Yes	IV
78	Mechanically switched Reactor bank (3-ph) including all accessories (MSR Branches)	Yes	IV
80	Mechanically switched Capacitor bank (3-ph) including all accessories (MSC Branches)	Yes	IV
81	Pass Harmonic filters	Yes	IV
82	Valve cooling system	Yes	III
	FODP including pigtail	No	II
	Radio link Telecom	Yes	III
	Hardware Fittings for Fibre Optic approach cable	Yes	III
	SDH Equipments (ADM), PDH, Primary Multiplexer	Yes	IV
	Drop & Insert Multiplexer	Yes	IV
	DACS	Yes	IV
	Main Distribution Frame	No	I
	HDPE Pipe	No	II
	NMS, TMN	Yes	IV
	Synchronization Equipment	No	Level-I
93	HT Capacitor	Yes	IV
94	PLC Capacitor	Yes	III
95	48V DCPS	Yes	III
96	Nitrogen Injection system	Yes	III
97	Foundation/Anchor bolts	Yes	III
98	EOT crane/Lift	No	II
99	Optical Signal Column	No	II
100	Maintenance Platform	No	II
101	Spark Gap	Yes	III
102	Thyristor Valve	Yes	III
103	DC current & voltage measuring device	ITP	III
104	Furniture	No	I

Note:

- * MICC for test and measuring equipment shall be issued only after actual verification/demonstration of satisfactory performance at site.
- ** Though level-2 items, CIP can be issued also on review of TCs and visual inspection of these items.



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

SECTION-4

GUARANTEED TECHNICAL PARTICULARS

To be submitted during contract execution stage as per TS requirement.



SECTION-5

CHECK LIST FOR INFORMATION TO BE FURNISHED WITH OFFER RETURN THIS CHECKLIST AS PART OF THE OFFER DULY SIGNED

The offer may not be considered if the following information and this Checklist are not enclosed with the Offer.

BHEL ENQUIRY. NO:

BIDDER: OFFER REFERENCE:

I. A) CARRIER EQUIPMENT

S.No.	Parameters	Data	Yes / No	Remarks
1.	Applicable Standard	IEC 60495	Yes / No	
2.	Type			
3	Type of Modulation	Amplitude Modulation	Yes / No	
4	Mode of Transmission	Single Side band	Yes / No	
5	Carrier frequency range	40 - 500 kHz	Yes / No	
6	Nominal carrier frequency band in either direction of transmission	4 kHz	Yes / No	
7	Frequency difference between the V.F. input and V.F. output of a pair of terminals connected back to back for permissible ambient temperature and supply voltage variation	Will not exceed 2 Hz	Yes / No	
8	Power Output at HF terminal	80W for S/C	Yes / No	
9	Whether compander is provided	Provided		
10	Compression and expansion ratio of compander	At least 2:1 compression ratio with a corresponding expansion ratio of 1:2.	Yes / No	
11	Whether carrier is suppressed during transmission of signal	Yes	Yes / No	
12	Whether frequency locking between Tx/Rx provided	Yes	Yes / No	
13	Automatic gain control range and regulation	For 40 dB change in carrier frequency signal level within the regulation range change in VF receive levels of both speech and other signals shall be less than 1 dB.	Yes / No	
14	Level of spurious emission at			
(a)	Edge of nominal carrier frequency	As per IEC 495	Yes / No	



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

(b)	4.0 kHz away from nominal carrier frequency band	As per IEC 495	Yes / No	
(c)	8.0 kHz away from nominal carrier frequency band	As per IEC 495	Yes / No	
15	Group delay distortion in the frequency band relevant to the transmission of protection signals	As per CCITT recommendation G.232	Yes / No	
16	Performance under noise condition			
(a)	Noise generated within terminal	As per IEC 495	Yes / No	
(b)	Additional noise introduced when terminals are connected back to back at repeater station	As per IEC 495	Yes / No	
(c)	Noise bandwidth	As per IEC 495	Yes / No	
17	Power supply requirements			
(a)	Voltage	48 V DC	Yes / No	
(b)	Permissible voltage requirement	15 %, - 10% (positive pole earthed)	Yes / No	
18	All solid state equipment /system panels subjected to heat soaking as per clause 9.16 of Section II		Yes / No	
19	Powergrid approved standard drawing/Type test reports/GTP are available for approval extension		YES	

II. B) TYPE TESTS

i) Whether type test reports of the following test conducted earlier as per IEC 495 on identical or similar material are available (test reports are of the test conducted not earlier than 10 (ten) years prior to the date of bid opening).
(YES / NO)

S.No.	TESTS	REPORT NO.	Date	Conducted at accredited laboratory or witnessed by independent authority
1	Voltage Variation			
2	Carrier frequency range & band			
3	Frequency accuracy			
4	Transmit / Receive frequency difference			
5	Automatic gain control			
6.	Harmonic distortion			
7	Selectivity			
8	Output impedance, Return loss & Tapping loss			
9	Return loss, Af			



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

	inputs/outputs			
10	Balance to ground			
11	Limiter action			
12	Spurious emission			
13	Carrier frequency levels and levels			
14	Attenuation distortion			
15	Noise generated within terminal			
16	Near and far end cross talk			
17	Group delay distortion			
18	Conducted noise			
19	Telephone signaling channel			
20	Speech levels			
21	Voltage withstand test			
22	Insulation test			

ii) If type test reports are not acceptable to BHEL/Customer then above tests shall be conducted by the bidder free of cost .
(YES / NO)

III. A) PROTECTION COUPLER

S.No.	Parameters	Data	Yes / No	Remarks
1.	Applicable Standard	IEC 60834	Yes / No	
2.	Type			
3	Principle of working for transmission / reception of protection signal	Frequency shift keying / coded signal	Yes / No	
4	Each protection signaling equipment shall provide	Transmission facilities for minimum three protection signals and reception facilities for minimum three protection signals.	Yes / No	
5	The equipment shall be suitable for	Transmission of direct and permissive trip signal as well as blocking signals	Yes / No	
6	The overall time of PLC,VFT and transmission path for permissive trip / blocking	20 msec.or less	Yes / No	
7	The overall time of PLC,VFT and transmission path for direct trip	30 msec.or less	Yes / No	



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii)765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

8	Under no circumstances protection channel should share power	Yes	Yes / No	
9	Whether loop facilities is provided for operational reliability	Yes	Yes / No	
10	Whether built in counters for counting the number of trip command sent and number of trip command received is provided	Yes	Yes / No	
11	Whether equipment is suitable for direct circuit breaker	Yes	Yes / No	
12	Transmitter input requirements (contact requirements)			
(a)	Voltage	660 volts	Yes / No	
(b)	Current	5 amps	Yes / No	
(c)	Power	1250 W/VA	Yes / No	
(d)	No. of contacts	2 No. potential free NO contact	Yes / No	
13	Receiver output requirements (contact requirements)			
(a)	Voltage	250 V (DC)	Yes / No	
(b)	Current	0.1 A (DC)	Yes / No	
(c)	Power	As per IEC-255--25	Yes / No	
(d)	No. of contacts	2 No. potential free NO contact	Yes / No	
14	Supervisory and alarm contact facilities			
(a)	Current	0.1A(DC)	Yes / No	
(b)	Voltage	250 V(DC)	Yes / No	
(c)	No of contacts	2 number potential free change over contact	Yes / No	
15	Power Supply			
(a)	Voltage	48 V DC , + 15 % - 10% (Positive pole earthed)	Yes / No	
16	Whether loop test is possible	Yes	Yes / No	
17	Insulation level	As per IEC 60834	Yes / No	
18.	Powergrid approved standard drawings available for approval extension		Yes	



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

III. B) TYPE TESTS

III. B.1) PROTECTION COUPLER :

i) Whether type test reports of the following test conducted earlier as per IEC 60834-1 on identical or similar material are available (test reports are of the test conducted not earlier than 10 (ten) years prior to the date of bid opening). **(YES / NO)**

S.No.	TESTS	REPORT NO.	Date	Conducted at accredited laboratory or witnessed by independent authority
1	Power supply variation			
2	Power supply interruption			
3	Reflected noise			
4	Reverse Polarity			
5	Interference by discrete frequency			
6.	Transmission time			
7	Interference by frequency deviation (Wherever applicable)			
8	Alarm functioned			
9	Security			
10	Dependability			
11	Voltage withstand test			
12	Insulation test			
13	Electrical fast transient test (along with carrier terminal)			
14	HF disturbance test (along with carrier terminal)			
15	Electrostatic discharge test (along with carrier terminal)			
16	Radiated electromagnetic field susceptibility test (along with carrier terminal)			
17	Environment test (as per IS 9000)			

ii) If type test reports are not acceptable to BHEL/Customer then above tests shall be conducted by the



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii)765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

bidder free of cost .

(YES / NO)

III. B.2) RELAY ASSOCIATED WITH PLCC EQUIPMENT :

i) Whether type test reports of the following test conducted earlier as per IS 8686 on identical or similar material are available (test reports are of the test conducted not earlier than 10 (ten) years prior to the date of bid opening).

(YES / NO)

S.No.	TESTS	REPORT NO.	Date	Conducted at accredited laboratory or witnessed by independent authority
1	Impulse voltage withstand test as per clause 6.1 of IS: 8686 (for a test voltage appropriate to clause III as per clause 3.2 of IS : 8686).			
2	High frequency disturbance test as per clause 5.2 of IS: 8686 (for a test voltage appropriate to clause III as per clause 3.2 of IS: 8686).			

ii) If type test reports are not acceptable to BHEL/Customer then above tests shall be conducted by the bidder free of cost .

(YES / NO)

IV. A) COUPLING DEVICE

S.No.	Parameters	Data		Yes / No	Remarks
1.	Applicable Standard	IEC 481, IS 8998		Yes / No	
2.	Type, Model Number				
	Type of Coupling device (indenter to tick)	Phase to Phase √	Phase to earth	Yes / No	
3	Type of mounting	Outdoor		Yes / No	
4	Maximum temperature limit for satisfactory operation	50 °C (Satisfactory operation upto 65 °C)		Yes / No	
5	Nominal line side Impedance	240 ohms for 765kV and 400kV Quad bundle conductor line		Yes / No	



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

6	Nominal equipment side impedance	75 ohm (unbalanced)	Yes / No	
7	Composite loss within passband	Not more than 2 dB	Yes / No	
8	Return loss within passband	Not less than 12 dB	Yes / No	
9	Available bandwidth	36 to 500 kHz	Yes / No	
10	Nominal peak Envelope Power (with distortion and inter modulation products 80 dB down)	Not less than 650 watt	Yes / No	
11	Power frequency impedance between primary terminal and Earth terminals of coupling device	Less than 20 ohms	Yes / No	
12	1 Minute power frequency insulation level between primary and secondary terminals of coupling device	5 kVrms	Yes / No	
13	Impulse (1.2/50 micro-sec.) withstand level between primary and secondary terminals of coupling device	As per IEC 481	Yes / No	
14	Power frequency current carrying capacity of drain coil (or primary winding of matching transformer)	As per IEC 481	Yes / No	
15	Whether Surge arrester in primary side of coupling device as per IEC 481 provided	Provided	Yes / No	
16	No. of H.F terminals provided for carrier equipment	At least 2	Yes / No	

IV. B) TYPE TESTS

i) Whether type test reports of the following test conducted earlier on identical or similar material are available (test reports are of the test conducted not earlier than 10 (ten) years prior to the date of bid opening).
(YES / NO)

S.No.	TESTS	REPORT NO.	Date	Conducted at accredited laboratory or witnessed by independent authority
1	Return loss test (as per IEC 481)			
2	Composite loss test (as per IEC 481)			
3	Distortion and inter modulation test (as per IEC 481)			



**Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00**

4	Impulse voltage test (as per IEC 481)			
5	Tests on arrestors (as per IEC 481)			

ii) If type test reports are not acceptable to BHEL/Customer then above tests shall be conducted by the bidder free of cost .
(YES / NO)

V. A) H.F.CABLE

S.No.	Parameters	Data	Yes / No	Remarks
1.	Applicable Standard	IEC 60096-2, BS:2316, IS:5082	Yes / No	
2.	Type	Steel Armoured and its outer covering shall be protected against attack by termites	Yes / No	
3	Attenuation per km. of cable at various carrier frequencies in the range of 40 to 500 kHz	1 to 5 dB/Km	Yes / No	
4	Details and particulars of insulation			
5	Withstand test voltage (rms) between conductor and outer sheath	4 kV for 1 min.	Yes / No	
6	Conductor resistance of cable	Not exceed 16 ohms /Km at 20 °C	Yes / No	
7	Packing length per drum	500 meter.	Yes / No	

V. B) TYPE TESTS

i) Whether type test reports of the following test conducted earlier on identical or similar material are available (test reports are of the test conducted not earlier than 10 (ten) years prior to the date of bid opening).

(YES / NO)

S.No.	TESTS	REPORT NO.	Date	Conducted at accredited laboratory or witnessed by independent authority
1	Inner conductor Tests			
2	Dielectric Tests			
3	Insulation Tests			
4	Outer conductor Tests			
5	Inner Sheath Tests			
6	Armour Tests			
7	Outer sheath Tests			
8	Ageing Tests			



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii)765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

ii) If type test reports are not acceptable to BHEL/Customer then above tests shall be conducted by the bidder free of cost .
(YES / NO)

VI. A) Electronic Private Automatic Exchange (EPAX)

S.No.	Parameters	Data	Yes / No	Remarks
1.	Type			
2	Construction feature	Solid state and fully automatic	Yes / No	
3	Number of subscriber lines (Indenter to tick)	4 8 24 v 48	Yes / No	
4	Number of trunk lines	4 8 v 12	Yes / No	
6	Operating voltage	48 V DC with + ve pole earthed	Yes / No	
7	Whether four wire E/M interfaces unit is provided.	Yes	Yes / No	
7	Whether suitable to work in conjunction with Electro - mechanical PAX	Yes	Yes / No	
9	Whether suitable to work with DOT leased lines	Yes	Yes / No	

VII. ADDITIONAL REQUIREMENTS:

1.	The PLCC manufacturer meets the Qualifying requirements specified in Section-I, 1.3 of this Technical Specification.		Yes/No	
2.	Valid Type test reports as per Section-II, is attached along with this offer.		Yes/No	
3	Confirmation to clause 9.0 of Section – III pertaining to TYPE TESTING, INSPECTION, TESTING & INSPECTION CERTIFICATE		Yes/No	
4	List of Deviations if any, is attached along with offer		Yes/No	
5	List of all special tools and tackles as per Clause 1.3.6 of Section-I of this technical Specification and scope thereof of BHEL/Supplier is attached along with offer.		Yes/No	
6	Confirmation to the undertakings to be		Yes/No	



Substation Package - SS02 for (i) 765kV Fatehgarh-2 (PG) S/S Extension and (ii) 765kV Bhadla-2 (PG) S/s Extension under Transmission System Associated With LTA applications from Rajasthan SEZ Part-B (Rajasthan SEZ Part-B Project) through Tariff Based Competitive Bidding (TBCB) Route. PLCC Equipment
Doc. No. : TB-409-557-023 Rev 00

	submitted at contract stage, as per Annexure C attached along with section III.			
7	Bidder to submit details of freq. planning done (including computer studies carried out and facilities available) for PLCC links on EHV lines in the past along with this offer		Yes/No	
8	One copy of computer study result done in past attached along with this offer.		Yes/No	
9	Following Documents are attached along with the offer :			
	a. Filled Checklist.		Yes/No	
	b. Filled GTP		Yes/No	
	c. Drawings & technical Literature		Yes/No	
10	Compliance to Cl. 5.11 of Section II. Req'd. details shall be submitted at contract stage .		Yes/No	
11	Construction dwg. of HF cable with Mechanical & Electrical parameters , enclosed with offer		Yes/No	
12	Details as per cl. 10.1(d) of Section II shall be furnished at contract stage		Yes/No	
13	All terminals for speech shall be with transit band pass filter, tunable at site & wired for addition of VFT's in future		Yes/No	
14	Compliance to cl. 10.4.2 of Section II. Req'd. data shall be furnished at contract stage		Yes/No	
15	Mandatory testing & maintenance equipment as per cl. 11, page 21/23 section II , included in offer		Yes/No	

Date:

Signature of the authorized representative of Bidder

Company Seal

SECTION II

PLCC EQUIPMENTS

1. GENERAL

- 1.1 All the PLCC equipment covered under the package shall conform to the requirements of the latest edition of the relevant IEC/IS Specifications or equivalent National Standards,

2. Standard And Drawing

- 2.1 The IEC/IS Specifications and international publication relevant to the equipment covered under this specification shall include but not be limited to the IS-8792,8793,8997,8998,IEC-60353,-60481,-60495,-60683,CIGRE-Teleprotection report by Committee 34 & 35.t, CIGRE-Guide on PLC 1979.,CCIR,CCITT,EIA

3. Location of Equipment

- 3.1 The PLCC Equipment and ~~Line traps~~ as specified shall be installed at the respective ends of the transmission lines. The Contractor shall be responsible for coordinating the equipment supplied by him with the already existing carrier equipment at the respective sub-stations. Contractor shall also be responsible for collecting all the necessary information/data from the respective sub-stations/concerned State Electricity Boards for the installation of the equipment.

4. Frequency Planning

- 4.1 For planning frequency and output power of carrier terminals Bidders may plan for a minimum receive signal to noise ratio of 25 dB for the speech channels without companders. The noise power in 2.1 kHz band (300-2400 Hz) may be taken as -13 dBm referred to the coupling point of the H.T. line. An additional minus two and a half dB may be assumed for psophometric factor. As far as coupling loss (phase to phase) is concerned the Bidders may assume the same as 6dB at one coupling end for evaluating SNR. For protection channels the minimum SNR shall not be less than 15 dB under adverse weather. A safety margin of 9 dB shall be taken over and above these SNR values in order to cater for variations in line attenuation from the computed value as inhand reserve. Frequency and output power of PLC terminals for protection shall be planned such that the protection signal is received with full reliability even when one of the phase is earthed or is on open circuit on the line side causing an additional minimum loss of 6 dB.

The Bidder shall indicate the noise power in the bandwidth used for protection signaling and shall submit the SNR calculations for speech as well as protection channels on all the line section given in at the proposed frequencies. Sample calculations for SNR requirement and power allocation over different channels

must be furnished alongwith the bid. Maximum permissible line attenuation shall be clearly brought out in these calculations. Further, Bidder shall submit details of frequency planning done (including computer studies carried out and facilities available) for PLCC links on EHV lines in the past in the relevant schedule of DRS. Bidder must enclose one copy of computer study result done in the past along with the Bid.

4.2 Successful Bidder shall be fully responsible for the coordination required with concerned State Electricity Boards for finalising the frequency plan.

4.3 The frequency plan will be referred to wireless Adviser/DOP Department for clearance and in case any change in the Contractor's recommended carrier frequency and power output is proposed by these authorities, the Contractor shall have to modify his proposal accordingly. Change of power output shall, however, not involve repeater stations.

5. **Proposed Arrangement**

5.1 The power line carrier communication equipment required by the OWNER is to provide primarily efficient, secure and reliable information link for carrier aided distance protection and direct tripping of remote-end breaker and also for speech communication between 765/400/220 kV sub-stations. It shall include separate carrier terminals of multipurpose type for speech and protection purposes. All carrier terminals including those for protection shall be suitable for point to point speech communication also.

5.2 For security reasons each 765/400/220kV transmission line shall be protected by Main-I and Main-II protections as given below :

Main-I Numerical Distance protection with permissive inter-tripping.

Main-II Distance protection of a different measuring technique than that of relay under Main I.

132kV transmission lines shall have Main I protection same as above alongwith backup overcurrent and earth fault protections.

5.3 The requirement of carrier information on each link covered under this specification is as below :

a) One protection channel for Main-I and another for Main-II distance protection schemes. Further these channels will also be used as main and back-up channel for direct circuit breaker inter-tripping for 765kV/ 400kV lines.

In case of 400KV/220 KV/132 KV lines ,speech and data channel can also be used for protection wherever possible.

- b) One speech channel with a facility to superimpose data signals upto 1200Baud.

However, the number of channels for protection signaling , speech and data communication for SAS and Load dispatch centre shall be as per the BOQ given in price schedule.

- 5.4 The equipment for protection signals shall have high degree of reliability and speed. It shall be guaranteed to function reliably in the presence of noise impulse caused by isolator or breaker operation. The equipment shall be suitable for direct tripping of remote end breaker for fault in unswitched 765kV/400 kV Shunt Reactor & Operation of Buchholz relays of reactor etc. It shall also be possible to effect direct tripping of breaker at one end when the other end breaker opens out either manually or by relays such as Bus fault relay etc.
- 5.5 The time intervals between receipt of a trip command on the transmit side, its transmission over the carrier link, reception at the far end and giving command to the trip relays at the distant end shall not exceed 20 mS. for permissive inter-tripping and 30 m sec. for direct inter-tripping even for the longest line section. The above timings are inclusive of operating time for auxiliary relays and interposing relays, if any, included in the PLCC equipment.
- 5.6 The requirement of protection signaling channel is such that security against incorrect signals being received shall be at least two to three orders higher than reliability against a signal not being received.
- 5.7 For reasons of security and reliability, phase to phase coupling for 765kV/400 kV S/C , D/C & 220kV S/C lines shall be employed. Inter-circuit coupling shall be used for 220/132kV D/C lines and phase to ground coupling shall be used for 132 KV S/C lines. Double differential coupling shall also be considered for double circuit lines. Bidders must furnish detailed write-up on methods of coupling and recommend suitable coupling mode for double-circuit lines along-with the bids. Coupling mode shall, however, be fully confirmed by Contractor after conducting detailed computer study taking into account the transpositions of 765kV/400 kV lines for optimum coupling mode over these line sections. The coupling arrangement shall be fully optimized by the Contractor after conducting detailed study of every line section individually, taking into account the temperature variations, transpositions, earth resistivity, conductor configuration, carrier channels requirements, security and reliability criteria and other relevant details. The line attenuation shall be calculated for complete range of frequencies. The earth resistivity data, existing frequency networks and other relevant details of each line will be furnished to the Contractor for carrying out the computer studies and frequency planning. The Contractor shall complete the computer

studies wherever required and submit the frequency plan and optimum coupling details within a period of one month from the date of receipt of above data.

- 5.8 The 765kV/400 kV transmission lines may be transposed.

The transmission tower configuration and conductor details shall be forwarded after the award to enable the contractor to make his own computer study assessment of the carrier path based on wave propagation over transposed lines with each transposition point acting as “Modal Converter”.

- 5.9 The parameters of the equipment quoted shall be such that the mode of wave propagation on 765kV/400 kV power line (with transpositions indicated) shall not impose any limitation on the efficient and reliable performance of information link from protection or communication point of view.

- 5.10 The Contractor shall have to check and prove through the results of his computer studies that attenuation due to transpositions in the EHV lines is within limits and the offered equipment will perform satisfactorily.

- 5.11 The Bidder shall submit curves illustrating ‘incorrect tripping’ and “Failure to trip” probability plotted against corona noise level, in the presence of impulse noise due to switching of isolator and circuit breaker etc. Details of field tests and laboratory tests for successful operation of his equipment, under such adverse conditions shall be furnished by the Bidder. These are to be related to end-to-end signaling and shall take into account the type of communication link e.g. account shall be taken of transpositions in the phase to phase coupled H.T. line. Details of field tests and laboratory tests for successful operation of the equipment under the above circumstances shall be submitted by the Bidder illustrating the above parameters.

~~6. LINE TRAP~~

- ~~6.1 Line trap shall be broad band tuned for its entire carrier frequency range. Resistive component of impedance of the line trap within its carrier frequency blocking range shall not be less than 450 ohms for 765kV/400 kV system and 570 ohms for 220kV and 132 kV systems..~~

- ~~6.2 Line trap shall be provided with a protective device in the form of surge arrestors which shall be designed and arranged such that neither significant alteration in its protective function nor physical damage shall result from either temperature rise or the magnetic field of the main coil at continuous rated current or rated short time current. The protective device shall neither enter into operation nor remain in operation, following transient actuation by the power frequency voltage developed across the line trap by the rated short time current.~~

~~The lightning arrester shall be station class current limiting active gap type. Its rated discharge current shall be 10 kA. Coordination, however, shall be done by taking 20 kA at 8/20 micro-sec. discharge current into account. Bidder has to furnish full justification in case the use of gap-less metal oxide arrester is recommended by them.~~

~~6.3 The lightning arrester provided with the line trap of each rating shall fully comply with the requirements of IS:3070 Part I/IEC 60099-1 Part I. It shall conform to type tests as applicable and type test certificate for the same shall be submitted by the Bidder.~~

~~6.4 The lightning arrester provided with the line trap shall be subject to routine and acceptance tests as per IEC-60099-1 (Part I).~~

~~6.5 The line trap on 765kV & 400 kV lines shall show no visual corona discharge at a voltage of 508kV(rms) and 320 KV (rms) power frequency falling voltage. Suitable corona rings may be incorporated in the line trap. Radio interference voltage for 420/245/132 kV shall not exceed 500 micro volts at 280/163/97 kV (rms) respectively. For 765kV, RIV shall not exceed 1000 micro volts at 508kV(rms).~~

~~6.6 Line trap shall be equipped with the bird barriers.~~

~~6.7 Line trap shall conform to IEC 60353 (latest) fulfilling all the technical requirements. The rated short time current for 1 Second shall be 31.5/40/50/63 kA as per requirement. The mH. rating shall be 0.25/0.5/1.0 mH depending on frequency plan.~~

~~6.8 The Bidder shall indicate continuous current rating of the line trap at 65 deg. C ambient.~~

~~6.9 Reports for the following type tests on each type of line trap shall be submitted as per clause 9.2 of Section III~~

- ~~1. Measurement of Inductance of the main coil.~~
- ~~2. Measurement of temperature rise.~~
- ~~3. Insulation test.~~
- ~~4. Short time current test.~~
- ~~5. Corona Extinction Voltage test (procedure for this shall be mutually agreed).~~
- ~~6. Radio Interference Voltage measurement test (procedure for this shall be mutually agreed).~~

- ~~6.10 The Bidder must enclose with his bid the reports of type and routine tests conducted on similar equipment earlier as per IEC 60353.~~
- ~~6.11 Welding~~
- ~~All the welding included in the manufacture of line traps shall be performed by personnel and procedure qualified in accordance with ASME IX and all the critical welds shall be subject to NDT as applicable.~~
- ~~6.12 Line Trap Mounting~~
- ~~6.12.1 The Line Trap shall be suitable for outdoor pedestal or suspension mounting and shall be mechanically strong enough to withstand the stresses due to maximum wind pressure of 260 kg/square meter.~~
- ~~6.12.2 For pedestal mounting, each line trap shall be mounted on a tripod structure formed by three insulator stacks arranged in a triangular form. All the accessories and hardware, mounting stool including bolts for fixing the line trap on insulators shall be of non magnetic material and shall be supplied by the Contractor.~~
- ~~6.12.3 For suspension mounting, Contractor shall be required to coordinate the mounting arrangement with the existing arrangement. Non magnetic suspension hook/link of adequate length and tensile strength to provide necessary magnetic clearance between the line trap and suspension hardware shall be supplied by the Contractor.~~
- ~~6.13 Terminal Connectors~~
- ~~6.13.1 The line traps shall be suitable for connecting to 4" IPS Aluminium tube or 3" IPS Al. tube or ACSR single/twin/Quad bundle conductor with horizontal or vertical take off. Necessary connector shall be supplied by the Contractor.~~
- ~~6.13.2 Terminal Connectors shall conform to IS:5561.~~
- ~~6.13.3 No part of clamp or connector (including hardware) shall be of magnetic material.~~
- ~~6.13.4 Clamps and connectors shall be designed corona controlled. Visual Corona extinction voltage shall not be less than 508kV(rms) & 320kV(rms) for 765kV and 420kV respectively. All nuts and bolts shall be suitably shrouded.~~
- ~~6.13.5 Radio interference Voltage for 420/245/132 kV shall not exceed 500 microvolts at 280/163/97 kV (rms) respectively. For 765kV, RIV shall not exceed 1000 micro volts at 508kV(rms).~~

~~6.13.6 Clamps/connectors shall be designed for the same current ratings as line trap and temperature rise shall not exceed 35 deg. C over 50 deg. C ambient. No current carrying part shall be less than 10 mm thick.~~

~~6.13.7 Clamps/connectors shall conform to type test as per IS:5561. Type Test reports shall also be submitted for following additional type tests :~~

- ~~a) Visual Corona Extinction Test~~
- ~~b) Radio Interference Voltage Measurement~~

~~6.13.8 Bidders are required to submit alongwith their bid typical drawings clearly indicating the above mentioned features of the line traps, line trap mounting arrangement and terminal connectors. For suspension mounted line traps, Bidder shall submit drawings showing single point as well as multipoint (normally 3 point) suspension arrangements.~~

7. COUPLING DEVICE

7.1 The coupling devices shall be interposed between the capacitor voltage transformer and coaxial line to the PLC transmitter/receiver, and in conjunction with the capacitor voltage transformer shall ensure :

- a) Efficient transmission of carrier frequency signals between the carrier frequency connection and the power line.
- b) Safety of personnel and protection of the low voltage parts and installation, against the effects of power frequency voltage and transient over voltages.

7.2 The coupling device, in conjunction with the CVT shall form an electric filter of band pass type :

- a) It shall match characteristic impedance of H.T. line to impedance of the carrier frequency connection.
- b) Galvanic isolation between primary and secondary terminals of the coupling device shall be performed by the above mentioned transformer.
- c) Power frequency currents derived by the CVT may be drained to the earth by a separate inductance termed drain coil of suitable rating.
- d) Voltage surges coming from the power line at the terminals of the coupling device shall be limited by a non-linear surge arrestor of suitable rating in the primary side. Requirement of a gas type voltage arrestor in secondary side of the coupling device shall have to be fully justified, but

in any case the input circuit of PLC. equipment shall have protective devices in the form of zener diodes and surge suppressers.

The surge arrester shall have power frequency spark over voltage coordinated with the equipment ahead of it.

- e) For direct and efficient earthing of its primary terminals, the coupling device shall be equipped with an earthing switch. The Earth Switch shall be available for earthing of CVT-HT terminals, when the coupling filter units are removed from circuit for maintenance/ replacement. The design shall take due regard of requirements for safety in accordance with the Indian Electricity Rules.

7.3 Two numbers 'phase to earth' type coupling filters shall be used to achieve 'phase to phase'/'inter-circuit coupling'. Connection between secondaries of the two phase to earth type coupling device shall be through a balancing transformer/hybrid such that reliable communication shall be ensured even when one of the coupled phase is earthed or open circuited on the line side.

7.4 Coupling device shall conform to IEC-60481 and shall have the following carrier frequency characteristics as applicable to a phase to earth type coupling device:

- | | | |
|----|--|--|
| a) | Nominal line side impedance | i) 240 ohms for 765kV and 400 kV Quad/triple bundle conductor line.
ii) 320 ohms for 400kV twin bundle conductor line.
iii) 400 ohms for 220/132 kV line |
| b) | Nominal equipment side impedance | 75 ohms (unbalanced) |
| c) | Composite loss | Not more than 2 dB |
| d) | Return Loss | Not less than 12 dB |
| e) | Bandwidth | Shall suit the frequency plan between 36 and 500 kHz |
| f) | Nominal peak envelope power
(for Inter-modulation product 80 dB down) | Not less than 650 Watt. |

7.5 The coupling device shall be suitable for outdoor mounting. Temperature of metallic equipment mounted outdoor is expected to rise upto 65 deg. C during the maximum ambient temperature of 50 deg. C specified. The equipment offered by the Bidder shall operate satisfactorily under these conditions.

- 7.6 The H.T. Terminal of coupling device shall be connected to H.F. Terminal of the CVT by means of 6 mm sq. copper wire with suitable lugs & taped with 11 kV insulation by the contractor.
- 7.7 Coupling device shall have at least two terminals for carrier equipment connection. Bidder shall confirm that such a parallel connection to coupling device directly will not result in any additional attenuation.
- 7.8 The coupling device including the drainage coil, surge arrester and earthing switch shall conform to type tests and shall be subject to routine tests as per IEC-60481/IS:8998.

Routine tests shall include but not be limited to the following :

- i) Composite loss and return loss tests on coupling device.
 - ii) Turns ratio test and insulation tests on the balancing transformer.
 - iii) Milli volt drop test, power frequency voltage test and mechanical operation test on earthing switch.
 - iv) Power frequency spark over test for lightning arrester as per relevant IS/IEC.
- 7.9 Reports for the following type tests on coupling device shall be submitted as per clause 9.2 of Section III
- 1.)Return loss test.
 - 2.)Composite loss test.
 - 3.)Distortion and inter modulation test .
 - 4.)Impulse voltage test.
 - 5)Tests on Arrestors

Bidder shall furnish, alongwith his bid copies of all type and routine test conducted earlier on similar coupling device in accordance with relevant standards.

8. **High Frequency Cable**

- 8.1 High frequency cable shall connect the coupling device installed in the switchyard to the PLC terminal installed indoor.

- 8.2 The cable shall be steel armoured and its outer covering shall be protected against attack by termites. Bidder shall offer his comments on method employed by him for earthing of screen and submit full justification for the same with due regard to safety requirements.
- Bidder must enclose in his bid a detailed construction drawing of the cable being offered, with mechanical and electrical parameters.
- 8.3 Impedance of the cable shall be such as to match the impedance of the PLC terminal on one side and to that of the coupling device on the other side over the entire carrier frequency range of 40-500 kHz.
- 8.4 Conductor resistance of cable shall not exceed 16 ohms per Km at 20°C.
- 8.5 The cable shall be designed to withstand test voltage of 4 kV between conductor and outer sheath for one minute.
- 8.6 Bidder shall specify attenuation per Km of the cable at various carrier frequencies in the range of 40 to 500 kHz. The typical attenuation figures for H.F. cable shall be in the range of 1 to 5 dB/km in the frequency range of 40-500 kHz.
- 8.7 The H.F. cable shall conform to type tests and be subjected to routine tests as per IS 11967(Part 2/Sec 1): 1989/IS 5026:1987.
- 8.8 All HF cables within the scope of this specification shall be laid and termination shall be carried out by the Contractor.
- 8.9 The cables shall be supplied wound on drums containing nominal length of 500 meters each. However, exact requirement of drum lengths shall be finalised during detailed engineering to avoid joint in HF cable and its wastage.
9. **Power Line Carrier Terminal**
- 9.1 As already indicated the information link shall be provided for speech, protection, telex and data services.
- 9.2 PLC terminal shall use Amplitude Modulation and shall have single side band transmission mode. These shall be equipped for fixed frequency duplex working.
- Characteristic input and output parameters of the SSB PLC terminals shall be as per IEC-60495, unless otherwise specified.
- 9.3 The salient features are detailed out below :

a)	Mode of transmission	Amplitude Modulation single side band with suppressed carrier or reduced carrier.
b)	Carrier frequency	40 to 500 kHz range
c)	Nominal carrier frequency band in either direction of transmission	4.0 kHz
d)	Power output (PEP) at HF terminal	20/40/80 Watt
e)	Frequency difference between a pair of PLC terminals	Frequency difference between VF signal at the transmitting and receiving ends will not exceed 2 Hz with suppressed carrier. With reduced carrier frequency difference shall be zero. This shall include permissible ambient temperature variation and supply frequency and voltage variation of (+) 15% and (-) 10%.
f)	Automatic gain control	For 40 dB change in carrier frequency signal level within the regulation range, change in VF receive levels of both speech and other signals shall be less than 1dB.
g)	Supply voltage	48 V DC + 15%, - 10%. (Positive pole earthed)

- 9.4 All the PLC terminals shall be of multipurpose type. The Bidder shall confirm that the total transmission time for teleprotection shall not exceed 20 ms for permissive and 30 ms for direct tripping signals. Speech and teleprotection channels shall independently fulfill the SNR requirements out of the power allocated to its channel from the total power of the PLC terminals.

Detailed calculation for SNR requirement and power allocation over different channels should be furnished alongwith the bid.

- 9.5 In the input circuit of the PLC terminal protective devices shall be provided in the form of zener diodes or surge suppressers in order to eliminate any surge transfer through the coupling device or the surge induced in the connecting path of H.F. cable.

- 9.6 To improve voice transmission characteristics for the system, compressors and expanders shall be provided. The companders shall have at least 2:1 compression ratio with a corresponding expansion ratio of 1:2. The operating range of compander shall be compatible with the audio power levels specified for 4 wire operation. The improvement gained by companders shall however not be taken into account for power allocation and shall be in-hand reserve.
- 9.7 Sudden changes in input level to the receiver shall not cause false tripping. The Bidder shall clearly indicate in his offer the methods adopted to ensure above phenomenon. The receiver design shall also provide protection against false tripping from random noise.
- 9.8 Fail-safe devices shall be provided, so that a malfunction in one unit or subassembly cannot cause damage elsewhere in the system. All plug-in equipment shall be fitted with features to prevent improper insertion. The electrical cables shall not be routed across sharp edges or near sources of high temperature. The adjustments, which are susceptible to misadjustment from accidental contact/vibration, shall be equipped with suitable locking devices.
- 9.9 The PLC set shall be designed to give guaranteed performance from 0 deg. C to 50 deg. C ambient temperature. The thermal capability of the equipment shall be so designed that the equipment remains operational successfully upto 60 deg. C ambient temperature. Any ventilation fans provided for circulation of air inside the cabinets shall conform to relevant Indian Standards.
- 9.10 The terminals shall be provided with built-in indicating instrument to facilitate checking of important voltages and current values and signal levels in different parts of the PLC Terminals. Protection fuses shall be provided in all important circuits and fuses shall be so mounted as allow their easy inspection and replacement. All test points shall be easily accessible.
- The carrier set shall be provided with suitable supervision and alarm facilities. Individual parts of the carrier set should be accessible from front, making it possible to place the carrier cabinets side-by-side. All components and parts of the carrier set shall be suitably tropicalised.
- 9.11 PLC terminals shall be housed in floor mounting sheet metal cabinets, suitable for mounting on concrete plinth as well as channel frame by means of nuts and bolts or welding. All the panels shall be properly earthed to the OWNER's earthing grid by the Contractor. Contractor shall submit detailed drawings for earthing connections.
- 9.12 All the panels shall be protected against moisture ingress and corrosion during storage. Panels shall be properly dried before they are installed and energized.

Bidder shall indicate measures adopted to prevent ingress of moisture during operation.

- 9.13 All cabinets having PLC terminals shall be provided with lamps of sufficient wattage for interior illumination with switch. Each panel shall be provided with 240 V AC single phase socket with switch to accept 5 & 15A standard Indian plugs.
- 9.14 A name plate shall be provided on the front door of each cabinet indicating channel function, transmitter frequency and direction etc.
- 9.15 Reports for the following type tests for PLC Terminals shall be submitted as per clause 9.2 of Section III
Tests to determine various characteristics of PLC terminals as per IEC –60495.
- a)Voltage variation
 - b)Carrier frequency range band.
 - c)Frequency accuracy
 - d)Transmit/Receive frequency difference.
 - e)Automatic gain control
 - f)Harmonic distortion
 - g) Selectivity
 - h)Output impedance, Return loss&Tapping loss
 - i)Return loss, Ainputs/Outputs
 - j)Balance to ground
 - k)Limiter action
 - l)Spurious emission
 - m)Carrier frequency levels and levels
 - n)Attenuation distortion
 - o)Noise generated within terminal

- p)Near and far end cross talk
- q)Group delay distortion
- r)Conducted noise
- s)Telephone signaling channel
- t)Speech levels
- u)Voltage withstand test
- v)Insulation test

9.16 Heat Soaking of panels
All the solid state equipment/system panels shall be subjected to the Heat Soaking as per the following procedure :

All solid state equipment shall be burn-in for minimum of 120 hours continuously under operation condition. During the last 48 hours of testing, the ambient temperature of the test chamber shall be 50°C. Each PLC panel shall be complete with all associated sub-systems and the same shall be in operation during the above test. During the last 48 hours of the above test, the temperature inside the panel shall be monitored with all the doors closed. The temperature of the panel interior shall not exceed 65°C.

10. **SPEECH COMMUNICATION**

10.1 PLC equipment offered shall provide telephone communication between the stations where the transmission lines are terminating. The equipment shall be suitable for providing the following facilities :

- a) It shall be possible for subscriber at any of the stations to contact the subscriber at all other stations connected in the system as shown in the specification drawing by dialing his call number. To achieve this a 24 lines EPAX with 4 wire interface & remote subscriber units shall be provided/available at different stations.
- b) The equipment shall contain all normal facilities like ring back tone, dial tone, engage tone & priority tone, and suitable pulses to establish and disconnect communication between subscribers.
- c) The equipment shall be provided with necessary alarm circuits and fuses etc.

- d) The equipment shall be of 4 kHz bandwidth on either direction and be suitable for providing superimposed data and teleprinter facilities at a later date without major modifications and high cost. The Bidder shall clearly indicate in his bid the provision made in his proposal for future development and the extent to which such additional facilities can be added at a later date.
- e) The system shall be completely automatic with definite number allocated for each telephone. The numbering scheme for telephones, exchange and tie lines shall be developed by the Bidder and indicated in the bid. Final numbering scheme shall be fully coordinated with the existing/ proposed future systems by the Contractor.
- f) Arrangement for over-riding facilities shall be provided by means of priority keys wherever specified. The over-riding facility shall enable cutting-in ongoing calls with the priority key and ask the concerned parties to finish their conversation. The wanted number should then get automatically connected without having to redial the number.
- g) All the carrier telephone conversations shall be secret and it should not be possible for anybody to over hear the conversation going on between any two parties excepting those provided with over-riding facilities.
- h) The necessary cables for connecting all the telephone instruments ordered for at each sub-station (including wiring and termination) shall be provided by the Contractor. These telephone instruments shall be located within control room building at respective sub-station.
- i) The cabinets housing the equipment for EPAX, four wire E/M interface & remote subscriber units (four wire) shall have mounting arrangement similar to that for PLC terminals.
- j) All the terminals for speech shall be with Transit Band Pass Filter suitable for tuning at site and shall be wired for addition of VFTs in future.
- k) Equipment for speech communication must be fully compatible with OWNER's existing equipment. Any interfaces required for proper matching and connection with the OWNER's existing equipment shall be provided by the Contractor.
- l) Terminals for protection shall be suitable for speech between two ends of each transmission line or on tandem operation basis with back to back connection at the intermediate stations.
- n) Each PLC terminal for speech as well as protection purposes shall be provided with a plug-in type service telephone and buzzer. Further, 4 wire

remote telephone instruments (parallel to service telephone) shall also be provided on one PLC terminal for protection for each link. These instruments shall be located in respective Switchyard control room to enable the operator to make emergency calls on point-to-point basis. Each such instrument shall be equipped with a buzzer and 'press-to-call' key and shall not require any additional power supply units.

10.2 Electronic Private Automatic Exchange (EPAX)

10.2.1 The 24 line Electronic Private Automatic Exchange (EPAX) wherever specified shall be connected to minimum six trunk routes thorough PLCC channels (speech panel) with Four-wire E/M' interface unit. This 4-wire interface unit either shall form an integral part of the 'EPAX' system or be suitable for mounting/housing in the carrier panel. The exchange will have its own ringing current and tone generator etc. The exchange shall be suitable for working on 48 V DC Power Supply (positive pole earthed).

The exchange shall be fully automatic, solid state, and of modular construction and shall have multiple switching routes (minimum 4-routes).

10.2.2 'EPAX' shall also be provided with two (2) additional interface units and operate exclusively with OWNER's leased subscriber lines, of Department of Telecommunication (DOT) and compatible with 2 wire full duplex, voice grade mode of operation.

The details of communication protocol, for interfacing of the 'DOT' leased lines, shall be coordinated by the Contractor, with the licensing authority (DOT).

10.3 Remote End Four Wire 'E/M' Interface & Subscriber Unit or Equivalent EPAX (4x4)

10.3.1 The remote end four wire 'E/M' interface & subscriber units, wherever specified, shall be of electronic type and be suitable for working on fixed frequency power line carrier systems with E & M signaling. This shall be housed in the carrier set and be fully wired to the power line carrier terminal equipment.

10.3.2 This unit shall receive and register various signals, on PLCC Channels, from remote end exchanges or other remote end subscriber units and associated four wire interface unit.

10.3.3 The four wire interface unit shall be equipped for routing transit calls and shall be supplied pre-wired to handle calls for minimum eight directions, in a form suitable for transmission over PLCC.

10.3.4 The bidder shall also indicate the total number of trunk-line capacity, available with each four-wire interface unit.

The unit shall be suitable for connecting two-wire telephone sets. Further, the associated telephone cables for locating two subscriber lines, within the control room is in the scope of this specification.

10.4 Network Protection Equipment (Protection Coupler)

10.4.1 The Bidder shall offer voice frequency transmission equipment which shall work on frequency shift or coded signal principle for transmission/reception of protection signals as single purpose channel. The equipment shall be suitable for connection to the power line carrier terminal.

10.4.2 The voice frequency transmission equipment shall not only be insensitive to corona noise but shall also remain unaffected by impulse type noise which are generated by electrical discharge and by the opening and closing of circuit breakers, isolators, earthing switches etc. The equipment shall also be made immune to a field strength of 10V/m expected to be caused by portable radio transmitters in the range of 20-1000 MHz. In his offer, bidder shall clearly explain as to what measures have been taken to make the equipment insensitive to corona noise, white noise and to impulse noise of an amplitude larger than the wanted signal and submit full field test and laboratory test reports. The guarantee on design data shall not be acceptable.

10.4.3 The equipment shall be unaffected by spurious tripping signals. The Bidder shall submit proof as to how this is achieved satisfactorily.

10.4.4 The equipment shall be suitable for transmission of direct and permissive trip signal as well as blocking signals for protective gear of power system. The equipment shall be operated in the audio frequency range in speech band or above speech band as superimposed channel in 4 kHz band of SSB carrier. The equipment shall operate with full duplex frequency shift mode of operation or by switching between two frequencies in case of coded signals. The protection signaling equipment shall be of solid state design, modular in construction and have a proven operating record in similar application over EHV systems. Details regarding application of the equipment over 765kV/400kV/220kV systems shall be submitted along with the bid. Each protection signaling equipment shall provide:

- i) Transmission facilities for minimum three protection signals.
- ii) Reception facilities for minimum three protection signals.

10.4.5 The equipment shall be designed for remote tripping/ blocking on permissive basis and direct tripping for reactor fault and others. The overall time of PLC,

VFT and transmission path for permissive trip/blocking shall be 20 m. Sec. or less and for direct tripping 30 m. Sec. or less even for the longest line section.

Operating time lower than specified above may be preferred provided they fulfill the requirements of security and reliability as mentioned below :

False - trip probability 10^{-5}
(Noise burst of any amplitude)

Fail to trip probability 10^{-2}
for S/N 6 dB in 3.1 kHz Band
(white Noise Measurement)

10.4.6 It may be emphasized that specified time, as mentioned above is composed of the following :

- a) Back-to-back signal delay in frequency shift or coded signals protection equipment.
- b) Back-to-back delay in PLC terminal.
- c) Delay in transmission line.
- d) Operation time of interposing relay, if any, in frequency shift or coding equipment.

Reference is invited in this regard to the guide lines expressed in CIGRE Publication “Teleprotection” report by Committee 34 and 35.

10.4.7 The following transfer criteria shall be provided by the equipment:

- a) Transmit side

One number potential free NO (normally open) contact of protective relays (To be supplied by the OWNER) of under noted rating for each of the following functions:

- i) Permissive trip command
- ii) Direct trip command

Contact Rating:

Maximum voltage	: 660 Volts
Maximum current rating	: 5 amps
Maximum power rating	: 1250 W/VA

b) Receive Side

Voice frequency transmission equipment for network protection shall be provided with one potential free NO (normally open) contact of the under noted rating for each of the following functions:

- i) Permissive trip command
- ii) Direct trip command

Contact Rating:

Rated voltage	:	250 Volts DC
Rated current	:	0.1 A DC
Other Parameters	:	As per IEC-60255-25

c) Alarm

In addition, the voice frequency protection terminal shall provide at least one number potential free change over contact of the following rating for alarm purposes.

Rated voltage	:	250 volts DC
Rated current	:	0.1 A DC
Other Parameters	:	As per IEC-60255-25

- 10.4.8 The Contractor shall submit drawings showing inter-connection between PLCC and protection panels for approval by the OWNER.
- 10.4.9 It has to be ensured that under no circumstances protection channel should share the power. Each protection channel shall be able to transmit power for which system is designed. For example, a 40 W PLC terminal shall transmit 40 Watt (max.) for protection channel alone in the event of fault. Speech and super-imposed data channels, in the same protection terminal must get disconnected momentarily during the operation of protection channels.
- 10.4.10 The equipment shall be constructed such that in permissive line protection system, operational reliability of the protection channel may be checked over the carrier link by means of a loop test. It shall be possible to carry out the above test from either end of the carrier link. During healthy condition of the transmission line, the loop test shall not initiate a tripping command. In the event of a system fault, while loop test is in progress, protection signal shall over-ride the test signal.

10.4.11 The equipment shall be complete with built in counters for counting the number of trip commands sent and number of trip commands received.

10.4.12 Reports for the following tests as per clause 9.2 of ~~GTR~~ ^{Section III} shall be submitted for approval for protection coupler and the relays associated with PLCC equipment for network protection signaling equipment and interface unit with protective relay units if any :

1)Protection coupler (As per IEC 60834 -1)

a)Power supply variation

b)Power supply interruption

c)Reflected noise

d)Reverse polarity

e)Interference by discrete frequency

f)Transmission time

g) Interference by frequency deviation. (Wherever applicable)

h)Alarm function

g)Security

h)Dependability

i)Voltage withstand test

j)Insulation test.

j) Electrical fast transient test (along with carrier terminal)

k)HF disturbance test (along with carrier terminal)

l)Electro static discharge test (along with carrier terminal)

m)Radiated electromagnetic field susceptibility test (along with carrier terminal)

n)Environment test (as per IS 9000)

:

2. **Relays.**

- a) Impulse voltage withstand test as per Clause 5.1 of IS:8686 (for a test voltage appropriate to Class III as per Clause 3.2 of IS:8686).
- b) High Frequency Disturbance test as per Clause 5.2 of IS:8686 (for a test voltage appropriate to Class III as per Clause 3.2 of IS:8686).

11. **Mandatory Testing & Maintenance Equipment**

Print testing kit for PLCC terminal, E/M interface & subscriber unit, Protection coupler & EPAX —

comprising of following items of reputed make in addition to any other special items required for testing and maintenance of this equipment packed in a carrying brief case:

- 1. Screw driver set with multi up fixing feature
- 2. Nose pliers
- 3. Cutting pliers
- 4. Ordinary Pliers
- 5. Adjustable wrench
- 6. Soldering iron with tip earthed
 - a) 150 watts - 1 No.
 - b) 35 Watts - 1 No
 - c) 10 watts - 1 No.

operated with isolated (step down) transformer having provision for interchangeable taps.

- 7. Desoldering pump
- 8. Print extender
- 9. Print puller
- 10. Large selection of test leads

11. Solder wire
12. Large selection of plugs, jacks & pistol probes compatible with equipment supplied
13. Dummy load
14. Interface card/print for Tx to Rx loop-back
15. Test oscillator/tone generator with indicating meters - either built in or separate
16. ESD wrist band
17. ESD conducting mat

12. **LIST OF COMMISSIONING TESTS**

The following tests shall be carried out on complete system/subsystem during commissioning:

1. Composite loss and return loss on coupling device using dummy load.
2. Composite loss (Attenuation) for HF Cable coupling device.
3. End to end attenuation measurement for verification of optimum coupling mode. Test shall be done for all combinations.
4. End to end return loss for optimum coupling mode.
 - a. open behind line trap.
 - b. grounded behind line trap.
5. If end to end return loss for optimum coupling mode is not satisfactory, same shall be measured for other coupling modes also.
6. Adjustment of Tx/Rx levels on PLCC equipment as per test schedule.
7. AF frequency response (end to end) for the entire 4 kHz Bandwidth for speech and teleoperation channels.
8. Measurement of noise in 2 kHz bandwidth with and without line energised.

9. SNR (test-one) with line energised noting down weather conditions.
10. Transmission time for teleprotection and other data channels.
11. Observation of Tx/Rx levels (test-tone) for each channel at both ends by sequential switching on/off parallel channels using dummy load and also with the transmission line.
12. Observation of end to end and trunk dialing performance.
13. Observation of end-to-end protection signaling (command sent & received) in conjunction with protective relays, noting down transmission/receipt of unwanted commands under switching operations in the switchyard during protective relay testing.

Notes

1. All measurements for link attenuation, composite loss and return loss shall be carried out for the entire range of carrier frequencies with specific attention to the frequencies.
 - i. within coupling device bandwidth.
 - ii. within line trap bandwidth, and
 - iii. operating frequencies.
2. Following tests shall be carried out independently at each and
 - i. Composite loss & return loss for coupling device.
 - ii. Attenuation test for HF cable + coupling device.
 - iii. Levels and other local adjustments (on dummy load).
Final adjustment shall be on end to end basis.
 - iv. Test for loading by parallel channels with dummy load.
This test can be done alongwith tests for coupling device.
 - v. Protection signaling under local loop test (dummy load).
3. Necessary test instruments required for all the above tests shall be brought by commissioning engineers of the contractor.

Specification of Digital Protection Coupler

SPECIFICATION FOR DIGITAL PROTECTION COUPLER

1.0 Digital protection coupler for protection signalling through optical fibre cable system.

- 1.1 The Digital protection signalling equipment is required to transfer the trip commands from one end of the line to the other end in the shortest possible time with adequate security and dependability. It shall also monitor the healthiness of the link from one end to the other and give alarms in case of any abnormality. The protection signalling equipment shall have a proven operating record in similar application over EHV systems and shall operate on 48V DC (+15%/-20%). It shall provide minimum four commands. These commands shall be suitable for Direct tripping, Intertripping and Blocking protection schemes of EHV lines.

The protection signalling equipment shall communicate to the remote end interfacing with SDH terminal equipment at its 2Mbps port. It shall provide suitable interfaces for protective relays, which operate at 220V DC. Power supply points shall be immune to electromagnetic interface.

1.2 Principle of operation

During normal operation, protection signalling equipment shall transmit a guard signal/code. In case Protection signalling equipment is actuated by protective relays for transmission of commands, it shall interrupt the guard signal/code and shall transmit the command code to the remote end. The receiver shall recognize the command code and absence of the guard code and will generate the command to the protective relays.

All signal processing i.e. generation of tripping signal and the evaluation of the signals being received shall be performed completely digital using Digital Signal Processing techniques.

1.3 Loop testing

An automatic loop testing routine shall check the teleprotection channel.

It shall also be possible to initiate a loop test manually at any station by pressing a button on the front of the equipment.

Internal test routine shall continuously monitor the availability of the protection signaling equipment.

Proper tripping signal shall always take the priority over the test procedure.

Specification of Digital Protection Coupler

The high speed digital protection signalling equipment shall be designed and provided with following features.

- Shall work in conjunction with SDH terminal equipment.
- It shall communicate on G 703 (E1,2 Mbps)
- Full Duplex operation
- Auto loop facility shall be provided
- Shall meet IEC 60834-1 standard
- Shall be able to transmit upto 4 commands with trip counter simultaneously or sequentially in one 2Mbps channel

Bidder shall quote for protection signalling equipment suitable for 4 commands with separate trip counters for transmit and receive. With regard to trip counters alternate arrangement .i.e. Laptop along with software & all accessories to download events including carrier receipt and transmit shall be acceptable. Laptop for the above shall be supplied at each substation under substation package.

High security and dependability shall be ensured by the manufacturer. Probability of false tripping and failure to trip shall be minimum. Statistical curves/figures indicating above mentioned measures shall be submitted along with the bid.

The DPC can be either housed in offered Control & Protection Panel / PLCC Panel or in separate panel.

Reports of the following tests as per clause 9.2 of Section-GTR shall be submitted for approval for protection signalling equipment and relays associated with the protection signalling equipment and interface unit with protective relay units, if any.

i) General equipment interface tests :

- a) Insulated voltage withstand tests
- b) Damped oscillatory waves disturbance test
- c) Fast transient bursts disturbance test
- d) Electrostatic discharge disturbance test
- e) Radiated electromagnetic field test
- f) RF disturbance emission test

ii) Specific power supply tests

- a) Power supply variations
- b) Interruptions
- c) LF disturbance emission
- d) Reverse polarity

Specification of Digital Protection Coupler

iii) Tele-protection system performance tests

- a) Security
- b) Dependability
- c) Jitter
- d) Recovery time
- e) Transmission time
- f) Alarm functions
- g) Temperature and Humidity tests (As per IEC 68-2)
 - Dry heat test (50°C for 8 hours)
 - Low temperature test (-5°C for 8 hours)
 - Damp heat test (40°C/95%RH for 8 hours)

All the above tests at i, ii & iii (except temperature & humidity tests) shall be as per IEC 60834-1 and the standards mentioned therein.

iv) Relays

- a) Impulse voltage withstand test as per clause 6.1 of IS:8686 (for a test voltage appropriate to clause III as per clause 3.2 of IS:8686)
- b) High frequency disturbance test as per clause 5.2 of IS:8686 (for a test voltage appropriate to clause III as per clause 3.2 of IS:8686)

The protection signalling equipment shall be of modular construction and preferably mounted in the Relay panels. Cabling between the protection signalling equipment & Protection relays and between protection signalling equipment & Communication equipment shall be in the scope of bidder.

The input/output interface to the protection equipment shall be achieved by means of relays and the input/output rack wiring shall be carefully segregated from other shelf/cubicle wiring.

The isolation requirements of the protection interface shall be for 2kV rms.

1.4 Major technical Particulars

The major technical particulars of protection signalling equipment shall be as follows.

- i) Power supply 48V DC +15% /-20%
- ii) Number of commands 4 (four)
- iii) Operating time <7 ms
- iv) Back to back operate time without propagation delay ≤ 8 ms
- v) Interface to Protection relays

Input:

Contact Rating:

Specification of Digital Protection Coupler

Output:	Rated voltage	:	250 volts DC
	Maximum current rating:		5 amps
	Contact Rating:		
	Rated voltage	:	250 volts DC
vi) Alarm contact	Rated current	:	0.1 A DC
	Other parameters :		As per IEC-255-0-20
	Rated voltage	:	250 volts DC
	Rated current	:	0.1 A DC
vii) Digital communication interface:	Other parameters :		As per IEC-255-0-20

Technical Pre-Qualifying Requirements – For SS02 PLCC – Fatehgarh II and Bhadla II

- (i) The manufacturer whose PLCC panels are offered, must have designed, manufactured, tested, supplied and commissioned PLCC panels for 400kV system or above [applicable for 765 kV & 400 kV substation] and the same must have been in satisfactory operation# for atleast two (2) years as on the date of NOA.
- (ii) Alternatively, the manufacturer, who have established manufacturing and testing facilities in India and not meeting the requirement stipulated in (i) above, can also be considered provided that
 - a) PLCC panels must have been manufactured in the above Indian works based on technological support of collaborator, type tested (as per IEC/IS standard) and supplied as on the date of NOA.
 - b) collaborator shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s) and this performance guarantee shall be in addition to contract performance guarantee to be submitted by the contractor.
 - c) The collaborator meets the requirements stipulated in (i) above. A valid collaboration agreement for technology transfer/license to design, manufacture, test and supply PLCC panels in India, shall be submitted.

Notes:

#: satisfactory operation means certificate issued by the Employer/Utility certifying the operation without any adverse remark.

Date of NOA is 05 Nov 2019.

Prepared By: Nishant Singh (Sr Engineer)

Checked By: Sanjeev K. Shrivastava (DGM)

Approved By: Aruna Gulati (AGM)