

	PROJECT: 4X225 MW ARUN-3 HEP NEPAL PRE-QUALIFICATION REQUIREMENT- HVAC SYSTEM.	PE-PQ-437-571-11000-A001	
		DATE	20.10.2020
		REV NO	00

1.0	Bidder shall have designed, manufactured/supplied and tested ventilation system comprising of at least three (3) nos. of centrifugal fans along with associated ducting work in last 20 years and should be in successful operation for at least 2 years in last 7 years as on 09.02.2018 meeting below installation criteria a) for two underground power house of station capacity of 200 MW and above. Or b) for any industrial complex with total working system capacity of minimum 350000 CMH.
2.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement Copy of performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S.No.1.0 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
6.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
7.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

Prepared By

Reviewed By

Approved By