

BHEL-PEM-MAUX PRE-QUALIFICATION CRITERIA			
	PROJECT: 2X660 MW KORADI STP (UNITS-11&12) PACKAGE: AIR CONDITIONING SYSTEM PRE-QUALIFICATION REQUIREMENT (TECHNICAL)	PE-PQ-527-553-A001	
		DATE	19.08.2026
		REV NO.	00

Sl. No.	DESCRIPTION
1.0	The Bidder should have designed, supplied, erected and commissioned at least one (1) number of Air conditioning system having a total installed capacity of 300TR or more including stand-by chiller unit (if any), which should have included at least one chilling unit with a minimum capacity of 60TR. The system should have been in successful operation for at least one (1) year from the date of commissioning/completion/ handover as on date of techno commercial bid opening.
2.0	Bidder has to submit following supporting documents meeting above mentioned pre-qualifying requirement Copy of minimum one (1) performance certificate from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S.No.1.0 above.
3.0	Sub-supplier Qualification Requirement for chiller: The chiller unit(s) (Screw/ VAM) proposed to be supplied for this package shall be sourced from the manufacturer(s) who have manufactured and supplied at least one (1) no. of Screw/VAM chiller unit each having a capacity of not less than 150 TR, which should have been in successful operation for at least one (1) year as on date of techno commercial bid opening. Bidder has to furnish a confirmation to meet above sub-supplier Qualification Requirement in prescribed format attached in Section II of tender specification. However, required documents (as mentioned against Sr. no. 2 above) for establishing chiller provenness shall be furnished by successful bidder after placement of order.
Notes	
a	BHEL reserves the right to seek approved design documents from bidders to substantiate technical parameters as specified in clause 1 above.
b	Bidder to submit all supporting documents in Hindi and/or English as required. If documents submitted by bidder are in language other than that specified above, a translated copy of the same, in above language(s) shall be submitted by the bidder. In such case, for purposes of interpretation, the translated version shall govern. The translation of the documents shall be carried out by professional translators and the translator shall certify that he is proficient in both languages in order to translate the document and that the translation is complete and accurate. Further, in case the supporting documents are issued outside India, same shall be authenticated by the Indian Consulate located in the Country where the documents have been issued or the Embassy of that Country in India.
c	In case the PO/ LOI /LOA/ WOs is more than ten (10) years old as on date of bid opening, minimum one (1) no. additional Purchase order (for similar jobs) shall be submitted which should not be more than ten (10) years old as on date of bid opening, for establishing continuity in business.
d	Notwithstanding anything stated above, BHEL/End customer/Owner reserves the right for physical assessment of the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/ End customer/Owner.

BHEL-PEM-MAUX PRE-QUALIFICATION CRITERIA			
	PROJECT: 2X660 MW KORADI STP (UNITS-11&12) PACKAGE: AIR CONDITIONING SYSTEM PRE-QUALIFICATION REQUIREMENT (TECHNICAL)	PE-PQ-527-553-A001	
		DATE	19.08.2026
		REV NO.	00

e	Consideration of offer shall be subject to End customer/Owner's approval of bidder.
f	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all other terms of the tender.
g	Bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.