

**4.3 Stone Aggregate paving**

- 4.3.1 Entire switch yard shall be provided with 75 mm paving of 40 mm single size stone aggregate on top and 75 mm paving of 20 mm single size stone aggregate below. Before laying the paving, the ground surface shall be treated with anti weed chemicals as per manufacturer recommendations.