

ANNEXURE-B

SCOPE, SPECIFIC TECHNICAL REQUIREMENTS & QUANTITIES

1.1 SCOPE

This technical specification covers the requirement of design, manufacture, testing at works, packing and dispatch of Cable Glands.

1.2 SPECIFIC TECHNICAL REQUIREMENTS

Cable glands shall be made of brass duly electro tinned in order to avoid corrosion and oxidation of the surface. The nipple threads shall be in accordance with IS 1653/ IEC. Glands shall provide neat, tight, dust and vermin proof termination. Gland shall be provided with rubber ring to hold the cables firmly when check-nut is slightly tightened. Gland shall be complete with suitable washers etc (Type-CGT)