



Phase assignment			
Client designation			
L1	=	A	= B
L2	=	B	= Y
L3	=	C	= R

For ventilation of SF6 switchgear hall pay attention to IEC 61936-1, section 8.8.2 and to national valid instructions off accident preventions at SF6 switchgear.

SCALE: 1 : 50

GIS MANUFACTURER:
SIEMENS LTD.
AURANGABAD, INDIA

R0	FIRST SUBMISSION	29.08.2019	GQ	GQ	SM
REV	DESCRIPTION	DATE	DRN.	CHD.	APD
		UTTAR PRADESH POWER TRANSMISSION CORP. LTD. 400/220/132KV GIS at RASRA BALLIA LOI No: 336/ESD-765KV/10 RASRA/vol-3 dated 03.07.2018			
		BHARAT HEAVY ELECTRICALS LTD. P.O. NUMBER P.O. DATE			
		DOCUMENT NO. – (1)-G71770-AD309-V023 - SH 02 OF 04			
TITLE :		220KV GIS LAYOUT - SECTION VIEW			REV. R0