

PRE-QUALIFICATION REQUIREMENT			
TENDER REFERENCE NO. : 12300988			
TENDER DESCRIPTION : ESP SWITCHGEAR FOR 2X800MW NTPC TELANGANA STPP (ESP PACKAGE)			
Technical PQR			
PROVENESS REQUIREMENT FOR LV SWITCHGEAR			
1. Bidder/ Sub Vendor should have manufactured and supplied at least a total of four hundred & fifty (450) nos. draw out type Air Circuit Breaker Panels and / or draw out Motor Control Centre Panels complete in all respects with fault rating of at least 45kA for 1 sec. and 105kA (peak) under a single order and these panels should have been in successful operation for a period of not less than two (2) years prior to the date of Techno-Commercial bid opening.			
2. Bidder/ Sub Vendor should have manufactured and supplied at least one hundred & fifty (150) nos. of Air Circuit Breakers having fault rating of at least 105 kA MAKING and 45 kA BREAKING, and their associated draw out Circuit Breaker Panels having fault withstand of at least 45kA for 1 second, which should have been in successful operation for a period of not less than two (2) years prior to the date of Techno-Commercial Bid Opening.			
Note: Each Single Front Panel shall be counted as one (1) Panel, Double Front Panel as one (1) Panel and Air Circuit Breaker Panel as one (1) Vertical Panel.			
SUB-QUALIFYING REQUIREMENTS DATA TO BE FILLED IN TO MEET THE PROVENESS REQUIREMENTS FOR LT SWITCHGEARS			
S. No.	Item Description - LT SWITCHGEAR	Details to be filled	
1.1	No. of draw out type Air circuit breaker panels and/or draw out motor control centre panels manufactured and supplied complete in all respects, under a single order, with fault rating of at least 45 kA (rms) for 1 sec and 105 kA (peak) which are in successful operation for a period of not less than two years prior to the date of Techno- Commercial bid opening.		
1.2	No. of Air circuit breakers having fault rating of at least 105 kA making and 45 kA breaking and their associated draw out circuit breaker panels having fault withstand of at least 45 kA for 1 second which are in successful operation for a period of not less than two (2) years prior to the date of Techno-commercial bid opening.		
Note: 1) Certificates from the client for the successful operation for each of the above shall be Submitted. 2) Supporting documents/ reference data as applicable shall be submitted.			
Financial PQR:			
For qualification, bidder should have average minimum Annual Turnover as per following details:			
Sr. No.	Details of requirement	Turnover FY	Turnover Value (in Rs. Crore)
1.	AVERAGE ANNUAL TURNOVER DURING THE LAST THREE FINANCIAL YEARS (2017-18,2016-17, 2015-16) (QUALIFYING VALUE – Rs. 12.00 Crore)	2017-18	
		2016-17	
		2015-16	
		Average	
Supporting documents like Financial standing through latest ITCC, Annual Report (Audited Balance Sheet and Profit & Loss Account) of past three years to be submitted by vendors.			