

Qualification Criterion**Annexure-E**

Sl. No.	Qualifying Criterion (ESSENTIAL)	Documents in support of PQR Condition
1	Bidder should have qualified aluminium welder. (Please submit certificate from any reputed & recognized agency like NTPC, Lloyd's Register as per standard)	Agency certificates attached
2	Bidder should have done have done busduct / aluminium fabrication work of 100 MT during last year as have done average fabrication of 100 MT (EC Grade AL Sheet/Plate of thickness NOT less than 4.78 mm) during past 3 years. (Please attach copy of PO's with scope of work)	PO and certificates attached
3	Bidder should have capacity to roll Al. sheet & Plates thickness up to 16 mm and minimum 3000 mm long with positive and negative flaring (4.78 mm to 16 mm Aluminium EC Grade). Also provision for mechanized edge bending and re-rolling should be available.	CONFIRMED
4	Bidder to submitt solvency certificate of Rs. 25 Lacs from any scheduled Bank.	CONFIRMED
5	Bidder should have following machineries and tools: 1. TIG welding machine (350 Amps - 600 Amps) 2. MIG Welding machine (350 Amps - 500 Amps) 3. Should have all required machinery (TIG / MIG welding machine, Compressor, Rolling Machine, Overhead Crane/Hoist - 3 MT, Radial Arm Drilling Machine, Bending Machine, All Hand tools like Grinders, Sanders, Circular Saws, Jig Saws, Drill Machines etc.)	CONFIRMED
6	Bidder should have covered work shop of at least 5000 square feet area.	CONFIRMED
Note:-	1. If required BHEL will do the inspection / assesment of works of Non PMD bidders before clearance of their technical bid. After successful qualification their offer will be considered for further processing. In case of disqualification their offer will not be considered for further action. 2. Bidder who fails to qualify any one of the above conditions from sl. no. 1 to 6, his offer shall be rejected without assigning any reasons whatsoever.	
Signature of Bidder (with Office seal)		