



Bharat Heavy Electricals Limited
ELECTRIC & PHOTOVOLTAIC DIVISION, Bangalore – 560 012

Control Panel Business Group

Doc. No. EP-CPBG-PQR-NSPBD-001

REV.001

DATE: 11.07.2019

Documents to be submitted as against pre-qualification requirement

SL.NO.	PRE-QUALIFICATION REQUIREMENT	DOCUMENTS TO BE SUBMITTED
1	Vendor shall be original manufacturer for 415V LT non segregated phase bus duct.	Factory registration certificate, manufacturing facility/machinery list and testing facility/equipment list
2.	Vendor shall have complete in-house manufacturing and routine testing facility	
3.	Vendor/Bidder shall have valid type test certificate as mentioned below for rating 1600A & above. a. Short circuit type test (50KA for 1Sec.) b. Heat Run test/Temperature rise test. c. Degree of protection IP-55.	a. Short circuit type test (50KA for 1Sec.) b. Heat Run /Temperature rise type test. c. Degree of protection IP-54/55
4.	Vendor must have supplied at least 300 meter of non-segregated phase bus duct(NSPBD) rating 1600A and above comprise of maximum 3 orders in last 5 years and each order must have minimum 50 meter quantity.	Purchase order copy along with approved GA drawing clearly indicating the length of the bus duct 'or' Purchase order copy along with customer MDCC clearly indicating the length of the bus duct.
5.	The manufacturer must have <i>ISO 9001</i> certification and quality plan for design, manufacturer and testing of NSPBD.	ISO 9001 Certificate indicating manufacturing of LT bus duct/Bus trunking system

Submitted

Not Submitted

Submitted


Not Submitted

Submitted

Not Submitted

Submitted

Not Submitted

Prepared by:-

SAURABH RUNGTA
Sr. Engineer/CPBG-ENGG

Reviewed & Approved by:

P.DURAIPPANDI
SR. MANAGER/CPBG ENGG