



A	C01	ST. PANEL FOR DEMANDING PUMPS	500	400	350	70	-	1	HPE	
	C02	ST. PANEL FOR DEMANDING PUMPS	1600	400	1500	50	-	1	HPE	
	C03	MISCELLANEOUS SERVICE BOARD (WALL MOUNT)	1000	1000	1400	-	2	HPE		
	C04	FIRE PROTECTION PANEL	3000	1000	2300	-	-	-	-	
	C05	GPS BASED TIME SYNCHRONIZATION SYSTEM	750	750	2255	-	1	EDN		
	C06	UPS	3000	1250	2320	-	-	1	EDN	
	C07	OPERATOR CONTROL DESK FOR OWS	1800	1250	825	600	-	2	EDN	
	C08	EMS PC TABLE	1270	160	760	100	-	1	EDN	
	C09	OTHER PC TABLE	1050	900	900	100	-	2	EDN	
	C10	PRINTER CONSOLE FOR PRINTERS	1000	800	800	-	-	1	EDN	
B	C11	LVS	-	-	-	-	-	1	EDN	
	C12	11 K.V. SWITCH GEAR W/MT	10X520	2150	2692	-	-	1	SWE	
	C13	MISC SERVICE BOARD (WALL MOUNTED)	1000	300	1400	-	-	1	HPE	
	C14	PROTECTION PANEL 11NO	750	800	2312	-	-	10	TBG	
	C15	B.C.U	800	800	2312	-	-	6	TBG	
	C16	AUX PANEL	800	800	2312	-	-	1	TBG	
	C17	PLCT	800	600	200	-	-	2	TBG	
	C18	EMP (CUSTOMER SUPPLIED)	800	800	2312	-	-	5	TBG	
	C19	EPAX (WALL MOUNTED)	800	500	-	-	-	1	TBG	
	A	C20	GENERATOR PROTECTION PANEL	2000	1000	2350	-	-	2	SWE
C21		R/U PANEL S	1500	600	600	-	-	-	1	UJVN
C22		PANEL FOR REDUNDANT PUMPS	1500	600	-	-	-	-	-	-
C23		PANEL FOR REDUNDANT PUMPS	1500	600	-	-	-	-	-	-

L01	LDB PANEL WITH 100 KVA ITR (MDB-3)	2000	1200	2200	-	1	PEM
L02	LDB PANEL WITH 50 KVA ITR (MDB-6)	2000	1200	2200	-	1	PEM
L03	STATION SERVICE BOARD (SSB-1 & SSB-2)	14600	1200	2500	-	1	HPE
L04	UAB1 UAB2	5100,4100	1200	2500	-	1	HPE
L05	1000 KVA STATION SERVICE TRANSFORMER	2500	2300	2600	5000	2	JHS
L06	LDB PANEL WITH 100 KVA TRFR (MLDB-4)	2000	1200	2200	-	1	PEM
L07	LDB PANEL WITH 50 KVA TRFR (MLDB-7)	2000	1200	2200	-	1	PEM
L08	DC LDB 6 O/G FIBRS (ELDB-2)	2000	1200	2200	-	1	PEM
L09	PANEL FOR ILLUMINATION SYSTEM	1800	600	2200	-	1	HPE

 भारत हेवी इलेक्ट्रिकल्स लिमिटेड, भोपाल Bharat Heavy Electricals Limited, Bhopal	CONSULTANT		
	—		
	NAME	SIGN	NO. OF DATE 28/08/14 WAT.
DR. P. T. KHAN			
CH. D. C. S. KHAN			

CIVIL GUIDELINES
PLAN AT EL 535.00M