



PROJECT: 2X195 MW MUZZAFARPUR TPP,
STAGE-II

TECHNICAL PREQUALIFYING
REQUIREMENTS FOR VENDOR FOR
VIS FOR ID/FD/PA FAN FOUNDATION

SPECIFICATION NO:PE-TS-358-618-C002

REV.NO. 0

DATE 14/02/2012

SHEET 1 OF 3

**TECHNICAL PREQUALIFYING REQUIREMENTS OF VENDOR
FOR
VIBRATION ISOLATION SYSTEM (VIS)
FOR
ID, FD AND PA FAN FOUNDATION**

SPECIFICATION NO: PE-TS-358-618-C002



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, HRD & ESI COMPLEX
Plot No. 25, Sector 16A
NOIDA, U.P. – 201301



PROJECT: 2X195 MW MUZZAFARPUR TPP,
STAGE-II

TECHNICAL PREQUALIFYING REQUIREMENTS
FOR VENDOR FOR
VIS FOR ID/FD/PA FAN FOUNDATION

SPECIFICATION NO: PE-TS-358-618-C002

REV.NO. 0

DATE 14/02/2012




SHEET 2 OF 3

PROJECT TITLE: 2X 195 MW MUZZAFARPUR TPP STAGE - II

JOB NO. 358 DOCUMENT NO. PE-TS-358-618-C002

BUILDING/SYSTEM: VIBRATION ISOLATION SYSTEM

SUBJECT: TECHNICAL PREQUALIFYING REQUIREMENTS OF VENDOR FOR
VIBRATION ISOLATION SYSTEM FOR ID/FD/PA FAN FOUNDATION.

REV. NO.	PARTICULARS	PREPD. BY	CHECKED BY	APPROVED BY	REMARKS
00	NAME	BR	SKM	HM	
	SIGN				
	DATE	14-02-12	14-02-12	14-02-12	



PROJECT: 2X195 MW MUZZAFARPUR TPP,
STAGE-II

TECHNICAL PREQUALIFYING
REQUIREMENTS FOR VENDOR FOR
VIS FOR ID/FD/PA FAN FOUNDATION

SPECIFICATION NO:PE-TS-358-618-C002

REV.NO. 0

DATE 14/02/2012

SHEET 3 OF 3

TECHNICAL PREQUALIFYING REQUIREMENTS OF VENDOR
FOR VIBRATION ISOLATION SYSTEM (VIS)
FOR ID/FD/PA FAN FOUNDATION

- a. Vendor should have **supplied and commissioned VIS (consisting of steel helical springs and viscous dampers)** for fan (Induced Draft – ID, Forced Draft –FD, Primary Air -PA) foundation or similar machine foundation in power plants or equivalent large sized industrial plants and furnish experience list of at least ten recently executed contracts where such systems have been successfully installed for such applications. The vibration isolation system shall be of proven make and should be in successful operation for ID/FD/PA fan or similar machines for at least two years.
- b. Vendor should have at least two years **design experience** of machine foundations and be able to furnish static and dynamic analysis of the RCC deck slab resting on VIS and supporting the machine. Calculation should establish that no dynamic loads are transferred to the structure supporting the VIS and that the foundation system meets the amplitude and frequency requirement as required by the machine manufacturer. The isolation system and R.C.C. deck slab shall be able to withstand seismic loading in addition to other loadings i.e. dead, live, wind, dynamic etc. Seismic design shall conform to IS: 1893 (Criteria for Earthquake Resistant Design of Structures).
- c. **Performance certificate** from the end user/customer for at least two successfully executed contracts for applying package shall be furnished.