

PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF 1.1 kV COPPER CONDUCTOR, XLPE INSULATED FIRE SURVIVAL CABLES FOR 2 X 520 MW VIZAG TPS.
CONTRACT DURATION	___ MONTHS.
APPROXIMATE COST (NOT TO BE PUBLISHED IN THE WEBSITE)	

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SL NO	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE A MANUFACTURER OF 1.1 kV COPPER CONDUCTOR, XLPE INSULATED FIRE SURVIVAL CABLES.
2.0	BIDDER SHOULD HAVE IN-HOUSE CAPABILITY TO CARRY OUT ALL ROUTINE & TYPE TESTS INCLUDING FIRE SURVIVAL TEST AS PER RELEVANT STANDARDS GIVEN IN TECHNICAL SPECIFICATION. IN CASE FACILITY FOR FIRE SURVIVAL TEST NOT AVAILABLE WITH BIDDER, THEN BIDDER TO HAVE SUITABLE TIE-UP WITH GOVERNMENT LABORATORY.
3.0	BIDDER TO FURNISH A TYPE TESTED DESIGN. THE TYPE TESTS SHOULD HAVE BEEN CARRIED OUT EITHER IN GOVERNMENT LABORATORY OR TESTS SHOULD HAVE BEEN WITNESSED BY CLIENT ON SIMILAR TYPE OF CABLES.
4.0	BIDDER TO FURNISH THE FOLLOWING: (A) LIST OF CUSTOMERS & PURCHASE ORDERS FOR WHICH BIDDER HAS SUPPLIED THE SPECIFIED CABLES IN THE PAST 5 YEARS. (B) TYPE TEST REPORT. (C) ISO CERTIFICATION IF AVAILABLE. (D) TECHNICAL CATALOGUE. (E) CONFIRMATION ON S. NO. 2 ABOVE REGARDING TEST FACILITIES/ TIE-UP DETAILS FOR FIRE SURVIVAL TEST.

NOTES

1.0	BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, NEED NOT SUBMIT CREDENTIALS FOR CRITERIA INDICATED ABOVE.
2.0	AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
3.0	CONSIDERATION OF OFFER WILL BE SUBJECT TO CUSTOMER'S APPROVAL OF BIDDER.