

**BHARAT HEAVY ELECTRICALS LIMITED, HARIDWAR**

Control & Instrumentation Engineering (CIE)

PRE-QUALIFICATION REQUIREMENT

DC OVER LOAD RELAY/DC AUXILIARY RELAY

- A. Application: DC Relay is used in **DC Starter panel**. DC starter panel is required for starting of DC Compound Motors in power plant for pumping oil.

Sr. No.	PRE-QUALIFICATION REQUIREMENTS	VENDOR RESPONSE
1.	Bidder shall be manufacturer or supplier of DC starter panels/DC over load relay / DC Auxiliary relay. In support BIDDER to provide PO(s) copy for supply of total 10 nos. or more DC starter panels/DC relay in last 5 years from Date of Enquiry.	
2.	Bidder must have supplied DC starter panels/DC over load relay / DC Auxiliary relay with at least 2 modules of motor starter with motor current 80A or more. Bidder to provide supporting document.	
3.	Operating voltage of DC overload relay/ Auxiliary relay should be 220V DC. Vendor to confirm.	
4.	Bidder shall confirm to abide by relevant national/international standard (where applicable) for DC relay.	
5.	Completing items, if any, against each item shall be part of supply.	
Note: Bidder to confirm specific compliance wherever asked. BHEL reserves the right to verify information submitted by Bidder. In case the information is found false/ incorrect/ incomplete, the offer shall be rejected.		

MANUFACTURER'S NAME AND ADDRESS			QUALITY PLAN					TO BE FILLED BY BHEL		TO BE FILLED BY BHEL			
BHEL	VENDOR'S NAME	ITEM			QP NO.								
				REV									
		DRG. NO.	AS PER PO										
		SPEC.	AS PER PO										
		REV				Page 1 of 1							
SL. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORDS		AGENCY			REMARKS
										M	B	N	
1	2	3	4	5	6	7	8	9	D	10			11

MANUFACTURER/SUBCONTRACTOR		LEGEND:	FOR CUSTOMER USE	APPROVED BY
		! RECORDS IDENTIFIED WITH 'TICK' SHALL BE ESSENTIALLY INCLUDED BY CONTRACTOR IN QA DOCUMENTATION.		
		M: MANUFACTURER / SUBCONTRACTOR B: BHEL / NOM. INSPECTION AGENCY N: CUSTOMER INDICATE 'P' PERFORM 'W' WITNESS AND 'V' VERIFICATION ALL 'W' INDICATED IN COLUMN 'N' SHALL BE 'CHP' OF CUSTOMER		