

PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF CONTROL VALVES (Pneumatically Operated) WITH SMART POSITIONER & ACCESSORIES FOR BELLARY TPS UNIT#3, 1x700MW - KPCL
CONTRACT DURATION	___ MONTHS.
APPROXIMATE COST (NOT TO BE PUBLISHED IN THE WEBSITE)	

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SL NO	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE DESIGNER & DIRECT MANUFACTURER OF THE CONTROL VALVES WITH ACCESSORIES
2.0	BIDDER TO FURNISH EXPERIENCE CERTIFICATES FOR MIN. 2 YEARS OF TROUBLE FREE OPERATION FROM MINIMUM 2 DIFFERENT END USERS, PREFERABLY FROM POWER PLANT OF RATING 600MW & ABOVE.
3.0	MANUFACTURER SHOULD COMPLY WITH BHEL QUALITY PLAN & SPECIFICATION FOR CONTROL VALVES.(As per Annexure attached) A CONFIRMATION FOR THE SAME SHALL BE SUBMITTED.
4.0	BIDDER TO FURNISH EXPERIENCE LIST/ ORDER EXECUTED IN LAST FIVE YEARS.
5.0	BIDDER SHALL HAVE THE CAPABILITY/REFERENCE OF SUPPLYING CONTROL VALVES WITH <ol style="list-style-type: none">1. ANSI RATING UPTO CLASS-45002. VALVE SIZE UPTO 16 INCH3. SHUTOFF PRESSURES UPTO 470 KG/CM24. DESIGN TEMPERATURES UPTO 400 DEG C5. DIFFERENTIAL PRESSURES UPTO 110 KG/CM2 <i>RELEVANT DOCUMENT IN SUPPORT OF ABOVE SHALL BE SUBMITTED</i>
6.0	BIDDER TO FURNISH TECHNICAL CATALOGUE OF CONTROL VALVES.

NOTES

1.0	BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, NEED NOT SUBMIT CREDENTIALS FOR CRITERIA INDICATED ABOVE.
2.0	AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
3.0	CONSIDERATION OF OFFER WILL BE SUBJECT TO END USER'S APPROVAL OF BIDDER.