


TRANSFORMER DIVISIONAL STANDARDS

B-JS-03

C 604014

BLOCKS & DOVETAIL STRIPS (PRESS BOARD)

TR-25004 B



C 2 OR 3 tk.




FIG. 1

DOVETAIL STRIPS




FIG. 2

BLOCKS (AA 21108): Blocks to be blanked out from precompressed press board strip using Blanking Tool No. 0160048 width of strip to be checked before blanking.
When Calling for blocks on Elec. specification or insulation dry. Specify this drawing & give A, B & C dimensions.

DOVETAIL STRIPS (AA 21109) When Calling for strips on Elec. specification or insulation drawing, Specify this drawing & give "L" dimensions & fig No. Length "L" to Extend above Top Block washer for ease of winding as given here. 1. For helical coil 17% . 2 for R.S. coil 14%.

NOTE:- FOR Details of Stocked strips Refer Sht No. TR 25006 B.

02	DIM A, WAS 38 TO 60.
02	Ravindra Aye.
28	IN FIG. 1 DIMNS. WERE 23.79, 19.39 & 12.24.
28	IN FIG. 2 DIMNS. WERE 23.79, 19.39 & 12.24.
01	IN FIG. 1, DIMNS. 23.79, 19.39 & 12.24 WERE 21.54, 17.14 & 10. IN FIG. 2, DIMNS. 26.10, 21.70 & 12.24 WERE 23.86, 19.46 & 10.
29	

Issued	11/1/94
Appd.	
CHANGES TO BE APPD. BY DIVISIONAL STDS. ENGINEER ONLY.	

Issued by	TRE JS
	D.O.

BHARAT HEAVY ELECTRICALS LTD.
UNIT: JHANSI



Scale

TR 25004 B

REVISIONS