



ANNEXURE A

PROJECT :- 4X270 MW BHADRADRI TPS

BOQ CUM PRICE SCHEDULE

PACKAGE-LT XLPE FIRE SURVIVAL CABLES

NAME OF VENDOR:-

(A) MAIN SUPPLY

1.1 kV Fire Survival cable with stranded, Circular/Circular Compacted/ shaped, plain annealed copper Class-2 conductor, XLPE (GP8) insulation, Polymeric material type-LSZH Inner Sheath, Al Round Wire (applicable for single core cable) / GS Round Wire Armour (applicable for multi core cable) and Polymeric material type-LSZH Outer Sheath. Generally conforming to BS 7846/ BS 6724/ BS 7655 and BHEL specification.

SL NO (1)	ITEM DESCRIPTION BOQ (2)	ITEM CODE (2A)	HSN CODE (TO BE FILLED BY THE BIDDER) FOR EACH ITEM (3)	UOM (4)	ORDERED QUANTITY (5)	LOT 1 QUANTITY (5A)	DRUM LENGTH (5B)	UNIT EX-WORKS PRICE (DULY PACKED) (INR) (6)	TOTAL EX- WORKS PRICE (DULY PACKED) (INR) (7)	FREIGHT CHARGES		TOTAL PRICES (ex works + freight) (INR) (9)	APPLICABLE GST RATE IN % ON (TOTAL EX WORKS + FREIGHT) BOTH (INR) (10)			TOTAL PRICE F.O.R Prices with taxes (INR) (11)
										@ % OF TOTAL EX WORKS (8A)	AMOUNT IN (INR) (8B) = {7X8A}		GST RATE IN % ON (TOTAL EX WORKS + FREIGHT) (10A)	TYPE OF GST APPLICABLE (IGST/CGST + SGST/UTGST) (10B)	TOTAL AMOUNT IN (INR) (10C) [9X10A]	
1.0	1C - 25- ARMoured	507-38007-A		MTR	9500	6500	500									
2.0	1C - 95- ARMoured	507-38071-A		MTR	3500	2500	500									
3.0	1C - 300- ARMoured	507-38009-A		MTR	5000	3500	500									
4.0	3C - 2.5- ARMoured	507-38021-A		MTR	2000	2000	1000									
5.0	3C - 95- ARMoured	507-38023-A		MTR	1500	1000	500									
6.0	12C - 2.5- ARMoured	507-38002-A		MTR	11000	8000	1000									
									GRAND TOTAL		GRAND TOTAL	GRAND TOTAL			GRAND TOTAL	GRAND TOTAL

Points for consideration before filling above price schedule-

- PVC shall be applicable as specified in NIT.
- Vendor to mention HSN Code in specific Column for each item of BOQ.
- In case of discrepancy in GST rate corresponding to HSN code and quoted GST, the evaluation shall be done on quoted price and correct GST rate shall be considered for ordering (limited to quoted FOR Site price)
- Unless the context requires otherwise, in all tenders and tender related documents any reference to taxes such as ED, CST/VAT, Services. Tax etc. shall refer to GST as implemented by GOI w.e.f. 1.07.2017.
- CGST/SGST/UGST/IGST shall be paid at actuals against documentary evidence but restricted to the amount and percentage in the order/contract.
- In case, any GST credit is delayed/denied to BHEL due to non/delayed receipt of goods and/or tax invoice or expiry to timeline prescribed in the relevant Act for availing such ITC, or any other reasons not attributable to BHEL, tax amount shall be recoverable from the vendor/contractor along with interest levied/leviable on BHEL.
- All taxes and duties other than CGST/SGST/UGST/IGST shall be deemed to be included in the Ex-Works prices unless specified otherwise by the bidder in the price bid. No variation in other taxes and duties shall be payable by Purchaser.
- Quantities indicated above shall be known as Order Quantities. The variation in quantities shall be as per NIT.
- Lot-I quantities indicated above shall be cleared for manufacturing along with LOI. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering and site requirements.
- The standard drum length for LT XLPE FS cables shall not be less than mentioned against each cable size above. The length per drum shall be subjected to a maximum tolerance of +/- 5% of the standard drum length.
- Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 1000m, in which case it shall be -5% to 0%. Cables consumed for testing and inspection shall be to bidder's account.
- For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply. The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- Bidder shall indicate unit price of cables inclusive of type test charges. No separate charges shall be payable for type tests.
- In case the quantities cleared by BHEL for manufacturing (in a lot) are manufactured and offered for inspection by successful bidder in more than one lot, BHEL reserves the right to witness type testing on all lots without any price implication.

Zumant