

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 1 of 159

E-TENDER SPECIFICATION

Sl No	E-Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/NTPRT-ESP FGD U1/2199	800 MW PVUNL PATRATU ESP, FGD Unit#01 (Package A)
2	BHE/PW/PUR/NTPRT-ESP FGD U2/2200	800 MW PVUNL PATRATU ESP, FGD Unit#02 (Package B)

PACKAGE-A:

1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, **ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES**, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1.

AND

2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1.

AND

3. Common system of FGD SYSTEM

FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

PACKAGE-B:

1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, **ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES**, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, TOUCHUP PAINTING ETC OF ESP of UNIT#2.

AND

2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#2

FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

VOLUME – I

CONSISTING OF:

- **Notice Inviting Tender**
- **Volume-IA : Technical Conditions of Contract**
- **Volume-IB : Special conditions of Contract**
- **Volume-IC : General conditions of Contract**
- **Volume-ID : Forms & Procedures**
- **Volume-IE : Plot Plan**



Bharat Heavy Electricals Limited
(A Government of India Undertaking)
Power Sector - Western Region
345-Kingsway, Nagpur-440001

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 2 of 159

CONTENTS

Volume No	Description	Hosted in website bhel.com (Briefly) and detailed in BHEL e-Procurement Portal as files titled
NIL	Tender Specification Issue Details	(Part of <u>Vol-IA-Tech Bid-2199-2200</u>)
NIL	Notice Inviting Tender	(Part of <u>Vol-IA-Tech Bid-2199-2200</u>)
I-A	Technical Conditions of Contract	<u>Vol-IA-Tech Bid-2199-2200</u>
I-B	Special Conditions of Contract	Vol-I BCD-Patratu-05.09.2019
I-C	General Conditions of Contract	(Part of Vol-I BCD-Patratu-05.09.2019)
I-D	Forms & Procedures	(Part of Vol-I BCD-Patratu-05.09.2019)
I-E	Plot Plan	Vo I E- Plot Plan
II	Price Bid Specification as specified in E-Procurement Portal	Volume-II-2199

2199-
2200

NOTICE INVITING TENDER

Bharat Heavy Electricals Limited



**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 4 of 159

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Date: 19/09/2019

NOTICE INVITING E-TENDER (NIT)

**NOTE: BIDDER MAY DOWNLOAD/ UPLOAD THE TENDER/ OFFER FROM/ON
BHEL E-PROCUREMENT PORTAL → <https://bhel.abcprocure.com>**

To,
Dear Sir/Madam,

Sub : NOTICE INVITING E-TENDER

Offers are invited in two part bid system from reputed & experienced bidders (meeting [PRE QUALIFICATION CRITERIA](#) as mentioned in Annexure-I) through **E-procurement portal → <https://bhel.abcprocure.com>** only for the subject job by the undersigned on behalf of BHARAT HEAVY ELECTRICALS LIMITED as per the tender documents. Following points relevant to the tender may please be noted and complied with:

Note: ***The bidder should respond by submitting their offer online only in our e-Procurement platform at <https://bhel.abcprocure.com>. No Hard copy bid/ bids through email/ fax shall be accepted.***

1.0 Salient Features of NIT

Sl No	ISSUE	DESCRIPTION
i	E-TENDER NUMBER	BHE/PW/PUR/NTPRT-ESP FGD U1/2199 BHE/PW/PUR/NTPRT-ESP FGD U2/2200
ii	Broad Scope of job	PACKAGE-A: 1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1. <p style="text-align: center;">AND</p> 2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1. <p style="text-align: center;">AND</p> 3. Common system of FGD SYSTEM FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 5 of 159

Sl No	ISSUE	DESCRIPTION	
		<p>PACKAGE-B:</p> <p>1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, TOUCHUP PAINTING ETC OF ESP of UNIT#2.</p> <p align="center">AND</p> <p>2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#2</p> <p align="center">FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND</p>	
iii	DETAILS OF TENDER DOCUMENT		
A	Volume-IA	<i>Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc.</i>	<i>Applicable</i>
B	Volume-IB	<i>Special Conditions of Contract (SCC)</i>	<i>Applicable</i>
C	Volume-IC	<i>General Conditions of Contract (GCC)</i>	<i>Applicable</i>
D	Volume-ID	<i>Forms and Procedures</i>	<i>Applicable</i>
F	Volume-II	<i>Price Bid as specified in E-Procurement Portal</i>	<i>Applicable</i>
iv	Issue of Tender Documents	<p>From https://bhel.abcprocure.com (Tender documents will be available for downloading from BHEL e-Procurement website till due date of submission)</p> <p>Brief information of the tender shall also be available at Central Public Procurement portal (https://eprocure.gov.in) and BHEL website (www.bhel.com).</p>	<i>Applicable</i>
v	DUE DATE & TIME OF OFFER SUBMISSION	<p>Date: 03/10/2019, Time: 15.00 Hrs Place: on E-Tender Portal https://bhel.abcprocure.com</p> <p>• Offer to be submitted online only through e-procurement Portal</p>	<i>Applicable</i>
vi	OPENING OF TENDER (Techno-	<p>Date: 03/10/2019, Time: 16.00 Hrs Notes: (1) In case the due date of opening of tender</p>	<i>Applicable</i>

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 6 of 159

Sl No	ISSUE	DESCRIPTION	
	Commercial Bid)	<i>becomes a non-working day, then the due date & time of offer submission and opening of tenders get extended to the next working day. (2) This tender being an e-tender, it shall be opened online only through the E-Procurement Portal. Participating bidders may witness the Opening online only.</i>	
vii	EMD AMOUNT	Rs. 38,00,000/- (Rupees Thirty Eight Lakhs Only) <i>[To be submitted as described in the NIT below]</i> <i>Important Note: Bidders kindly to take note that EMD (Earnest Money Deposit) shall be furnished by MSE bidders as well, as per the amount and procedure indicated in the NIT/GCC.</i>	<i>Applicable</i>
viii	COST OF TENDER	<i>Rs 2000/-</i> <i>[To be submitted in the form and manner as mentioned below]</i>	<i>Applicable</i>
ix	LAST DATE FOR SEEKING CLARIFICATION	Date: 27/09/2019 <i>Along with soft version also, addressing to undersigned & to others as per contact address given below. Bidders may consider to seek clarifications through email.</i>	<i>Applicable</i>
x	SCHEDULE OF Pre Bid Discussion (PBD)	-	<i>Not Applicable</i>
xi	INTEGRITY PACT & DETAILS OF INDEPENDENT EXTERNAL MONITOR (IEM)	Sh. Arun Chandra Verma, IPS (Retd.) and Sh Virendra Bahadur Singh, IPS (Retd.) (Please refer Annexure-04 "Important Information" of NIT for more details)	<i>Applicable</i>
xii	Latest updates	Latest updates on the important dates, Amendments, Correspondences, Corrigenda, Clarifications, Changes, Errata, Modifications,	

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 7 of 159

Sl No	ISSUE	DESCRIPTION
		Revisions, etc to Tender Specifications will be hosted in BHEL webpage (www.bhel.com -->Tender Notifications →View Corrigendum), Central Public Procurement portal (https://eprocure.gov.in) & on e-tender portal https://bhel.abcprocure.com and not in the newspapers. Bidders to keep themselves updated with all such information.

2.0 The offer shall be submitted as per the instructions of tender document and as detailed in this NIT. Bidders to note specifically that all pages of tender document, including these NIT pages of this particular tender together with subsequent correspondences shall be submitted by them, duly **digitally** signed on all the documents, as part of offer. **Rates/Price including discounts/rebates, if any, mentioned anywhere/in any form in the techno-commercial offer other than the Price Bid, shall not be entertained.**

~~3.0 Unless specifically stated otherwise, bidder shall remit cost of tender and courier charges if applicable, in the form of Demand Draft drawn in favour of Bharat Heavy Electricals Ltd, payable at Power Sector Regional HQ at Nagpur issuing the Tender, along with techno-commercial offer. Bidder may also choose to deposit the Tender document cost by cash at the Cash Office as stated above against sl no iv of 1, on any working day. Copy of Cash receipt or the proof of Demand Draft duly **digitally** signed is to be uploaded with the Techno Commercial offer **on e-tender portal <https://bhel.abcprocure.com>**. However Original Demand Draft shall be sent to the officer inviting tender within a reasonable time failing which the offer is liable to be rejected. Sale of tender Documents shall not take place on National Holidays, holidays declared by Central or State Governments and BHEL PS HQ at _____, Sundays and second/ last Saturdays.~~

4.0 Unless specifically stated otherwise, bidder shall deposit EMD through Demand Draft/Pay Order in favour of Bharat Heavy Electricals Ltd, payable at Nagpur For other details and for 'One Time EMD' please refer General Conditions of Contract. Copy of ~~One Time EMD Certificate~~ or the proof of Demand Draft/Payorder duly **digitally** signed is to be uploaded with the Techno Commercial offer **on e-tender portal <https://bhel.abcprocure.com>**. However Original Demand Draft shall be sent to the officer inviting tender within a reasonable time failing which the offer is liable to be rejected.

In case of remittance of EMD through Electronic Fund Transfer, Bank account details of BHEL PSWR to be used is as below: -

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 8 of 159

NAME OF THE COMPANY	BHARAT HEAVY ELECTRICALS LTD
ADDRESS OF THE COMPANY	SHREE MOHINI COMPLEX 345, KINGSWAY,NAGPUR
NAME OF BANK	STATE BANK OF INDIA
NAME OF BANK BRANCH AND BRANCH CODE	SBI,KINGSWAYBRANCH,BRANCH CODE-00432
CITY	NAGPUR
ACCOUNT NUMBER	31380025872
ACCOUNT TYPE	CURRENT A/C
IFSC CODE OF THE BANK BRANCH	SBIN0000432
MICR CODE OF THE BANK BRANCH	440002002

Above bank account, details can be used for remittance of Security Deposit as well by the successful tenderer.

Procedure for Earnest Money Deposit					
Description / Mode of Submission	EFT	Cash	DD/Pay Order	FDR (Refer GCC clause no 1.9.1(iv) for FDR)	Bank Guarantee (Refer GCC clause no 1.9.1(iv) for Acceptable Portion of EMD in the Form of BG)
Proof of EMD along with the offer			Scan Copy has to be uploaded	Scan Copy has to be uploaded	Scan Copy of BG has to be uploaded.
Submission of EMD to BHEL PSWR, Nagpur	Receipt of Amount Transferred into BHEL Account	Receipt of cash deposit at BHEL office	Original DD/ Pay order to be sent through Registered Post	The Original FDR to be sent through Courier/Post to BHEL PSWR Nagpur.	The Original Bank Guarantee/any extensions /amendments shall be sent directly by the Bank to BHEL under Registered Post (Acknowledgement Due), addressed to the Purchase Department, BHEL PSWR, Nagpur.

In addition to the EFT, Cash, DD/Pay order and Bank Guarantee, Fixed Deposit Receipt (FDR) issued by Scheduled banks / Public Financial Institutions as defined in the Companies Act (FDR should be in the name of the Contractor, a/c BHEL) can also be submitted towards EMD.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 9 of 159

.....

Further, it is to be noted that, the EMD amount in excess of Rs. 2 Lakh may also be accepted in the form of Bank Guarantee from scheduled bank. The Bank Guarantee in such cases shall be valid for at-least six months. (Proforma of Bank Guarantee for Earnest Money shall be as provided in Vol-ID "FORMS & PROCEDURES".)

~~Copy of One Time EMD Certificate or~~ The proof of Demand Draft/ Payorder/FDR or BG or receipt of Electronic Fund Transfer duly **digitally** signed is to be uploaded with the Techno Commercial offer on '**e-tender portal**' → <https://bhel.abcprocure.com>. **In case of Demand Draft/ Payorder/FDR/BG, Original Demand Draft/ Payorder/FDR/BG shall be sent to the officer inviting tender within a reasonable time failing which the offer is liable to be rejected.**

5.0 Procedure for Submission of Tenders:

Procedure for Submission of Tender is available in the "[Bidder Manual for BHEL Bidders](#)" at E-tender portal <https://bhel.abcprocure.com> . Terms and conditions mentioned therein shall form integral part of the NIT and bidders shall abide by the same.

a) Hardware and Software requirements for participating in e-tender:

- ❖ Please refer the website for the minimum system requirements and setting document for Bidders under the link: <https://bhel.abcprocure.com>

b) Digital Signature

- ❖ To know the procedure for obtaining Digital Signature Certificate (DSC), suppliers who are not having the DSC are advised to visit our website www.bhel.com → Tender Notifications → Sample Checklist.

c) M/s E-Procurement Technologies Limited Helpdesk Contacts:

During normal business hours, helpline maintained by the service provider e-Procurement Technologies Limited is available for clarifying any doubts of supplier/s. The helpline numbers are provided in the e-procurement website.

- Mr. Swapnil Hamilton, Support Executive, Ph: +91 7940270549, e-mail ID: swapnil.h@eptl.in
- Mr. Hardik Oza, Support Executive, Ph: +91 7940270560, e-mail ID: hardik.oza@eptl.in
- Mr. Ankur Bhatt, Support Executive, Ph: +91 7940270590, e-mail ID: ankur.bhatt@eptl.in
- Mr. Prashant, Asst. Manager – Implementation & Support, Ph: +91 7940270545, e-mail ID: prashant@eptl.in

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 10 of 159

Note

- i. **Offers/tenders submitted in the E-tender portal shall only be considered for further evaluation. Offers sent by FAX / E-mail / any mode other than E-tender would not be entertained.**

The Tenderers must submit their Tenders, as detailed below:

- PART-I consisting of 'PART-I A (Techno Commercial Bid)' & 'PART-I B (EMD/COST of TENDER)'
- PART-II (Price Bid)

The contents of the offer/tender are as given below. **(All Documents to be digitally signed and uploaded in E-tender Portal)**

SN	Description	Remarks
	Part-I A	
i.	Covering letter/Offer forwarding letter of Tenderer (in the techno commercial compliance sheet provided)	
ii.	Duly filled-in 'No Deviation Certificate' as per prescribed format. Note: a. In case of any deviation, the same should be submitted separately, indicating respective clauses of tender against which deviation is taken by bidder. It shall be specifically noted that deviation recorded elsewhere shall not be entertained. b. BHEL reserves the right to accept/reject the deviations without assigning any reasons, and BHEL decision is final and binding. i). In case of acceptance of the deviations, appropriate loading shall be done by BHEL ii). In case of unacceptable deviations, BHEL reserves the right to reject the tender	
iii.	Supporting documents/ annexure/ schedules/ drawing etc as required in line with Pre-Qualification criteria. It shall be specifically noted that a credential certificates issued by clients shall distinctly bear the name of organization, contact phone no, FAX no, etc.	
iv.	All Amendments/Correspondences/Corrigenda/Clarifications/Changes/Errata etc. pertinent to this NIT.	
v.	Integrity Pact Agreement (Duly signed by the authorized signatory)	If applicable
vi.	Duly filled-in annexures, formats etc. as required under this Tender Specification/NIT	
vii.	Notice inviting Tender (NIT)	
viii.	Volume – I A : Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc	
ix.	Volume – I B : Special Conditions of Contract (SCC)	

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 11 of 159

SN	Description	Remarks
x.	Volume – I C : General Conditions of Contract (GCC)	
xi.	Volume – I D : Forms & Procedures	
xii.	Volume - IE: Plot Plan	
xiii.	Volume – II (UNPRICED – without disclosing rates/price, but mentioning only 'QUOTED' or 'UNQUOTED' against each item	
xiv.	Any other details preferred by bidder with proper indexing.	

PART-I B		
i.	1. Earnest Money Deposit (EMD) in the form as indicated in this Tender OR Documentary evidence for 'One Time EMD' with the Power Sector Region of BHEL floating the Tender 2. Cost of Tender (Demand Draft or copy of Cash Receipt as the case may be) Note: Refer Clause No-3 and 4 of NIT for further details	

PART-II		
ii	Volume II – PRICE BID (Duly Filled in Schedule of Rates – rate/price to be entered in words as well as figures)	

- **SPECIAL NOTE: All documents/ annexures to be submitted should be uploaded in respective places in the E-Tender portal as per the list mentioned given in this NIT. BHEL shall not be responsible for in-complete documents.**

6.0 Void

7.0 Deviation with respect to tender clauses and additional clauses/suggestions in Techno-commercial bid / Price bid shall NOT be considered by BHEL. Bidders are requested to positively comply with the same.

8.0 BHEL reserves the right to accept or reject any or all Offers without assigning any reasons thereof. BHEL also reserves the right to cancel the Tender wholly or partly without assigning any reason thereof. Also BHEL shall not entertain any correspondence from bidders in this matter (except for the refund of EMD).

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 12 of 159

9.0 Assessment of Capacity of Bidders:

Bidder's capacity for executing the job under tender shall be assessed 'LOAD' wise and 'PERFORMANCE' wise as per the following:

- 1 **LOAD:** Load takes into consideration **ALL** the contracts of the Bidder under execution with BHEL Regions, irrespective of whether they are similar to the tendered scope or not. The cut off month for reckoning 'Load' shall be the 3rd Month preceding the month corresponding to the 'latest date of bid submission', in the following manner -

(Note: For example, if latest bid submission is in Jan 2017, then the 'load' shall be calculated up to and inclusive of Oct 2016)

Total number of Packages in hand = Load (P)

Where 'P' is the sum of all unit wise identified packages (refer table-1) under execution with BHEL Regions as on the cut off month defined above, including packages yet to be commenced, excepting packages which are on Long Hold.

- 2 **PERFORMANCE:** Here 'Monthly Performance' of the bidder for all the packages (under execution/ executed during the 'Period of Assessment' in all Power Sector Regions of BHEL) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced shall be taken into consideration. The 'Period of Assessment' shall be 6 months preceding and including the cut off month. The cut off month for reckoning 'Period of Assessment' shall be the 3rd Month preceding the month corresponding to 'latest date of bid submission', in the following manner:

(Note: For example, if 'latest date of bid submission' is in Jan 2017, then the 'performance' shall be assessed for a 6 months' period up to and inclusive of Oct 2016 (i.e. from May 2016 to Oct 2016), for all the unit wise identified packages (refer Table I))

- i). Calculation of Overall 'Performance Rating' for 'Similar Package/Packages' for the tendered scope under execution at Power Sector Regions for the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for all the similar Package/packages', divided by the total number of Package months for which evaluation should have been done, as per procedure below:

- a) $P_1, P_2, P_3, P_4, P_5, \dots, P_N$ etc. be the packages (under execution/ executed during the 'Period of Assessment' in all Regions of BHEL) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced. Total number of similar packages for all Regions = P_T (i.e. $P_T = P_1 + P_2 + P_3 + P_4 + \dots + P_N$)
- b) Number of Months ' T_1 ' for which 'Monthly Performance Evaluation' as per relevant formats, should have been done in the 'Period of Assessment' for the corresponding similar package P_1 . Similarly T_2 for package P_2, T_3 for package P_3 , etc. for the tendered scope. Now calculate cumulative total months ' T_T ' for total similar Packages ' P_T ' for all Regions (i.e. $T_T = T_1 + T_2 + T_3 + T_4 + \dots + T_N$)
- c) Sum ' S_1 ' of 'Monthly Performance Evaluation' Scores ($S_{1-1}, S_{1-2}, S_{1-3}, S_{1-4}, S_{1-5} \dots S_{1-T_1}$) for similar package P_1 , for the 'period of assessment' ' T_1 ' (i.e. $S_1 = S_{1-1} + S_{1-2} + S_{1-3} + S_{1-4} + S_{1-5} + \dots + S_{1-T_1}$). Similarly, S_2 for package P_2 for period T_2 , S_3 for package P_3 for period T_3 etc. for the tendered scope for all Regions. Now calculate cumulative sum ' S_T ' of 'Monthly

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 13 of 159

Performance Evaluation' Scores for total similar Packages ' P_T ' for all Regions (i.e. ' S_T ' = $S_1 + S_2 + S_3 + S_4 + S_5 + \dots S_N$.)

- d) **Overall Performance Rating ' R_{BHEL} ' for the Similar Package/Packages** (under execution/ executed during the 'Period of Assessment') in all the Power Sector Regions of BHEL

$$= \frac{\text{Aggregate of Performance scores for all similar packages in all the Regions}}{\text{Aggregate of months for each of the similar packages for which performance should have been evaluated in all the Regions}}$$

$$= \frac{S_T}{T_T}$$

- e) **Bidders to note that the risk of non-evaluation or non-availability of the 'Monthly Performance Evaluation' reports as per relevant formats is to be borne by the Bidder.**

- f) **Table showing methodology for calculating 'a', 'b' and 'c' above**

Sl. No.	Item Description	Details for all Regions							Total
		(iii)	(iv)	(v)	(vi)	(vii)	(viii)	(ix)	
(i)	(ii)	(iii)	(iv)	(v)	(vi)	(vii)	(viii)	(ix)	(x)
1	Similar Packages for all Regions → (under execution/ executed during period of assessment)	P_1	P_2	P_3	P_4	P_5	...	P_N	Total No. of similar packages for all Regions = P_T i.e. Sum (Σ) of columns (iii) to (ix)
2	Number of Months for which 'Monthly Performance Evaluation' as per relevant formats should have been done in the 'period of assessment' for corresponding Similar Packages (as in row 1)	T_1	T_2	T_3	T_4	T_5	...	T_N	Sum (Σ) of columns (iii) to (ix) = T_T

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 14 of 159

Sl. No.	Item Description	Details for all Regions							Total
		(iii)	(iv)	(v)	(vi)	(vii)	(viii)	(ix)	
3	Monthly performance scores for the corresponding period (as in Row 2)	S ₁₋₁ , S ₁₋₂ , S ₁₋₃ , S ₁₋₄ , ... S _{1-T1}	S ₂₋₁ , S ₂₋₂ , S ₂₋₃ , S ₂₋₄ , ... S _{2-T2}	S ₃₋₁ , S ₃₋₂ , S ₃₋₃ , S ₃₋₄ , ... S _{3-T3}	S ₄₋₁ , S ₄₋₂ , S ₄₋₃ , S ₄₋₄ , ... S _{4-T4}	S ₅₋₁ , S ₅₋₂ , S ₅₋₃ , S ₅₋₄ , ... S _{5-T5}	S _{N-1} , S _{N-2} , S _{N-3} , S _{N-4} , ... S _{N-TN}	-----
4	Sum of Monthly Performance scores of the corresponding Package for the corresponding period (as in row-3)	S ₁	S ₂	S ₃	S ₄	S ₅	...	S _N	Sum (Σ) of columns (iii) to (ix) = S _T

ii). Calculation of Overall 'Performance Rating' (R_{BHEL}) in case at least 6 evaluation scores for 'similar Package/Packages' for the tendered scope ARE NOT AVAILABLE, during the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for ALL the packages, divided by the total number of Package months for which evaluation should have been done. 'R_{BHEL}' shall be calculated subject to availability of 'performance scores' for at least 6 'package months' in the order of precedence below:

- a) 'Period of Assessment' i.e. 6 months preceding and including the cut-off month
- b) 12 months preceding and including the cut-off month
- c) 24 months preceding and including the cut-off month

In case, R_{BHEL} cannot be calculated as above, then Bidder shall be treated as 'NEW VENDOR'. Further eligibility and qualification of this bidder shall be as per definition of 'NEW VENDOR' described in 'Explanatory Notes'.

iii). Factor "L" assigned based on Overall Performance Rating (R_{BHEL}) at Power Sector Regions:

Sl. no.	Overall Performance Rating (R _{BHEL})	Corresponding value of 'L'
1	=60	NA
2	> 60 and ≤ 65	0.4
3	> 65 and ≤ 70	0.35
4	> 70 and ≤ 75	0.25
5	> 75 and < 80	0.2
6	≥ 80	NA

3 'Assessment of Capacity of Bidder':

'Assessment of Capacity of Bidder' is based on the Maximum number of packages for which a vendor is eligible, considering the performance scores of similar packages, as below:

Max number of packages P_{Max} = (R_{BHEL} - 60) divided by corresponding value of 'L', i.e. (R_{BHEL} - 60)/L

Note:

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 15 of 159

- i). In case the value of P_{Max} results in a fraction, the value of P_{Max} is to be rounded off to next whole number
- ii). For $R_{BHEL} = 60$, $P_{Max} = '1'$
- iii). For $R_{BHEL} \geq 80$, there will be no upper limit on P_{Max}

The Bidder shall be considered 'Qualified' as per 'Assessment of Capacity of Bidder' for the subject Tender if $P \leq P_{Max}$
(Where P is calculated as per clause 'T' above)

Note: For the transition period of 1 year (i.e. for all the NITs floated between 11th May 2019 to 10th May 2020), in addition to above, 'Assessment of Capacity of Bidder' shall also be calculated considering 'performance scores' till 36 months as per Sl. no II ii).

Higher of the results obtained out of both shall be considered for 'Assessment of Capacity of Bidder'.

4 Explanatory note:

- i). Similar package means Boiler or ESP or Piping or Turbine or Civil or Structure or Electrical or C&I etc. at the individual level irrespective of rating of Plant and irrespective of whether the subject tender is a single package or as part of combined/composite packages. Normally Boiler, ESP, Piping, Turbine, Electrical, C&I, Civil, Structure etc. is considered individual level of package. For example, in case the tendered scope is a Boiler Vertical Package comprising of Boiler, ESP and Power Cycle Piping (i.e. the 'identified packages as per Table-1 below), the 'PERFORMANCE' part against sl.no. II above, needs to be evaluated considering all the identified packages (i.e. Boiler, ESP and Power Cycle Piping) and finally the Bidder's capacity to execute the tendered scope is assessed in line with III above.

- ii). Identified Packages (Unit wise)

Table-1

Civil	Electrical and C&I	Mechanical
i). Enabling works	i). Electrical	i). Boiler & Aux (All types including CW Piping if applicable)
ii). Pile and Pile Caps	ii). C&I	ii). Power Cycle Piping/Critical Piping
iii). Civil Works including foundations	iii). Others (Elect. and C&I)	iii). ESP
iv). Structural Steel Fabrication & Erection		iv). LP Piping
v). Chimney		v). Steam Turbine Generator set & Aux
vi). Cooling Tower		vi). Gas Turbine Generator set & Aux
vii). Others (Civil)		vii). Hydro Turbine Generator set & Aux
		viii). Turbo Blower (including Steam Turbine)
		ix). Material Management
		x). Others

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 16 of 159

		(Mechanical)
--	--	--------------

iii). Bidders who have not been evaluated for at least six package months in the last 24 months preceding and including the Cut-off month in the online BHEL system for contractor performance evaluation in BHEL PS Regions, shall be considered "NEW VENDOR".

A 'NEW VENDOR' shall be considered qualified subject to satisfying all other tender conditions.

A 'NEW VENDOR' if awarded a job (of package/packages identified under this clause) shall be tagged as "FIRST TIMER" on the date of first LOI from BHEL.

The "FIRST TIMER" tag shall remain till completion of all the contracts against which vendor has been tagged as First Timer or availability of 6 evaluation scores within last 24 months preceding and including the Cut-off month in the online BHEL system for contractor performance evaluation in BHEL PS Regions.

A Bidder shall not be eligible for the next job as long as the Bidder is tagged as "FIRST TIMER" excepting for the Tenders which have been opened on or before the date of the bidder being tagged as 'FIRST TIMER'.

After removal of 'FIRST TIMER' tag, the Bidder shall be considered 'QUALIFIED' for the future tenders subject to satisfying all other tender conditions including 'Assessment of Capacity of Bidders'.

iv). Consequent upon applying the criteria of 'Assessment of Capacity of Bidders' detailed above on all the bidders qualified against Technical and Financial Qualification criteria, if the number of qualified bidders reduces to less than four, then for further processing of the Tender, BHEL at its discretion reserves the right to also consider the bidders who are "not qualified" as per criteria of 'Assessment of Capacity of Bidders' and for this, procedure described in following three options shall be followed:

- a) All the bidders having Overall Performance Rating (R_{BHEL}) ≥ 60 shall be considered qualified against criteria of 'Assessment of Capacity of Bidders'.
- b) If even after using option "a", the number of qualified bidders remains less than four, then in addition to bidders considered as per option "a", "First timer" bidders having average of available performance scores ≥ 60 upto and including the Cut Off month shall also be considered qualified against criteria of 'Assessment of Capacity of Bidders'.
- c) If even after using option "a" and "b", the number of qualified bidders remains less than four, then in addition to bidders considered as per option "a" and "b", "First timer" bidders for whom no performance score is available in the system upto and including the Cut Off month, shall also be considered qualified against criteria of 'Assessment of Capacity of Bidders'.

Note:- In case, the number of bidders qualified against Technical and Financial Qualification criteria itself is less than four, then all bidders (a)- having Overall Performance Rating (R_{BHEL}) ≥ 60 , (b)- "First timer" bidders having average of available performance scores ≥ 60 upto and including the Cut Off month, (c)- "First timer" bidders for whom no performance score is available in the system upto and including the Cut Off month, shall be considered qualified against criteria of 'Assessment of Capacity of Bidders' for further processing of tender.

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 17 of 159

- v). 'Under execution' shall mean works in progress as per the following:
- a. Up to execution of 90% of anticipated Contract Value in case of Civil, MM, Structural and Turbo Blower Packages
 - b. Up to Steam Blowing in case of Boiler/ESP/Piping Packages
 - c. Up to Synchronization in all Balance Packages

Note: BHEL at its discretion can extend (or reduce in exceptional cases in line with Contract conditions) the period defined against (a), (b) and (c) above, depending upon the balance scope of work to be completed.

- vi). Contractor shall provide the latest contact details i.e. mail-ID and Correspondence Address to SCT Department, so that same can be entered in the Contractor Performance Evaluation System, and in case of any change/discrepancy same shall be informed immediately. Login Details for viewing scores in Contractor Performance Evaluation System shall be provided to the Contractor by SCT Department.
- vii). Performance Evaluation for Activity Month shall be completed in Evaluation Month (i.e. month next to Activity Month) or in rare cases in Post Evaluation Month (i.e. month next to Evaluation Month) after approval from Competent Authority. In case scores are not acceptable, Contractor can submit Review Request to GM Site/ GM Project latest by 25th of Evaluation Month or 3 days after approval of score, whichever is later. However, acceptance/rejection of 'Review Request' solely depends on the discretion of GM Site/GM Project. After acceptance of Review Request, evaluation score shall be reviewed at site and the score after completion of review process shall be acceptable and binding on the contractor.
- viii). Project on Hold due to reasons not attributable to bidder -
- a. **Short hold:** Evaluation shall not be applicable for this period, however Loading will be considered.
 - b. **Long hold:** Short hold for continuous six months and beyond or hold on account of Force Majeure shall be considered as Long Hold. Evaluation as well as Loading shall not be considered for this period.
- ix). Performance evaluation in CL 9 above is applicable to Prime bidder and Consortium partner (or Technical tie up partner) for their respective scope of work.

10.0 Since the job shall be executed at site, bidders must visit site/ work area and study the job content, facilities available, availability of materials, prevailing site conditions including law & order situation, applicable wage structure, wage rules, etc before quoting for this tender. They may also consult this office before submitting their offers, for any clarifications regarding scope of work, facilities available at sites or on terms and conditions.

11.0 For any clarification on the tender document, the bidder may seek the same in writing or **through e-mail or through E-tender Portal**, as per specified format, within the scheduled date for seeking clarification, from the office of the undersigned. BHEL shall not be responsible for receipt of queries after due date of seeking clarification due to postal delay

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 18 of 159

or any other delays. Any clarification / query received after last date for seeking clarification may not be normally entertained by BHEL and no time extension will be given.

- 12.0 BHEL may decide holding of pre-bid discussion [PBD] with all intending bidders as per date indicated in the NIT. The bidder shall ensure participation for the same at the appointed time, date and place as may be decided by BHEL. Bidders shall plan their visit accordingly. The outcome of pre-bid discussion (PBD) shall also form part of tender.
- 13.0 In the event of any conflict between requirement of any clause of this specification/ documents/drawings/data sheets etc or requirements of different codes/standards specified, the same to be brought to the knowledge of BHEL in writing for clarification before due date of seeking clarification (whichever is applicable), otherwise, interpretation by BHEL shall prevail. Any typing error/missing pages/ other clerical errors in the tender documents, noticed must be pointed out before pre-bid meeting/submission of offer; else BHEL's interpretation shall prevail.
- 14.0 Unless specifically mentioned otherwise, bidder's quoted price shall deemed to be in compliance with tender including PBD.
- 15.0 Bidders shall submit Integrity Pact Agreement (Duly Digitally/ signed by authorized signatory who signs in the offer), **if applicable**, along with techno-commercial bid. This pact shall be considered as a preliminary qualification for further participation. **The names and other details of Independent External Monitor (IEM) for the subject tender is as given at point (1) above.**
- 16.0 The Bidder has to satisfy the Pre-Qualifying Requirements stipulated for this Tender in order to be qualified. The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of satisfying the Pre-Qualification Criteria specified in this NIT as per Annexure-I (as applicable), past performance etc. and date of opening of price bids shall be intimated to only such bidders. BHEL reserves the right not to consider offers of parties under HOLD.
- 17.0 In case BHEL decides on a 'Public Opening', the date & time of opening of the sealed PRICE BID shall be intimated to the qualified bidders and in such a case, bidder may depute one authorized representative to witness the price bid opening. BHEL reserves the right to open 'in-camera' the 'PRICE BID' of any or all Unsuccessful/Disqualified bidders under intimation to the respective bidders.
- 18.0 Validity of the offer shall be for **six months** from the latest due date of offer submission (including extension, if any) unless specified otherwise.
- 19.0 BHEL reserves the right to decide the successful bidder on the basis of Reverse Auction process. In such case all qualified bidders will be intimated regarding procedure/ modality

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 19 of 159

for Reverse Auction process prior to Reverse Auction and price will be decided as per the rules for Reverse Auction. .

However, if reverse auction process is unsuccessful as defined in the RA rules/procedures, or for whatsoever reason, then the sealed 'PRICE BIDS' will be opened for deciding the successful bidder. BHEL's decision in this regard will be final and binding on bidder.

- 20.0 On submission of offer, further consideration will be subject to compliance to tender & qualifying requirement and customer's acceptance, as applicable.
- 21.0 In case the bidder is an "Indian Agent of Foreign Principals", 'Agency agreement has to be submitted along with Bid, detailing the role of the agent along with the terms of payment for agency commission in INR, along with supporting documents. For the tenders requiring services of Original supplier of equipment/services, offer is preferred from the OEM/Principal. However, if the OEM/Principal insists on engaging the services of an agent, such agent shall not be allowed to represent more than one manufacturer/supplier in the same tender. Moreover, either the agent could bid on behalf of manufacturer / supplier or manufacturer / supplier could bid directly but not both. In case bids are received from both manufacturer / supplier and the agent, bid from agent shall be ignored.
- 22.0 The bidders shall not enter into any undisclosed M.O.U. or any understanding amongst themselves with respect to tender.
- 23.0 Consortium Bidding (or Technical Tie up) shall be allowed only if specified in Pre-Qualifying Requirement (PQR) criteria, and in such a case the following shall be complied with:
- 23.1 Prime Bidder and Consortium Partner or partners are required to enter into a consortium agreement with a validity period of six months initially. In case the consortium is awarded the contract, then the Consortium Agreement between the Prime Bidder and Consortium Partner or partners shall be extended till contractual completion period including extension periods if any applicable.
- 23.2 'Standalone' bidder cannot become a '**Prime Bidder**' or a '**Consortium bidder**' or '**Technical Tie up bidder**' in a consortium (or Technical Tie up) bidding. Prime bidder shall neither be a consortium partner to other prime bidder nor take any other consortium partners. However, consortium partner may enter into consortium agreement with other prime bidders. In case of non-compliance, consortium bids of such Prime bidders will be rejected.
- 23.3 Number of partners for a consortium Bidding (or Technical Tie up) shall be as specified in the PQR.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 20 of 159

-
- 23.4 Prime Bidder shall be as specified in the Pre-Qualification Requirement, else the bidder who has the major share of work.
- 23.5 In order to be qualified for the tender, Prime Bidder and Consortium partner or partners shall satisfy (i) the Technical 'Pre Qualifying Requirements' specified for the respective package, (ii) "Assessment of Capacity of Bidder" as specified in clause 9.0.
- 23.6 Prime Bidder shall comply with additional "Technical" criteria of PQR as defined in 'Explanatory Notes for the PQR'.
- 23.7 Prime Bidder shall comply with all other Pre Qualifying criteria for the Tender unless otherwise specified.
- 23.8 In case customer approval is required, then Prime Bidder and Consortium Partner or partners shall have to be individually approved by Customer for being considered for the tender.
- 23.9 Prime Bidder shall be responsible for the overall execution of the contract.
- 23.10 In case of award of job, Performance shall be evaluated for Prime Bidder and Consortium Partner or partners for their respective scope of work(s) as per prescribed formats.
- 23.11 In case the Consortium partner or partners back out, their SDs shall be encashed by BHEL. In such a case, other consortium partner or partners meeting the PQR have to be engaged by the Prime Bidder, and if not, the respective work will be withdrawn and executed on risk and cost basis of the Prime Bidder. The new consortium partner or partners shall submit fresh SDs as applicable.
- 23.12 In case the prime Bidder withdraws, the whole contract shall be considered cancelled and short closed.
- 23.13 After execution of work, the work experience shall be assigned to the Prime Bidder and the consortium partner or partners for their respective scope of work.
- 23.14 The consortium partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value. In case there are two consortium partners, then each partner shall submit SD equivalent to 0.5% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value. The 100% SD value to be submitted by the consortium partner/(s) shall be remitted before start of work. All the terms & conditions of the SD clause in Vol-IC GCC shall be applicable for this SD except clauses

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 21 of 159

no 1.10.1, 1.10.4 & 1.10.6 of Vol-IC GCC. For “modes of deposit” of this SD, clause no 1.10.3 of Vol-IC GCC shall be applicable.

23.15 In case of a Technical Tie up, all the clauses applicable for the Consortium partner shall be applicable for the Technical Tie up partner also.

24.0 The bidder shall submit/upload documents in support of possession of ‘Qualifying Requirements’ duly self-certified and stamped by the authorized signatory (**through Digital Signature**), as per the format for PQR. In case BHEL requires any other documents/proofs, these shall be submitted immediately.

25.0 The bidder may have to produce original document for verification if so decided by BHEL.

26.0 Order of Precedence

In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below:

- a. Amendments/Clarifications/Corrigenda/Errata etc issued in respect of the tender documents by BHEL
- b. Notice Inviting Tender (NIT)
- c. Price Bid-Volume-II
- d. Technical Conditions of Contract (TCC)—Volume-1A
- e. Special Conditions of Contract (SCC) —Volume-1B
- f. General Conditions of Contract (GCC) —Volume-1C
- g. Forms and Procedures —Volume-1D

It may please be noted that guidelines/rules in respect of suspension of business dealings’, ‘Vendor evaluation format’, ‘Quality, Safety & HSE guidelines’, etc may undergo change from time to time and the latest one shall be followed.

For BHARAT HEAVY ELECTRICALS LTD

Addl. General Manager - Purchase)

Enclosure

01. Annexure-1: Pre Qualifying criteria.
02. Annexure-2: Check List.
03. Annexure-3: Integrity Pact
04. Annexure-4: Important Information.
05. Annexure-5: Declaration for Reverse Auction.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 22 of 159

ANNEXURE - 1

PRE QUALIFYING CRITERIA

E-Tender Specification Number:			
BHE/PW/PUR/NTPRT-ESP FGD U1/2199			
BHE/PW/PUR/NTPRT-ESP FGD U2/2200			
JOB	<p>PACKAGE-A: 1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1.</p> <p align="center">AND</p> <p>2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1.</p> <p align="center">AND</p> <p>3. Common system of FGD SYSTEM FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND</p>		
	<p>PACKAGE-B: 1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION OAND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, TOUCHUP PAINTING ETC OF ESP of UNIT#2.</p> <p align="center">AND</p> <p>2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#2</p> <p align="center">FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND</p>		
S No	PRE QUALIFICATION CRITERIA		
		Applicability	Remarks
A	<p>Submission of Integrity Pact duly signed (if applicable)</p> <p>(Note: To be submitted by Prime Bidder & Consortium /Technical Tie up partner jointly in case Consortium bidding is permitted, otherwise by the sole bidder)</p>		APPLICABLE

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

B	<p><u>TECHNICAL PQR:</u> <u>B.1: Not Applicable</u> <u>B.2: Technical Criteria:</u> B.2.1) Bidder must have executed Erection and Commissioning of at-least One Boiler (Consisting of Structure and Pressure part (of the same unit as standalone Bidder)) / ESP of One Unit of 190 MW or higher rating in the last seven (7) years as on latest date of offer submission. OR B.2.2) Bidder must have executed Erection and Commissioning of at-least One STG of 400 MW or higher rating, under direct order of BHEL in the last seven (7) years as on latest date of offer submission. OR B.2.3) Bidder must have executed One Work of Erection and Commissioning of <u>ESP And/Or Boiler (Consisting of Structure/Non Pressure Parts/Pressure Parts/Rotating Machines)</u> of 13400 MT or higher tonnage (up to boiler Light up) in the last seven (7) years as on latest date of offer submission against single work order. OR B.2.4) Bidder must have executed Two Works of Erection and Commissioning of <u>ESP And/Or Boiler (Consisting of Structure/Non Pressure Parts/Pressure Parts/Rotating Machines)</u>, each of 8400 MT or higher tonnage (up to boiler Light up) in the last seven (7) years as on latest date of offer submission against maximum two work orders. OR B.2.5) Bidder must have executed Three Works of Erection and Commissioning of <u>ESP And/Or Boiler (Consisting of Structure/Non Pressure Parts/Pressure Parts/Rotating Machines)</u>, each of 6700 MT or higher tonnage (up to boiler Light up) in the last seven (7) years as on latest date of offer submission against maximum Three work orders.</p>	APPLICABLE	
C-1	<p><u>Financial TURNOVER</u> Bidders must have achieved an average annual financial turnover (audited) of Rs. 840 Lakhs or more over last three Financial Years (FY) i.e. 2015-16, 2016-17 & 2017-18.</p>	APPLICABLE	

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 24 of 159

C-2	<u>NETWORTH</u> (only in case of Companies) Net worth of the Bidder based on the latest Audited Accounts as furnished for 'C-1' above should be positive.	APPLICABLE	
C-3	<u>PROFIT</u> Bidder must have earned profit in any one of the three financial years as applicable in the last three financial years as furnished for 'C-1' above.	APPLICABLE	
C-4	Bidder must not be under Bankruptcy Code Proceedings (IBC) by NCLT or under Liquidation / BIFR, which will render him ineligible for participation in this tender, and shall submit undertaking to this effect.	APPLICABLE	
D	Assessment of Capacity of Bidder to execute the work as per sl no 9 of NIT (if applicable) The "Assessment of Capacity of Bidders" for this Tender shall be carried out by considering the identified similar package as "ESP".	APPLICABLE	BY BHEL
E	Approval of Customer (if applicable) Note: Names of bidders (including consortium/Technical Tie-up partners in case consortium bidding is permitted) who stand qualified after compliance of criteria A to D shall be forwarded to customer for their approval	APPLICABLE	BY BHEL
F	Price Bid Opening Note: Price Bids of only those bidders shall be opened who stand qualified after compliance of criteria A to E		BY BHEL
G	Consortium tie-ups	NOT APPLICABLE	

Explanatory Notes for Technical Criteria (B):

1. Void.
2. Unless otherwise specified, for the purpose of 'Technical' criteria of PQR (as in 'B' above), the word 'EXECUTED' means achievement of milestones as defined below -
 - a. "ACHIEVEMENT OF PHYSICAL QUANTITIES" as per PQRs.
 - b. "READINESS FOR COAL FILLING" in respect of Mill Bunker.
 - c. "HARGING" in respect of Power Transformers/ Bus Ducts/ "HT/LT Switchgears" / "HT/LT Cabling".
 - d. For C&I works: "SYNCHRONISATION" in case of power project and "WORK COMPLETION of the

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 25 of 159

value as defined in PQR" in case of industry.

e. "BOILER LIGHT UP" in respect of Boiler / CFBC / ESP.

f. "GAS IN" in respect of HRSG.

g. "STEAM BLOWING COMPLETION" in respect of Power Cycle Piping.

h. "HYDRAULIC TEST" of the system in respect of Pressure parts/ LP Piping/CW Piping.

i. "FULL LOAD OPERATION OF THE UNIT" in respect of Insulation work.

j. "SYNCHRONISATION" in respect of STG / GTG.

k. "SPINNING" in respect of HTG.

l. "COMPLETION AND HANDING OVER FOR MECHANICAL ERECTION" in respect of STG Deck and Machine/Equipment foundation.

3. Boiler means HRSG or WHRB or any other types of Steam Generator.

4. Critical/Power Cycle piping means Main Steam, Hot Reheat, Cold Reheat, HP Bypass.

5. For the purpose of evaluation of the PQR, one MW shall be considered equivalent to 3.5 TPH where ever rating of HRSG/BOILER is mentioned in MW. Similarly, where ever rating of Gas Turbine is mentioned in terms of Frame size, ISO rating of the same in terms of MW shall be considered for evaluation.

6. Scope for Capital overhaul of STG shall cover Bearing Inspection work and overhauling of all cylinders of the Turbine.

7. In case the tendered scope is not a Pulverized Fuel Boiler, experience of Oil/Gas Fired Boilers can also be considered.

Common Explanatory Notes:

1. For evaluation of PQR, the credentials of the Bidder alone, and not that of the Group Company shall be considered.

2. Completion date for achievement of the technical criteria specified in the Common QR should be in the last 7 years ending on the 'latest date of Bid Submission' of Tender irrespective of date of the start of work.

3. "Executed" means the bidder should have achieved the technical criteria specified in the Technical criteria of PQR (as in 'B' above) even if the Contract has not been completed or closed.

4. In case the Experience/PO/WO certificate enclosed by bidders do not have separate break up of prices for the E&C portion for Electrical and C&I works (i.e. the certificates enclosed are for composite order for supply and erection of Electrical and C&I and other works if any), then value of Erection & Commissioning for the Electrical and C&I portion shall be considered as 15% of the price for supply & erection of Electrical and C&I, unless otherwise specifically indicated in the PQR.

~~5. Following shall be complied with in case of consortium:~~

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 26 of 159

-
- a. ~~The Prime Bidder and Consortium Partner(s) are required to enter in to a consortium agreement with a validity period of six months initially. Thereafter, the Prime Bidder and Consortium Partner(s) shall certify to BHEL regarding existence and validity of their consortium agreement on six monthly basis.~~
 - b. ~~Prime Bidder and Consortium partners shall be approved by Customer for being considered for the tender (applicable if customer approval is required).~~
 - c. ~~Number of partners including prime Bidder shall be NOT more than 3 (three).~~
 - d. ~~Prime Bidder alone shall necessarily comply with "B1 Technical Criteria" except for mechanical package where B1 criteria is not applicable.~~
 - e. ~~Prime Bidder and Consortium Partner shall together comply with the 'Pre-Qualification Requirements' specified for the respective category of technical requirement as per "B2 technical criteria".~~
 - f. ~~Prime Bidder shall comply with all other Pre-Qualifying criteria for the Tender unless otherwise specified.~~
 - g. ~~All other conditions shall be read in conjunction with clause no 23.0 of NIT.~~
 - h. ~~Prime Bidder shall be the Bidder who has a major share of work.~~
 - i. ~~Prime Bidder shall be responsible for the overall execution of the Contract.~~
 - j. ~~Performance shall be evaluated for Prime Bidder and the Consortium partner for their respective scope of work.~~
 - k. ~~In case the Consortium partner backs out, another consortium partner meeting the QRs, has to be engaged by Prime Bidder and if not, the respective work will be withdrawn and executed on risk and cost basis of the prime bidder.~~
 - l. ~~In case Prime Bidder withdraws, the whole contract shall be considered cancelled and short closed.~~
 - m. ~~After successful execution of one work with a consortium partner under direct orders of BHEL, the Prime Bidder shall be eligible for becoming a 'standalone' bidder for works similar to that for which consortium partner was engaged, for subsequent tenders.~~
 - n. ~~The Consortium partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the Prime Bidder for the total contract value.~~

Explanatory Notes for PQR -C (Financial):

1. Bidder to submit Audited Balance Sheet and Profit and Loss Account for the respective years as indicated against C-1 above along with all annexures.
2. In case audited financial statements have not been submitted for all the three years as indicated against C-1 above, then the applicable audited statements submitted by the bidders against the requisite three years, will be averaged for three years i.e. total divided by three.
3. If financial statements are not required to be audited statutorily, then instead of audited financial statements, financial statements are required to be certified by Chartered Accountant.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 27 of 159

4. **C-2:** Net Worth (Only in case of companies) of the bidder should be positive.
Note: Net worth shall be calculated based on the latest Audited Accounts as furnished for 'C-1' above.
Net worth = Paid up share capital* + Reserves
(* : Share Capital OR Partnership Capital OR Proprietor Capital as the case may be)
5. **C-3:** Bidder must have earned profit in any one of the three financial years as applicable in the last three financial years as furnished for 'C-1' above.
Note: PROFIT shall be PBT earned during any one year of last three financial years as in 'C-1' above.
6. **C-4:** Bidder must not be under Bankruptcy Code Proceedings (IBC) by NCLT or under Liquidation / BIFR, which will render him ineligible for participation in this tender, and shall submit undertaking to this effect.

Annexure A

~~Value of work is to be updated with indices for "All India Avg. Consumer Price index for industrial workers" and "Monthly Whole Sale Price Index for All Commodities" with base month as per last month of work execution and indexed up to three (3) months prior to the month of latest due date of bid submission as per following formula-~~

$$P = R + 0.425 \times R \times \frac{(X_N - X_0)}{X_0} + 0.425 \times R \times \frac{(Y_N - Y_0)}{Y_0}$$

~~Where~~

~~P = Updated value of work~~

~~R = Value of executed work~~

~~X_N = All India Avg. Consumer Price index for industrial workers for three months prior to the month of latest due date of bid submission (e.g. If latest bid submission date is 02-Mar-17, then bid submission month shall be reckoned as March'17 and index for Dec'2016 shall be considered).~~

~~X₀ = All India Avg. Consumer Price index for industrial workers for last month of work execution~~

~~Y_N = Monthly Whole Sale Price Index for All Commodities for three months prior to the month of latest due date of bid submission (e.g. If latest bid submission date is 02-Mar-17, then bid submission month shall be reckoned as March'17 and index for Dec'2016 shall be considered).~~

~~Y₀ = Monthly Whole Sale Price Index for All Commodities for last month of work execution~~

Note: Credentials submitted by the bidder against "PRE QUALIFYING CRITERIAS" shall be verified for its authenticity. In case, any credential (s) is/are found unauthentic, offer of the bidder is liable to the rejection. BHEL reserves the right to initiate any further action as per its internal guidelines.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 28 of 159

ANNEXURE - 2

CHECK LIST

NOTE: - Tenderers are required to fill in the following details and no column should be left blank

1	Name and Address of the Tenderer		
2	Details about type of the Firm/Company		
3.a	Details of Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
3.b	Details of alternate Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
4	EMD DETAILS	DD No: Date : Bank : Amount: <u>Please tick (√) whichever applicable:-</u> ONE TIME EMD / ONLY FOR THIS TENDER	
5	Validity of Offer	TO BE VALID FOR SIX MONTHS FROM DUE DATE	
		APPLICABILITY (BY BHEL)	ENCLOSED BY BIDDER
6	Whether the format for compliance with PRE QUALIFICATION CRITERIA (ANNEXURE-I) is understood and filled with proper supporting documents referenced in the specified format	Applicable/ Not Applicable	YES / NO
7	Audited profit and Loss Account for the last three years	Applicable/ Not Applicable	YES/NO
8	Undertaking for QR C-4	Applicable/ Not Applicable	YES/NO
9	Copy of PAN Card	Applicable/ Not Applicable	YES/NO
10	Whether all pages of the Tender documents including annexures, appendices etc. are read understood and signed	Applicable/ Not Applicable	YES/NO
11	Integrity Pact	Applicable/ Not Applicable	YES/NO

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 29 of 159

12	Declaration by Authorized Signatory	Applicable/ Not Applicable	YES/NO
13	No Deviation Certificate	Applicable/ Not Applicable	YES/NO
14	Declaration for Reverse Auction by Bidder	Applicable/ Not Applicable	YES/NO
15	Declaration confirming knowledge about Site Conditions	Applicable/ Not Applicable	YES/NO
16	Declaration for relation in BHEL	Applicable/ Not Applicable	YES/NO
17	Non-Disclosure Certificate	Applicable/ Not Applicable	YES/NO
18	Bank Account Details for E-Payment	Applicable/ Not Applicable	YES/NO
19	Capacity Evaluation of Bidder for current Tender	Applicable/ Not Applicable	YES/NO
20	Tie Ups/Consortium Agreement are submitted as per format	Applicable/ Not Applicable	YES/ NO
21	Power of Attorney for Submission of Tender/Signing Contract Agreement Power of Attorney of Consortium Partner.	Applicable/ Not Applicable	YES/NO
22	Analysis of Unit rates	Applicable/ Not Applicable	YES/NO

NOTE: STRIKE OFF 'YES' OR 'NO', AS APPLICABLE. TENDER NOT ACCOMPANIED BY THE PRESCRIBED **ABOVE APPLICABLE DOCUMENTS** ARE LIABLE TO BE SUMMARILY REJECTED.

DATE :

AUTHORISED SIGNATORY
(With Name, Designation and Company seal)

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 30 of 159

ANNEXURE-3

INTEGRITY PACT

Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at "BHEL House" Siri Fort, New Delhi – 110049 (India) hereinafter referred to as "The Principal", which expression unless repugnant to the context of meaning hereof shall include its successors or assigns of the ONE PART

And

_____, (description of the party along with address), hereinafter referred to as "The Bidder/ Contractor" which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for

_____. The Principal values full compliance with all relevant laws of the land, rules and regulations and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1 - Commitments of the Principal

- 1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles: -
 - 1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - 1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
 - 1.1.3 The Principal will exclude from the process all known prejudiced persons.
- 1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 31 of 159

Section 2 – Commitments of the Bidder(s)/ Contractor(s)

- 2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
- 2.1.1 the Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he / she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.
- 2.1.2 The bidder(s)/ Contractors(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant Indian Penal Code (IPC) and Prevention of Corruption Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
- 2.1.4 Foreign Bidders (s)/ Contractor(s) shall disclose the name and address of agents and representative in India and India Bidder(s)/Contractor(s) to disclose their foreign principals or associates. The Bidders (s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
- 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

Section 3 – Disqualification from tender process and execution from future contracts

If the Bidder(s)/Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process or take action as per separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors" framed by the Principal.

Section 4 – Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit/ Bid Security.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 32 of 159

-
- 4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to Section 3, the Principal shall be entitled to demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/ Performance Bank Guarantee, whichever is higher.

Section 5 – Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 If the Bidder makes incorrect statement on his subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

Section 6 – Equal treatment of all Bidders/ Contractors/ Sub-Contractors

- 6.1 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors. In case of sub-contracting, the Principal contractor shall be responsible for the adoption of IP by his sub-contractors and shall continue to remain responsible for any default by his sub-contractors.
- 6.2 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section -7 Criminal Charges against violating Bidders/ Contractors/ Sub-contractors

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Sub-contractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section – 8 Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 The Bidder(s)/ Contractors(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s)/ Sib-contractor(s) with confidentiality in line with Non-disclosure agreement.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meeting could have an impact on the contractual relations

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 33 of 159

between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.

- 8.5 The role of IEMs is advisory, would not be legally binding and it is restricted to resolving issues raised by an intending bidder regarding any aspect of the tender which allegedly restricts competition or bias towards some bidders. At the same time, it must be understood that IEMs are not consultants to the Management. Their role is independent in nature and the advice once tendered would not be subject to review at the request of the organization.
- 8.6 For ensuring the desired transparency and objectivity in dealing with the complaints arising out of any tendering process, the matter should be examined by the full panel of IEMs jointly as far as possible, who would look into the records, conduct an investigation, and submit their joint recommendations to the Management.
- 8.7 The IEMs would examine all complaints received by them and give their recommendations/ views to CMD, BHEL, at the earliest. They may also send their report directly to the CVO and the Commission, in case of suspicion of serious irregularities requiring legal/ administrative action. IEMs will tender their advice on the complaints within 10 days as far as possible.
- 8.8 The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.9 IEM should examine the process integrity, they are not expected to concern themselves with fixing of responsibility of officers. Complaints alleging mala fide on the part of any officer of the organization should be looked into by the CVO of the concerned organization.
- 8.10 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant Indian Penal Code/Prevention of Corruption Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.11 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.
- 8.12 The word 'Monitor' would include both singular and plural.

Section 9 – Pact Duration

- 9.1 This Pact shall be operative from the date IP is signed by both the parties till the final completion of contract for successful bidder and for all other bidder 6 months after the contract has been awarded. Issues like warranty / guarantee etc. should be outside the purview of IEMs.
- 9.2 If any claim is made/ lodged during currency of IP, the same shall be binding and continue to be valid despite the lapse of this pact as specified above, unless it is discharged/ determined by the CMD, BHEL.

**BHEL PSWR
Notice Inviting Tender**

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 34 of 159

Section 10 – Other Provisions

- 10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.
- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the reminder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those Bidders/ Contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

For & On Behalf of the Principal

For & On Behalf of the Bidder/ Contractor

(Office Seal)

(Office Seal).

Place-----

Date-----

Witness: _____

Witness: _____

(Name & Address) _____

(Name & Address) _____

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 35 of 159

ANNEXURE-4

IMPORTANT INFORMATION

E -Tender for this work is invited by BHEL PSWR NAGPUR and offer shall be submitted through BHEL e-procurement portal only. All correspondences regarding this tender shall be through E-procurement portal.

Postal Address:

AGM /Purchase BHEL PSWR,
SRIMOHINI COMPLEX, 345 KINGSWAY, NAGPUR 440001, INDIA

Following are the concerned BHEL officials to whom bidders can contact in case of any difficulty:

AGM Purchase, Email: prchiwarkar@bhel.in. Ph: +91 – 712 – 3048 – 633

Dy Manager, E-mail: tapishkhandelwal@bhel.in Ph: 91-712-3048732/ 9010903666

Sr Engineer Purchase, Email: shubh@bhel.in, Ph: +91 – 712 – 3048 – 742

Sr Engineer Purchase, Email: svm@bhel.in, Ph: +91 – 712 – 3048 – 715

- 1. The offers of the bidders who are on the banned list as also the offer of the bidders, who engage the services of the banned firms, shall be rejected. The list of banned firms is available on BHEL web site (www.bhel.com → Tender Notification → List of Banned Firms)**
- 2. Refer Chapter XII of Volume IB Special Conditions of Contract regarding Suspension of Business Dealings: The abridged version of extant 'Guidelines for suspension of business dealings with suppliers/ contractors' has now been uploaded on www.bhel.com on "supplier registration page" at the following link: http://www.bhel.com/vender_registration/pdf/Suspension_guidelines_adbridged.pdf**
- 3. The offers of the bidders who are under suspension as also the offers of the bidders, who engage the services of the banned firms, shall be rejected. The list of banned firms is available on BHEL web site www.bhel.com.**

3.0 Integrity commitment, performance of the contract and punitive action thereof:

3.1. Commitment by BHEL:

BHEL commits to take all measures necessary to prevent corruption in connection with the tender process and execution of the contract. BHEL will during the tender process treat all Bidder(s) in a transparent and fair manner, and with equity.

3.2. Commitment by Bidder/ Supplier/ Contractor:

3.2.1. The bidder/ supplier/ contractor commit to take all measures to prevent corruption and will not directly or indirectly influence any decision or benefit which he is not legally entitled to nor will act or omit in any manner which tantamount to an offence punishable under any provision of the Indian Penal Code, 1860 or any other law in force in India.

3.2.2. The bidder/ supplier/ contractor will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 36 of 159

connection with the award of the contract and shall adhere to relevant guidelines issued from time to time by Govt. of India/ BHEL.

3.2.3. The bidder/ supplier/ contractor will perform/ execute the contract as per the contract terms & conditions and will not default without any reasonable cause, which causes loss of business/ money/ reputation, to BHEL.

If any bidder/ supplier/ contractor during pre-tendering/ tendering/ post tendering/ award/ execution/ post-execution stage indulges in mal-practices, cheating, bribery, fraud or and other misconduct or formation of cartel so as to influence the bidding process or influence the price or acts or omits in any manner which tantamount to an offence punishable under any provision of the Indian Penal Code, 1860 or any other law in force in India, then, action may be taken against such bidder/ supplier/ contractor as per extant guidelines of the company available on www.bhel.com and/or under applicable legal provisions”.

4. **“Pradhan Mantri Kaushal Vikas Yojna:** The contractor shall, at all stages of work deploy skilled/semi-skilled tradesmen who are qualified and possess certificate in particular trade from CPWD Training Institute/Industrial Training Institute/ National Institute of Construction Management and Research (NICMAR), National Academy of Construction, CIDC or any similar reputed and recognized Institute managed/ certified by State/ Central Government. The number of such qualified tradesmen shall not be less than 20% of total skilled/semi-skilled workers required in each trade at any stage of work. The contractor shall submit number of man days required in respect of each trade, its scheduling and the list of qualified tradesmen along with requisite certificate from recognized Institute to Engineer-in-Charge for approval. Notwithstanding such approval, if the tradesmen are found to have inadequate skill to execute the work of respective trade, the contractor shall substitute such tradesmen within two days of written notice from Engineer-in-Charge. Failure on the part of contractor to obtain approval of Engineer-in-Charge or failure to deploy qualified tradesmen will attract a compensation to be paid by contractor at the rate of Rs.100 per such tradesman per day. Decision of Engineer-in-Charge as to whether particular tradesman possesses requisite skill and amount of compensation in case of default shall be final and binding”.
5. **All Statutory Requirements as applicable for this project shall be complied with.**
6. **BHEL Fraud Prevention Policy: “The Bidder along with its associate/ collaborators/ sub-contractors/ sub-vendors/ consultants/ service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.”**
7. **Following clause shall form part of the HSE documents issued under Chapter IX of Volume IB ‘Special Conditions of Contract’**

“In case of any financial deduction made by Customer for lapses of safety other than what is provided elsewhere in the contract, the same shall be charged on back-to-back basis on the defaulting contractor without prejudice to any other right spelt anywhere in the tender /contract”

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 37 of 159

8. Modality Tendering and Ordering Philosophy

- i. This is a combined tender for E & C of 2 units of 800 MW ESP and FGD Package etc. of Unit#01 & Unit#02 at PVUNL Project Patratu.
- ii. Tender specification (Volume I) is common for both units/packages
-Unit#01 (Pkg-A) & Unit#02 (Pkg-B).
- iii. Vol-II Price bid is invited only for Unit#01 (Package-A).
- iv. Unit#01 (Pkg-A) & Unit#02 (Pkg-B) shall be awarded to separate agencies.
- v. **Award of U#1 (Package A) :**
 - 1. L-1 Bidder shall be considered for award of Unit#01 (Package-A).
- vi. **Award of U#2 (Package B) :**
 - 1. For award of UNIT#02 (Package-B), next bidder in the order of their price competitiveness (i.e L-2, then L-3 and hence forth) shall be given an option to match their price/rate, with the Awarded/Finalized price/rates of Unit#01 (Package-A). In case none of the bidders agree to match the Awarded RATE of Unit#01 (Package A), then BHEL may consider awarding the Unit#02 (Package B) to L-1 bidder or opt any other suitable method to finalize Unit#02 (Pkg-B).
 - 2. Price matching philosophy for award of U#2 (Package B) as detailed in sl no. 1 above shall be at BHEL's discretion. BHEL may opt any other suitable method to finalize Unit#02 (Pkg-B)

Package	Package A
TS No.	BHE/PW/PUR/NTPRT-ESP FGD U1/2199
JOB	<p>PACKAGE-A:</p> <p>1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1.</p> <p style="text-align: center;">AND</p> <p>2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1.</p> <p style="text-align: center;">AND</p> <p>3. Common system of FGD SYSTEM FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND</p>

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 38 of 159

Package	Package B
TS No.	BHE/PW/PUR/NTPRT-ESP FGD U2/2200
JOB	PACKAGE-B: 1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, TOUCHUP PAINTING ETC OF ESP of UNIT#2. AND 2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#2 FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

9. **"Performance Guarantee for Workmanship"**: Clause no 2.24 of General Conditions of contract is amended as below:

2.24 PERFORMANCE GUARANTEE FOR WORKMANSHIP

2.24.1 Even though the work will be carried out under the supervision of BHEL Engineers the Contractor will be responsible for the quality of the workmanship and shall guarantee the work done for a period of **18 months commencing from the date of Completion of contract as certified by BHEL Engineer**, for good workmanship and shall rectify free of cost all defects due to faulty erection detected during the guarantee period. In the event of the Contractor failing to repair the defective works within the time specified by the Engineer, BHEL may proceed to undertake the repairs of such defective works at the Contractor's risk and cost, without prejudice to any other rights and recover the same from the Guarantee money.

2.24.2 Release of guarantee money: As per Cl no. 2.24.2 of General Conditions of contract

10. **Delay in 1st submission of SDBG/ PBBG**: SDBG/ PBG is to be furnished by the vendor before start of work. No payment will be released till SDBG/PBG is submitted by the vendor.

However if requested by the vendor, cash recovery equivalent to SDBG/ PBG value to be made from the running bills submitted by the vendor. In such case, recovery of interest calculated @SBI PLR +2% on amount equivalent to SDBG/ PBG value to be made for the gap period (difference between date of start of work and date of submission of BG/ cash recovery).

11. **Compensation in case of Death/ Permanent Incapacitation of Person**: BHEL shall recover the amount of compensation paid to victim (s) by BHEL towards loss of life/ permanent disability due to

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 39 of 159

an accident which is attributable to the negligence of contractor, agency or firm or any of its employee as detailed below:

- a) Victim: Any person who suffers permanent disablement or dies in an accident as defined below.
- b) Accident: Any death or permanent disability resulting solely and directly from any unintended and unforeseen injurious occurrence caused during the manufacturing/ operation and works incidental thereto at BHEL factories/ offices and precincts thereof, project execution, erection and commissioning, services, repairs and maintenance, trouble shooting, serving, overhaul, renovation and retrofitting, trial operation, performance guarantee testing undertaken by the company or during any works/ during working at BHEL Units/ Offices/ townships and premises/ Project sites.
- c) Compensation in respect of each of the victims:
 - (i) In the event of death or **permanent disability** resulting from **Loss of both limbs**: Rs 10,00,000/- (**Rs Ten Lakh**)
 - (ii) In the event of **other permanent disability**: Rs 7,00,000/- (**Rs Seven Lakh**)
- d) Permanent Disablement: A disablement that is classified as a permanent total disablement under the proviso to Section 2(I) of the Employee's Compensation Act, 1923.

12. The clause 2.7.9.1 below is added under the heading "Rights of BHEL" of General Conditions of Contract Volume-IC GCC.

2.7.9.1 Provision of Penalty in case of slippage of Intermediate Milestones:

- i) Two major Intermediate Milestones are mentioned as M1 & M2 in Chapter VI: Time Schedule of Vol IA Technical Conditions of Contract.
- ii) In case of slippage of these identified Intermediate Milestones, Delay Analysis shall be carried out on achievement of each of these two Intermediate Milestones in reference to Form 14.
- iii) In case delay in achieving M1 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value*, limited to maximum 2% of Executable Contract Value, will be withheld.
- iv) In case delay in achieving M2 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value*, limited to maximum 3% of Executable Contract Value, will be withheld.
- v) Amount already withheld, if any against slippage of M1 milestone, shall be released only if there is no delay attributable to contractor in achievement of M2 Milestone.
- vi) Amount required to be withheld on account of slippage of identified intermediate milestone(s) shall be withheld out of respective milestone payment and balance amount (if any) shall be withheld @10% of RA Bill amount from subsequent RA bills.
- vii) Final deduction towards LD (if applicable as per clause 2.7.9 above), on account of delay attributable to contractor shall be based on final delay analysis on completion / closure of contract. Withheld amount, if any due to slippage of identified intermediate milestone(s) shall be adjusted against LD or released as the case may be.
- viii) In case of termination of contract due to any reason attributable to contractor before completion of work, the amount already withheld against slippage of intermediate milestones shall not be released and be converted into recovery.

Executable Contract Value - Value of work for which inputs/ fronts were made available to contractor and were scheduled for execution till the date of achievement of that milestone.

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 40 of 159

13. Acceptance of Bank Guarantee (BG)

Revision in Acceptance of Bank Guarantee (BG) Clause no. 1.10.3 (iii) of Vol I C GCC:

Clause No. 1.10.3 (iii) of Vol IC GCC is revised as below: -

“Bank Guarantee issued by:

a. Any of the BHEL consortium bank listed below:

State Bank of India
ABN Amro Bank N.V.
Bank of Baroda
Canara Bank
Citi Bank N.A.
Corporation Bank
Deutsche Bank
HDFC Bank Ltd.
The Hongkong and Shanghai Banking Corporation Ltd
ICICI Bank Ltd.
IDBI Ltd.
Punjab National Bank
Standard Chartered Bank
State Bank of Travancore
State Bank of Hyderabad
Syndicate Bank

b. Any public sector Bank (other than consortium banks) with a clause in the text of Bank Guarantee that “**It is enforceable at Nagpur, Maharashtra**”.

c. Any private sector banks, with a clause in the text of Bank Guarantee that “**It is enforceable by being presented at any branch of the bank**”.

Note: “Bank Guarantees issued by Co-operative Banks are not acceptable”.

14. Broad Terms & Conditions of Reverse Auction

In continuation to Clause 19.0 of NIT (Notice Inviting Tender) following are the broad terms and conditions of Reverse Auction for which Declaration Proforma by bidder has been given in Annexure 5 of NIT:

BHEL reserves the right to go for Reverse Auction (RA) (Guidelines as available on www.bhel.com) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. Bidders to give their acceptance with the offer for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids, in case BHEL decides to go for RA.

Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit ‘Process compliance form’ (to the designated service provider) as well as ‘Online sealed bid’ in the Reverse Auction. Non-submission of ‘Process compliance form’ or ‘Online sealed bid’

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 41 of 159

by the agreed bidder(s) will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines for suspension of business dealings with suppliers/ contractors (as available on www.bhel.com).

The bidders have to necessarily submit online sealed bid less than or equal to their envelope sealed price bid already submitted to BHEL along with the offer. **The envelope sealed price bid of successful L1 bidder in RA, if conducted, shall also be opened after RA and the order will be placed on lower of the two bids (RA closing price & envelope sealed price) thus obtained. The bidder having submitted this offer specifically agrees to this condition and undertakes to execute the contract on thus awarded rates.**

If it is found that L1 bidder has quoted higher in online sealed bid in comparison to envelope sealed bid for any item(s), the bidder will be issued a warning letter to this effect. However, if the same bidder again defaults on this count in any subsequent tender in the unit, it will be considered as fraud and will invite action by BHEL as per extant guidelines for suspension of business dealings with suppliers/ contractors (as available on www.bhel.com).

As a reminder to the bidders, system will flash following message (in RED color) during the course of 'online sealed bid':

"Bidders to submit online sealed bid less than or equal to their envelope sealed bid already submitted to BHEL"

Note:- In case of enquiry through e-procurement the sealed electronic price bid (e-bid) submitted on BHEL e-procurement portal is to be treated as sealed envelope price bid.

15. PUBLIC PROCUREMENT (PREFERENCE TO MAKE IN INDIA) CLAUSE:

"For this procurement, Public Procurement (Preference to Make in India), Order 2017 dated 15.06.2017 & 28.05.2018 and subsequent Orders issued by the respective Nodal Ministry shall be applicable even if issued after issue of this NIT but before finalization of contract/ PO/ WO against this NIT.

In the event of any Nodal Ministry prescribing higher or lower percentage of purchase preference and/ or local content in respect of this procurement, same shall be applicable."

16. Health Safety and Environment Plan at PVUNL Patratu Site : In the clause no. 9.1 of VOL I B 'SCC', "Document No HSEP:14:Rev 00" is to be read as "Doc no. WRHPP:PVUNL REV 00 dtd 01/05/2018". Bidders to take note of this revised HSE Plan for the subject tender which is provided along with VOL I BCD.

17. Integrity Pact:

(a) IP is a tool to ensure that activities and transactions between the company and its Bidder/Contractors are handled in a fair, transparent and corruption free manner.

BHEL PSWR
Notice Inviting Tender

E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Page 42 of 159

Following Independent External Monitors (IEMs) on the present panel have been appointed by BHEL with the approval of CVC to oversee implementation of IP in BHEL.

SI	IEM	Address	Phone & Email
1	Sh. Arun Chandra Verma, IPS (Retd.)	Flat No. C -1204, C Tower, Amrapali, Platinum Complex, Sector 119, Noida (U.P.)	acverma1@gmail.com
2	Sh Virendra Bahadur Singh, IPS (Retd.)	H. No. B-5/64, Vineet Khand, Gomti Nagar, Lucknow - 226010	vbsinghips@gmail.com

- (b) The IP as enclosed with the tender is to be submitted (duly signed by authorized signatory) along with techno-commercial bid (Part-I, in case of two/three part bid). Only those bidders who have entered into such an IP with BHEL would be competent to participate in bidding. In other words, entering into this pact would be a preliminary qualification.
- (c) Please refer section-8 of the IP for Role and Responsibilities of IEMs. In case of any complaint arising out of the tendering process, the matter may be referred to any of the IEM(s). All correspondence with the IEMs shall be done through email only.

Note:

No routine correspondence shall be addressed to the IEM (phone/ post/ email) regarding the clarifications, time extensions or any other administrative queries, etc. on the tender issued. All such clarification /issues shall be addressed directly to the tender issuing (procurement) department.

For all clarifications/ issues related to the tender, Please contact:

Name: (1) P R Chiwarkar/ AGM (Pur) (2) Tapish Kumar/ Dy Manager (Pur)
Dept.: Purchase Department
Address: Shreemohini Complex, 345 Kingsway, Nagpur-440001
Phone: (LL/ Mobile) (1) 0712-3048633 (2)0712-3048732
Email: prchiwarkar@bhel.in tapishkhandelwal@bhel.in
Fax: 0712-3048699

18. **MSE Vendors:** MSE bidders kindly to take note that EMD (Earnest Money Deposit) shall be furnished by Micro & Small Enterprises (MSE) bidders as well, as per the amount and procedure indicated in the NIT/GCC.
19. **PVC clause no 2.17 of Vol-IC GCC: Applicable**

Revision in Price Variation Compensation Clause no. 2.17 of Vol I C GCC:

Clause No. 2.17.5 of Vol IC GCC is revised as below:-

Base date shall be the calendar month of the mid schedule completion date (i.e. Actual start date + "Scheduled Contractual completion period/2" as per Letter of Intent/ award and/or work order).

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 43 of 159

Clause No. 2.17.9 of Vol IC GCC is revised as below:-

PVC shall be applicable only, during the extended period of contract (if any) after the scheduled completion period and for the portion of work delayed / backlog for the reasons not attributable to the Contractor.

However total quantum of Price Variation amount payable/recoverable shall be regulated as follows:

i. For the portion of shortfall/ backlog not attributable to contractor, PVC shall be worked out on the basis of indices applicable for the respective month in which work is done. Base index shall be applicable as defined in clause 2.17.5

ii. In case of Force majeure, PVC shall be regulated as per (a) or (b) below:

a) Force majeure is invoked during original contract period (i.e. during the period when PVC is not applicable):

1. Base date shall be revised: Revised base date = Previous base date + duration of Force majeure.

2. PVC will be applicable for the work done during extended period when delay is not attributable to contractor. PVC shall be worked out on the basis of indices applicable for the respective month in which work is done with base index as on revised base date”

b) Force majeure is invoked after “base date”/ “revised base date” as the case may be (during extended period when delay is not attributable to contractor) –

1. PVC shall be applicable for the work done after revocation of force majeure.

2. PVC for the work done after revocation of force majeure shall be worked out on the basis of indices applicable for the respective month in which work is done excluding the effect of change in indices during total period of Force majeure(s) invoked after “base date”/ “revised base date” as the case may be. Base index shall be taken as on “base date”/ “revised base date” as the case may be.

However the Clause no **2.17.1 to 2.17.4 & 2.17.6 to 2.17.8** of Vol-IC GCC shall remain unchanged.

**BHEL PSWR
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199
BHE/PW/PUR/NTPRT-ESP FGD U2/2200**

Page 44 of 159

ANNEXURE-5

Declaration for Reverse Auction

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub: Declaration for Participation in Reverse Auction (RA)

Ref: NIT/Tender Specification No:

We declare that we will participate in Reverse Auction (RA) if BHEL decides for that instead of opening the sealed envelope/ E-Procurement Portal Price Bid, submitted by us. We have read all the guidelines of reverse auction available in tender enquiry as well as on www.bhel.com portal. We also declare that during reverse auction:

- ❖ We will submit online sealed bid less than or equal to of our envelope sealed/ E-Procurement Portal price bid already submitted to BHEL along with the offer.

We also declare to submit the "Process Compliance Form" (to the designated service provider) as well as "Online Sealed Bid" in the Reverse Auction, in case BHEL decides to go for that.

Yours Faithfully,

(Signature, Date & Seal of Authorized
Representative of the Bidder)

Date:

2199
&
2200

TECHNICAL CONDITIONS OF CONTRACT (TCC)

BHARAT HEAVY ELECTRICALS LIMITED



BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract - Volume I A

Page 45 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Contents

SI No	DESCRIPTION	Chapter
Volume-IA	Contract specific details	
1	Project Information	Chapter-I
2	Scope of Works	Chapter-II
3	Facilities in the scope of Contractor/BHEL	Chapter-III
	Annexure-2 Approved list of welding electrodes supplier	
4	T&Ps and MMEs to be deployed by Contractor	Chapter-IV
	Annexure 1- BHEL T&P Hire Charges	
5	T&Ps and MMEs to be deployed by BHEL on sharing basis	Chapter-V
6	Time Schedule	Chapter-VI
7	Terms of Payment	Chapter-VII
8	Taxes and Duties	Chapter-VIII
9	Specific Inclusion	Chapter-IX
10	Specific Exclusion	Chapter-X
11	Estimated Weight For Various Systems in Scope of Work (BOQ)	Chapter-XI
12	General	Chapter-XII
13	ESP, FGD, Auxiliaries and Piping	Chapter-XIII
14	Foundation & Grouting	Chapter-XIV
15	Welding, Radiography, NDT, Heat Treatment	Chapter-XV
16	Lining & Insulation	Chapter-XVI
17	Painting	Chapter-XVII
18	Testing, Pre-Commissioning, Commissioning	Chapter-XVIII

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Contents

19	Preservation & Protection of Components	Chapter-XIX
20	Weightages / Factors	Chapter-XX

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter - I: Project Information

INTRODUCTION

1	Project Name	3x800 MW Patratu Vidut Utpadan Nigam Ltd. (PVUNL) Patratu STPP	
2	Plant Site Location	Near Patratu town in Ramgarh district of Jharkhand	
3	Location Co-ordinate		
3.1	Corner name	Latitude	Longitude
3.2	Top Corner	23° 39 ' 00" N	85° 17' 51.5" E
3.3	Bottom Corner	23° 38 ' 12.5" N	85° 17' 27" E
3.4	Left Corner	23° 38 ' 22.5" N	85° 17' 10.6" E
3.5	Right Corner	23° 38 ' 40" N	85° 17' 57" E
4	Nearest Town/City	Patratu -03Kms Ramgarh- 30Kms Ranchi - 37Kms	
5	Nearest Railway Station	Patrat-4Kms	
6	Nearest Airport	Ranchi-45Kms	
7	Nearest Seaport	Kolkata-424Kms	
8	Nearest Road Access	Ranchi Patratu Ramgarh Rd	
9	Site Elevation	377M above MSL	
10	Ambient Temperature		
10.1	Mean of Daily Maximum Temperature	40°C (During May)	
10.2	Mean of Daily Minimum Temperature	10.7°C (During December)	
10.3	Wet Bulb Temperature	27°C (Maximum)	
11	Annual Rainfall	311 mm average annually	
12	Wind Speed	0 to 39 Km/Hr	
13	Wind Direction	East North East to West South West	
14	Seismic Zone	Zone III as per IS:1893	

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 48 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter - I: Project Information

The vicinity map of the project is shown below



The Bidder shall visit site and get acquainted himself with the conditions prevailing at site before submission of the bid. The information's given here in under are for general guidance and shall not be contractually binding on BHEL/ Owner. All relevant site data's/information's as may be necessary shall have to be obtained/ collected by the Bidder.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

2.0 SCOPE OF WORK

1) The work to be carried out under the scope of these specifications is broadly as under:

PACKAGE-A:

1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1.

AND

2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1.

AND

3. Common system of FGD SYSTEM

FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

PACKAGE-B:

1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUT LET DUCT UP TO CHIMNEY, LINING & INSULATION, TOUCHUP PAINTING ETC OF ESP of UNIT#2.

AND

2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#2

FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND

2) Erection, alignment and welding, bolting, fastening, grouting as applicable of:

- ✓ Duct supporting structure, ducts, dampers from ESP out let to chimney
- ✓ Handling arrangements for rotating machines for ID fans.
- ✓ Electrostatic precipitator and stairways & galleries
- ✓ Erection, testing, commissioning, trial run and handing over of the FGD system (Mechanical) as per the tender specifications. FGD system mainly consists of Absorber tower along with oxidation blowers, Lime stone grinding and slurry preparation system consist of wet ball mills, lime stone silos, slurry pumps, Gypsum dewatering system, associated piping.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

The scope of work under these specifications for Erection, testing, commissioning, trial operation & handing over of FGD system (Mechanical), broadly consists of but not limited to following:

1. Taking delivery of the materials from the project storage yard /stores /sheds to erection site.
2. Their preservation, safe keeping, watch and ward
3. Checking, dressing, chipping and leveling of foundations.
4. Hydraulic testing, fill test of tanks/vacuum test, air/gas leak test, air tightness test, other pre commissioning tests as per approved quality plan/drawings/ documents. Pre-assembly, if any, pre-erection checks as applicable.
5. Non-destructive examination & post weld heat treatment.
6. Insulation of ESP, FGD & Its auxiliaries ESP to ID fan duct & ID fan to chimney duct.
7. Pre-commissioning checks/ tests, trial runs/ testing and commissioning.
8. Supply and application of paints and touch up painting of erected items
9. Trial operation , GD test and associated tests
10. Making unit ready for PG test and assistance for conductance.
11. Completion of all facilities/ systems
12. Handing over of the unit
13. Providing assistance during commissioning.

2.1 BRIEF DESCRIPTION OF THE FGD SYSTEM

2.1.1 The FGD system shall be based on Wet Limestone Forced Oxidation process. Each unit shall be provided with an independent absorber.

2.1.2 Gas from terminal point on ID fan discharge duct shall be taken directly to the absorber through ID Fans. In the absorber, SO₂ in flue gas shall be removed by a spray of recirculating slurry, pumped by slurry recirculation pumps.

2.1.3 Compressed oxidation air shall be blown through the slurry in the oxidation tank, to oxidize the Calcium sulphite to gypsum.

2.1.4 Clean gas from the absorber shall be taken to the Wet Chimney through three stage mist eliminators.

2.1.5 Limestone to the absorbers of the units shall be supplied by a wet limestone grinding system, common for all 3 units. Limestone shall be fed to the Limestone day silos which in turn will feed the Limestone to wet ball mill through a gravimetric feeder.

2.1.6 The gypsum from the absorber(s) shall be pumped by dedicated gypsum bleed pumps to a common Gypsum Dewatering system consisting of two streams (2x100%) of primary and secondary hydrocyclone and vacuum belt filters for gypsum dewatering. The water removed from the absorber shall be recycled to the absorbers. The waste

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

water from the system shall be collected and neutralized using lime and neutralized effluent shall be pumped at required pressure to waste water terminal point.

2.2 THE BRIEF LIST OF THE MAJOR EQUIPMENT TO BE ERECTED UNDER THE FGD SYSTEM BUT NOT LIMITED TO FOLLOWING:

2.2.1 Absorber System along with supporting structures

2.2.2 Isolation gates

2.2.3 Tanks of various sizes. (Some tanks should be supplied in segments/plates and some in fabricated condition. Agency has to fabricate the tanks from the supplied segments/ plates.

2.2.4 Lime stone grinding and slurry preparation system consist of lime stone silos,

2.2.5 Bunker, Gravimetric feeder, wet ball mills, Hydro-cyclones

2.2.6 Slurry pumps (Absorber Slurry recirculation pumps, Gypsum Bleed pumps, limestone Slurry feed pumps)

2.2.7 Gypsum Dewatering system consists of Vacuum belt filter, hydrocyclones

2.2.8 Process water and cooling water storage system

2.2.9 Thermal Insulation and cladding sheets

2.2.10 Sump Pumps

2.2.11 Piping system

2.2.12 Equipment Cooling water System (PHEs, DMCW pumps)

2.2.13 Misc. platforms, galleries, handrails

2.2.14 Fire Protection System including hydrant, MVWS, HVWS

2.2.15 Equipment Handling System.

2.2.16 Agitators.

2.2.17 EOTs & Hoists.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

2.3 TENTATIVE WEIGHT TO BE ERECTED FOR THE FGD SYSTEM SHALL BE AS DETAILED BREAK UP INDICATED IN CHAPTER-XI “ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE OF WORK (BOQ)”.

2.3.1 The contractor is required to erect actual tonnage (irrespective of any variation plus or minus) which may be necessary to complete their work and commission above system and complete the work in all respects as detailed in tender specifications, for which payments shall be released on finally accepted tonnage rates. The contractor undertakes to erect / commission actual quantities as per instruction of the BHEL Engineer and accordingly the final contract price shall be worked out on the basis of quantities actually erected at site and payments shall also be regulated for the same.

2.3.2 The customer M/s. PVUNL and / or their Consultant may depute their representative for checking and supervision of important stages of work. The contractor shall be required to provide all facilities for inspection of works, without any cost implications to the BHEL. Any defect in quality of work or deviations from drawings / specifications pointed out during such inspection shall be made good by the contractor in the same way as if pointed out by the BHEL Engineer, without any cost implication to BHEL.

2.4 Detailed description of major equipment (per unit & common) to be Installed, Tested and Commissioned under this specification is given below.

Below mentioned details are to give only general idea of FGD system/ equipment's to the bidder. Any equipment's/system's not mentioned in this specification but which are required for the completion and smooth running of the FGD system contractor shall do the erection and commissioning of that system within the finally accepted rates / prices.

Absorber System:

An independent Limestone Forced Oxidation (LSFO) type absorber system shall be provided for each unit. Each absorber system shall be comprises of:

2.4.1.1 Absorber tower complete with re-circulating slurry spray header(s) and nozzles, three stage mist eliminators, wash water nozzles, oxidation tank integral tower, oxidation headers and nozzles, and agitators and all internal systems integral to the working of the absorber.

2.4.1.2 2X100% absorption oxidation blower.

2.4.1.3 2x100% re-circulating slurry pump for each level of spray.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

2.4.1.4 Complete Ducting System from ID fan common outlet duct to absorber tower & from absorber outlet to wet stack chimney.

2.4.1.5 2x100% Centrifugal/ positive displacement type oxidation blowers / compressors

2.4.1.6 1 No. Emergency water tank for spraying water at inlet of Absorber for upset condition.

2.4.1.7 2x100% gypsum bleed pumps.

2.4.1.8 Auxiliary Absorbent tank.

2.4.1.9 Passenger cum Goods elevator for each Absorber of minimum capacity of 1000 kgs.

2.4.2 LIMESTONE GRINDING AND SLURRY PREPARATION SYSTEM (COMMON SYSTEMS FOR ALL THREE UNITS)

2.4.2.1 Limestone grinding system for all the (Three) units and shall comprise of:

2.4.2.2 Two numbers Limestone storage silos shall be complete with supporting steel

2.4.2.3 Structure, platforms, staircase, air canons, power operated gates, gravimetric feeders etc.

2.4.2.4 Two numbers of wet horizontal ball mills.

2.4.2.5 Two (2) limestone slurry tanks complete with all accessories and Agitator(s).

2x100% limestone slurry pumps for each absorber connected to each of the limestone slurry tank. Each pumps catering to slurry requirement of each unit's absorber. Each mill shall be fed from an independent Limestone bunker. Each mill shall be complete with the following items, as a minimum requirement:

a) A bunker outlet gate

b) A gravimetric limestone feeder along with its drive and all other auxiliaries

c) One no. separator tank with agitator(s).

d) 2x100% Mill circuit pump.

e) One set of hydro-cyclone

f) A peripheral/central drives system with motor, speed reducer gearbox and other auxiliaries.

g) An auxiliary motor for inching operation with speed reducer.

h) Complete lubricating system

i) Lube oil pumps, coolers, duplex oil filters, connecting piping

2.4.3 GYPSUM DEWATERING SYSTEM (COMMON SYSTEMS FOR ALL THREE UNITS)

Each set of dewatering equipment (01 working set + 01 standby set) shall comprise of the following Systems as a minimum requirement:

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

- 2.4.3.1** One set of primary hydro-cyclones
- 2.4.3.2** One vacuum belt filter
- 2.4.3.3** Vacuum receiver tank
- 2.4.3.4** Vacuum pump
- 2.4.3.5** One set of secondary hydro-cyclones
- 2.4.3.6** Filtrate tank along with filtrate water pump
- 2.4.3.7** Cake washing Pumps for Vacuum Belt Filter.
- 2.4.3.8** Cloth washing Pumps for Vacuum Belt Filter.
- 2.4.3.9** Waste water tank along with agitator and centrifugal pumps
- 2.4.3.10** Lime neutralization tanks

2.4.4 PROCESS WATER STORAGE TANKS AND PUMPS

- 2.4.4.1** Two (2) Process water Storage tanks along with two numbers of 2x100 % Booster water pumps, if required.
- 2.4.4.2** 2x100% Process Water Pumps for each unit connected to each of the Process water Storage tanks along with all necessary piping, valves.
- 2.4.4.3** 2x100% Mist Eliminator Wash Water Pump for each unit connected to each of the Process water Storage tanks along with all necessary piping, valves.
- 2.4.4.4** Two (2) clarified water Storage tanks (each tank catering to the clarified water requirement for one vacuum Belt Filter) along with two numbers of 2x100 % clarified Booster water pumps, if required, from terminal point.
- 2.4.4.5** Emergency water storage tanks.
- 2.4.4.6** 2x100% horizontal centrifugal pumps shall be provided for recirculation of filtrate water to absorber.
- 2.4.4.7** 2x100% horizontal centrifugal pumps shall be provided for wash water requirements of belt filter.

2.4.5 PIPING

Slurry Piping

- 2.4.5.1** Piping from gypsum bleed pumps to gypsum dewatering system, along with recirculation lines (if required) necessary isolation and control valve Limestone slurry piping to each absorber, along with recirculation lines, all isolation and control valves.
- 2.4.5.2** All connecting pipes / chutes along with necessary valves between various systems of the mill and from hydro-cyclone to common slurry storage. All

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

slurry pipes having Material of construction carbon steel and rubber lined.
End connections are bolted flanged connections.

2.4.5.3 Oxidation Air piping

2.4.5.4 Service Water

2.4.5.5 Service Air & Instrument Air

2.4.5.6 Process water piping

2.4.5.7 Equipment Cooling water system piping

2.4.5.8 Piping and equipment, as per requirement / drawings are to be thermally insulated with bonded / unbounded mineral wool /LRB mineral wool and to be covered with aluminium cladding.

2.4.5.9 All the above systems of piping include the erection of pipes, bends, elbows, valves, fittings, impulse piping and including root valves, sampling lines, drains, hangers and supports & other accessories so as to make the systems complete in all respect.

2.4.6 Equipment Cooling Water System ((COMMON SYSTEMS FOR ALL THREE UNITS)

Equipment Cooling water system for all two units with a closed circuit cooling system for cooling of the various auxiliaries of FGD system. The equipment cooling system shall include the following:

2.4.6.1 2x100% capacity self-cleaning strainers on the secondary side.

2.4.6.2 3 x 50% (2 working + 1 standby) capacity of plate type heat exchangers.

2.4.6.3 4 x 50% (2 Working + 2 standbys) capacity FGD Auxiliary (Secondary) Cooling water pumps, along with drives.

2.4.6.4 3.20.11.5 3 x 50% (2 Working + 1 standby) capacity FGD DM (Primary) cooling water pumps along with drives.

2.4.6.5 One Overhead DM water tank (ECW O/H tank).

2.4.6.6 Alkali (Sodium Hydroxide) preparation tank, agitator and motor, piping, valves etc

2.4.7 Waste water System:

2.4.7.1 2x100% horizontal centrifugal pumps.

2.4.7.2 1x100% Waste water tank shall be provided which shall be sized for 12 hrs storage of waste water.

2.4.7.3 2x100% horizontal centrifugal pumps shall be provided for pumping the waste water from waste water tank.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

2.4.7.4 2x 100% Lime Neutralization tanks.

2.4.7.5 2x100% Lime storage silos.

Notes:

- 1.Weight schedule /BOQ of the FGD system given under CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE OF WORK (BOQ)**
2. The equipment /piping systems indicated above are only major items and does not cover all the equipment / piping system to be erected / commissioned. Contractors are however, required to erect / commission within the price quoted by them, all connected equipment / system shown in manufacturer's drawings / other documents which may be necessary for erection completion and overall commissioning of FGD system.
3. The contractor undertakes to erect/ commission actual quantities as per advice of BHEL Engineer and accordingly the final contract price shall be worked out on the basis of quantities actually erected at site and payments will also be regulated for the same.

2.5 Important information for the Erection Work of FGD system under this tender specifications:

2.5.1 Absorber tower have top elevation of approx. 47 mtr with 7 tier structure and average casing panels have size (6000 mmX4000mm x5 mm).

2.5.2 Absorber System W/D (wet dry) interface having lining of C276 material .Site welding of liner is in the contractor scope. BHEL will supply the liner with plug welding and special electrode for the welding of liner shall be supplied by BHEL Ranipet.-Welding to be done as per approved procedure of BHEL/PVUNL.

2.5.3 Tanks shall be supplied by the units in more than one segment (rolled sections/plates) having height of each segment approx. 2500 mm. Contractor have to complete the assembly at site with necessary welding/NDT/testing as per the approved FQP. **Rubber lining of the tanks (along with surface preparation by blasting or any other approved method and necessary testing i.e spark test/ pin hole test of the rubber lining) excluded from the scope of work and shall be done by rubber lining vendor of BHEL Ranipet.** However necessary assistance to be provided by the contractor. Sizes of the tank mentioned below to give general idea **to** the bidders regarding the extent of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

Table-1:

Sr. N	Description	Diameter in mm	Height in mm	Qty
1	Belt filter washing tank	5500	5900	2
2	Filtrate Water Tank	8000	8900	1
3	Secondary Hydrocyclone Tank	9000	10300	1
4	Waste Water Tank	12000	13600	1
5	Lime stone Slurry Storage Tank	17500	19800	2
6	Auxiliary absorbent tank	17500	20400	1
7	Process Water tank	7000	7400	2
8	Clarified Water Tank (cake washing)	3000	3800	2
9	Emergency quench tank	5500	6000	3

2.5.4 Lime stone silos shall be supplied by the units in more than one segment (3 to 4 segment) and height of each segment shall be 2500 mm. Contractor shall have to complete the assembly, final welding, /NDT/testing as per the approved drawings/ documents/ FQP. Sizes of the silos mentioned below to give general idea to the bidders regarding the extent of work.

Table- 2:

Sr.No	Description	Diameter in MM	Height in mm	Qty
1	Lime stone Storage Silo	8100	12400(5400Mt straight height)	2
2	Lime stone silo	1200	2000(1000m Straight Height)	2

2.5.5 Erection and commissioning of the below mentioned equipment's/system under FGD system excluded from the scope of work under this contract. Erection and commissioning shall be done by the BHEL Ranipet vendor /system supplier/OEM of the system.

- a. Absorber Elevator
- b. Rubber lining of tanks and absorber
- c. Rubber lining of pipes.

However, contractor scope limited to extend the necessary assistance along with T&Ps, scaffolding to the vendor during the erection and commissioning of the above system.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: Scope of Work

2.5.6 BHEL shall provide the technical support for commissioning of below mentioned equipment's on need basis. If support required during the erection same shall be Provided free of charges by BHEL.

- a) Slurry Recirculation Pump System
- b) Mist Eliminator & Accessories
- c) Air Oxidation System
- d) Slurry Pumps & Accessories
- e) Agitators
- f) Limestone Mill
- g) Primary Hydroclone And Accessories
- h) Secondary Hydroclone And Accessories
- i) Gypsum Belt Filter And Accessories

Note: Quantities and dimensions mentioned above for tanks, silos, absorber are indicative and to give general idea regarding the extent of work.

2.6 Touch-up Painting (Applicable in entire scope of work): All Duct structures/ components shall be supplied from BHEL units/ workshops with finish coats of paint. Therefore final painting is not applicable in the scope of contractor. However touch up painting (wherever required), incidental to the work, shall be in the scope of the contractor, including supply of the required paints and primers and associated consumables. Though the final painting is not there in the scope of the contractor, in case any shop painted structure/component is required to be repainted due to the reasons attributable to the contractor such as Mis-handling, damage during erection process, other reasons incidental to the work etc, such re-painting/finish painting of the components/structures shall be in the scope of the contractor including the supply of paints and primers along with all required consumables.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.1	PART I ESTABLISHMENT			
3.1.1	FOR CONSTRUCTION PURPOSE:			
a	Open space for office (as per availability)	Yes		Location will be finalized after joint survey with owner.
b	Open space for storage (as per availability)	Yes		Location will be finalized after joint survey with owner.
c	Construction of bidder's office, canteen and storage building including supply of materials and other services		Yes	
d	Bidder's all office equipments, office / store / canteen consumables		Yes	
e	Canteen facilities for the bidder's staff, supervisors and engineers etc		Yes	
f	Fire fighting equipments like buckets, extinguishers etc		Yes	
g	Fencing of storage area, office, canteen etc of the Contractor		Yes	
3.1.2	FOR LIVING PURPOSES OF THE BIDDER			
a	Open space for labour colony (as per availability)		Yes	Agency has to make his own arrangement at his own cost.
b	Labour Colony with internal roads, sanitation, complying with statutory requirements		Yes	
3.2.0	ELECTRICITY			
3.2.1	Electricity For construction purposes of Voltage 415 V, A.C., 3 Phase , 50 Hz	Yes		At Single point on free of cost basis.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
a	Single point source	Yes		At a distance of 500 M from site (Distance is only tentative, it may vary upto an extent depending on site condition)
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.2	Electricity for the office, stores, canteen etc of the bidder	Yes		Chargeable basis. Applicable charges shall be as per rate of PVUNL prevailing during the execution period including applicable taxes, duties, levy etc.
a	Single point source	Yes		At a distance of 500 M from site (Distance is only estimated, it may vary upto an extent depending on site condition)
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.3	Electricity for living accommodation of the bidder's staff, engineers, supervisors etc		Yes	Agency has to make his own arrangement at his own cost.
a	Single point source		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
	PART I			
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.3.0	WATER SUPPLY			
3.3.1	For construction purposes: (Single point source provided by BHEL)			
a	Making the water available at single point	Yes		Chargeable basis
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	Agency has to make his own arrangement at his own cost.
3.3.2	<u>Water supply for bidder's office, stores, canteen etc</u>			
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.3	<u>Water supply for Living Purpose</u>			
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.4.0	LIGHTING			
a.	For construction work (supply of all the necessary materials) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
PART I				
b	For construction work (execution of the lighting work/ arrangements) 1. At office/storage area 2. At the preassembly area 3 At the construction site /area		Yes	
c	Providing the necessary consumables like bulbs, switches, etc during the course of project work		Yes	
d	Lighting for the living purposes of the bidder at the colony / quarters		Yes	
3.5.0	COMMUNICATION FACILITIES FOR SITE OPERATIONS OF THE BIDDER			
a	Telephone, fax, internet, intranet, e-mail etc		Yes	
3.6.0	COMPRESSED AIR wherever required for the work		Yes	
3.7.0	Demobilization of all the above facilities		Yes	
3.8.0	TRANSPORTATION			
a	For site personnel of the bidder		Yes	
b	For bidder's equipments and consumables (T&P, Consumables etc)		Yes	
Sl. No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
PART II				
3.9 ERECTION FACILITIES				
3.9.1	Engineering works for construction:	Yes		
a	Providing the erection drawings for all the equipments covered under this scope	Yes		
b	Drawings for construction methods	Yes	Yes	In consultation with BHEL
c	As-built drawings – where ever deviations observed and executed and also based on the decisions taken at site- example – routing of small bore pipes		Yes	In consultation with BHEL

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description PART I	Scope / to be taken care by		Remarks
		BHEL	Bidder	
d	Shipping lists etc for reference and planning the activities	Yes		
e	Preparation of site erection schedules and other input requirements		Yes	In consultation with BHEL
f	Review of performance and revision of site erection schedules in order to achieve the end dates and other commitments	Yes	Yes	In consultation with BHEL
g	Weekly erection schedules based on SL No. e		Yes	In consultation with BHEL
h	Daily erection / work plan based on SL No. g		Yes	In consultation with BHEL
i	Periodic visit of the senior official of the bidder to site to review the progress so that works are completed as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two months.		Yes	
j	Preparation of preassembly bay		Yes	
k	Laying of racks for gantry crane if provided by BHEL or brought by the contractor/bidder himself		Yes	Not Applicable
L	Arranging the materials required for preassembly		Yes	

3.10 ELECTRICITY:

3.10.1 The construction power (415V) will be provided at a single point for construction purpose only on free of cost. Further distribution is to be arranged by the bidder at his cost. Construction power shall be provided from the nearest Substation / tapping point.

3.10.2 As regards to contractor's office/store/canteen/labour colony & sheds all such expenditure shall be borne by the contractor.

3.10.3 Provision of distribution of electrical power from the given single central common point to the required places with proper distribution boards, approved cables and cable laying including supply of all materials like cables, switch boards, pipes etc., observing the safety rules laid down by electrical authority of

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – III: Facilities in the scope of Contractor/BHEL

the State / BHEL / their customer with appropriate statutory requirements shall be the responsibility of the tenderer / contractor.

- 3.10.4 BHEL is not responsible for any loss or damage to the contractor's equipment as a result of variations in voltage / frequency or interruptions in power supply.
- 3.10.5 Necessary "Capacitor Banks" to improve the Power factor to a minimum of 0.8 shall be provided by the contractor at his cost. Penalty if any levied by customer on this account will be recovered from contractor's bills.
- 3.10.6 The required energy meter for measuring power consumption shall be arranged by the contractor and taken care by the contractor.
- 3.10.7 Contractor has to make his own arrangements for his electricity requirement for his labour colony at his cost.
- 3.10.8 As there are bound to be interruptions in regular power supply, power cut/load shedding in any construction sites, contractor should make his own arrangement for alternative source of power supply through deployment of adequate number of DG sets at their cost during the power breakdown /failure to get urgent and important work to go on without interruptions. No separate payment shall be made for this contingency.

Note I:

Although the **Electricity is free for construction, the same shall be used sparingly. Details of Electricity units consumed shall be submitted to BHEL office every month for records.**

3.11 CONSTRUCTION WATER

- 3.11.1 Water (Raw water) required for construction purposes will be provided at one single point within the plant area on chargeable basis. The required water meter for measuring the consumption shall be provided and installed by the contractor. The required pumps & accessories, pipes for drawing water from the points and further distribution will be arranged by the contractor at their cost.
- 3.11.2 The water charges may vary from time to time as per PVUNL water conditions, Any dispute regarding consumption, the BHEL engineer decision will be final. In case of non-availability of water, the contractor shall make his own arrangements of water suitable for construction to have uninterrupted work. No separate payment shall be made for any contingency arrangement made by contractor, due to delay / failure for providing water supply. Contractor has to make his own arrangements for his water requirement for his labour colony at his cost.
- 3.11.3 In case of non-availability of water, the contractor shall make his own arrangements of **water suitable for construction purpose** to have uninterrupted work. No separate payment shall be made for any contingency arrangement made by contractor, due to delay / failure for providing water supply. Contractor has to make his own arrangements for his water requirement for his labour colony at his cost.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – III: Facilities in the scope of Contractor/BHEL

3.12 DRINKING WATER

Bidder shall provide drinking water at the work spot at their cost.

3.13 ONLINE SITE CONSTRUCTION MANAGEMENT SYSTEM (SCMS):

Contractor has to provide minimum 1 computer with one operator, for online material management, reporting of daily progress, billing and other similar activities, within the quoted rate. Computers shall have minimum configuration of Windows 7 OS, 4GB RAM and Internet Explorer 8 or above.

3.14 CONSUMABLES:

- 3.14.1 Such of those consumables as indicated as consumables provided by BHEL alone will be provided to the contractor by BHEL free of charge for erection activities. Other required consumables like electrodes, all gases, and other materials for this scope of work are to be arranged by the contractor at their cost.
- 3.14.2 All the required electrodes (in his scope) as approved by BHEL shall be arranged by contractor at his cost. It shall be the responsibility of the contractor to obtain prior approval of BHEL, before procurement regarding, suppliers, type of electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number and date of expiry etc.
- 3.14.3 All other electrodes including stainless steel electrodes required for shall be arranged by the contractor at his cost. However BHEL will provide imported electrodes as provided by manufacturing units. The bidder shall use the Customer approved quality welding electrodes only.
- 3.14.4 The contractor shall provide within finally accepted price / rates, all consumables like welding electrodes (including alloy steel and stainless steel), all gases (inert, welding, and cutting), soldering material, dye penetrants, radiography films. Other erection consumables such as tapes, jointing compound, grease, mobile oil, M-seal, Araldite, petrol, CTC / other cleaning agents, grinding and cutting wheels are to be provided by the contractor. Steel, H&S, packers, shims, wooden planks, scaffolding and pre-assembly materials, hardware items etc. required for temporary works such as supports, scaffoldings, bed are to be arranged by him. Sealing compounds, gaskets, gland packing, wooden sleepers, for temporary work, required for completion of work except those which are specifically supplied by manufacturing unit are also to be arranged by him.
- 3.14.5 All the shims, gaskets and packing, which go finally as part of equipment, shall be supplied by BHEL free of cost.

Note: List of approved vendors attached as file Named: 'Annexure-2 Approved list of welding electrodes supplier'.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – III: Facilities in the scope of Contractor/BHEL

3.15 MATERIAL SUPPLY:

BHEL will supply the materials / equipments indicated in the weight schedule from their respective manufacturing units which are to be executed / incorporated in the permanent system. In addition the material such as lube oil, grease required for commissioning the erected equipments and chemicals required for chemical cleaning of equipments will be supplied free of cost by BHEL.

3.16 LIGHTING FACILITY:

Adequate lighting facilities such as flood lamps, hand lamps and area lighting shall be arranged by the contractor at the site of construction, pre assembly yard and contractor's material storage area etc. at his cost.

3.17 GASES:

- 3.17.1 All the required gases like Oxygen / Acetylene / argon / Nitrogen required for work shall be supplied by the Contractor at his cost. It shall be the responsibility of the contractor to plan the activities and store sufficient quantity of these gases. Non availability of gases cannot be considered as reason for not attaining the required progress. BHEL reserves the right to reject the use of any gas in case required purity is not maintained.
- 3.17.2 The contractor shall submit weekly / fortnightly / monthly statement report regarding consumption of all consumables for cost analysis purposes.
- 3.17.3 The contractor shall ensure safe keeping of the inflammable cylinder at a separate place away from normal habit with proper security etc.
- 3.17.4 BHEL reserves the right to reject the use of any gas in case required purity is not maintained.

3.18 ELECTRODES SUPPLY AND STORAGE

- 3.18.1 The bidder shall use the BHEL / Customer approved quality welding electrodes only.
- 3.18.2 It shall be the responsibility of the contractor to obtain prior approval of BHEL, before procurement, regarding suppliers, type of electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number and date of expiry etc.
- 3.18.3 Shortage of any of the electrodes or the equivalent suggested by BHEL shall not be quoted as reason for deficiency in progress or for additional rate.
- 3.18.4 Storage of electrodes shall be done in an air conditioned / controlled humidity room as per requirement, at his own cost by the contractor.
- 3.18.5 All low hydrogen electrodes shall be baked / dried in the electrode drying oven (range 375 deg. C - 425 deg. C) to the temperature and period specified by the BHEL Engineer before they are used in erection work and each welder should be provided

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – III: Facilities in the scope of Contractor/BHEL

with one portable electrode drying oven at the work spot. Electrode drying oven and portable drying ovens shall be provided by contractor at his cost.

- 3.18.6 In case of improper arrangement of procurement of above electrodes BHEL reserves the right to procure the same from any source and recover the cost from the contractor's first subsequent bills at market value plus departmental charges of BHEL communicated from time to time. Postponement of such recovery is not permitted.
- 3.18.7 BHEL reserves the right to reject the use of any electrodes at any stage, if found defective because of bad quality, improper storage, date expiry, unapproved type of electrodes etc. It shall be the responsibility of the contractor to replace at his cost without loss of time.

3.19 OTHER FACILITIES

3.19.1 Adequate water less urinals (at least 4 nos in different locations) shall be arranged by the contractor within quoted rates, at site of construction at different areas, with proper disposal arrangement.

3.19.2 Vendors have to comply requirements of HSE & Statutory requirement in line with BHEL HSE plan, NTPC Safety requirement, Jharkhand/Central statutory requirement.

3.19.3 Agencies are to get registered (to take membership) from Safety Council of India, Mumbai/National Safety Council.

3.19.4 Vendors have to arrange labour rest sheds, drinking water facility, toilets, canteen facility as per local labour act/BOCW act. Maintaining hygiene and disposal of debris, scraps, canteen items and area cleaning is included in vendor's scope.

3.19.5 Agency has to arrange trained scaffolding experts with accreditation from statutory agencies with proper experience and they will issue fitness certificates for safe use. Such kind of qualified scaffolding experts will vary as per job requirement. At the same time, training has to be given by these experts at regular intervals for their own workers for increasing no. of experts.

3.19.6 Agencies HSE officers should have sufficient experience as per rule 209 of BOCW act central rule 1998. Agencies HSE officers will be part of BHEL HSE Team and they will be responsible for giving training on HSE issues in addition to normal field works and other normal site requirements.

3.19.7 Preparation of method statement, HIRA, Job Safety analysis, permit to work, Lifting plans, and all supporting documents as required for starting & continuation of work/job is in vendor's scope.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – III: Facilities in the scope of Contractor/BHEL

3.19.8 Hydras are not allowed for materials transport, only pick and carry cranes shall be deployed by the agency.

3.19.09 First aid centre will be maintained by BHEL and cost will be proportionately recovered from vendors.

3.19.10 Vendor has to arrange land within his quoted rate for making labour colony. Vendors labour colony has to be maintained with proper hygiene, drinking water, bathroom water, lighting arrangement, sewerage system. These facilities are to be regularly maintained including drains, surrounding, up-keepment of labour colony. BHEL/NTPC & local statutory authorities will visit labour colony from time to time and all healthy conditions are to be maintained by vendor.

3.19.11. Scaffolding pipes, clamps, safety nets, floor grills for working platforms are to be made of good quality with proper certifications as per IS Codes.

3.20. DEWATERING:

Contractor shall ensure at all times that the work area & approach/ access roads are free from accumulation of water, so that the materials are safe and the erection/ progress schedule are not affected. No separate claim in this regard shall be admitted by BHEL.

3.21 SITE ORGANISATION

3.21.1 The contractor shall provide adequate staffing in the following areas in addition to the staffing requirements of execution as instructed/informed by BHEL:

- i. Overall planning, monitoring & control.
- ii. Quality control and quality assurance.
- iii. Materials management.
- iv. Safety, fire & security.
- v. Industrial relations and fulfilment of labour laws and other statutory obligations.

3.21.2 The contractor shall maintain a site organization of adequate strength in respect of manpower, construction machinery and other implements at all times for smooth execution of the contract. This organization shall be reinforced from time to time, as required to make up for slippage from the schedule without any commercial implication to BHEL. The site organization shall be headed by a competent construction manager having sufficient authority to take decisions at site.

3.21.3 The contractor should also submit to BHEL for approval a list of construction equipment, erection tools, tackle etc prior to commencement of site activities. These tools & tackles shall not be removed from site without written permission of BHEL

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of Contractor/BHEL

3.22 LAND FOR SITE OFFICE AND LABOUR COLONY

3.22.1 Minimum Open space as made available by customer will be provided at free of charges to the contractor, for construction of temporary office shed, fabrication yard and storage area at the job site, contractor's stores shed(s).

3.22.2 BHEL shall not provide to the contractor any residential accommodation to any of his staff and the contractor has to make his own arrangements. Contractor has to make his own arrangements for labour colony.

3.22.3 Location and area requirement for office / storage sheds / fabrication yard shall be discussed and mutually agreed to.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps and MMEs to be deployed by Contractor

A: LIST OF TOOLS & PLANTS TO BE DEPLOYED BY THE CONTRACTOR -

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
1	Crawler CRANE	150 MT	01 No.	From Start of Erection till completion of ducts, ESP HVR and Roof structure erection completion of all passes of ESP & absorber, tanks and duct of FGD and further requirement for ESP & FGD systems erection in consultation with site.
2	Tyre mounted mobile crane	18T/20T	02 Nos.	From Erection start to till trial run.
3	Tyre mounted mobile crane	14/20T	02 Nos.	From Erection start to till trial run
4	TRAILER WITH PRIME MOVER	20 MT	02 NOS.	1 from Start of ESP erection Work till roof structure completion of all passes, 2nd from Start of FGD erection work to till trial run.
5	Oxy Acetylene Gas cutting Machine		Adequate nos.	
6	3-PHASE DISTRIBUTION BOARD WITH COMPLETE SET UP FOR DRAWL OF CONSTRUCTION POWER	AS REQUIRED	as required	
7	POWER CABLE FOR DRAWL OF CONSTRUCTION POWER	AS REQUIRED	as required	
8	RADIOGRAPHY ARRANGEMENT WITH RADIOACTIVE ISOTOPE SOURCE	COBALT-60	as required	
9	THEODOLITE OF REQUIRED ACCURACY	To ensure verticality of str columns.	1 Nos.	
10	SELF DRILLING CUM TAPPING MACHINE FOR SCREWS OF ESP ROOF SHEETS	AS REQUIRED	4 nos. (As required)	

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract –Volume I A

Page 71 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps and MMEs to be deployed by Contractor

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
11	WELDING GENERATOR (ELECTRICAL)	300 AMPERE RATING	AS REQUIRED	Since erection start
12	RADIOGRAPHY FILM VIEWER	AS REQUIRED	AS REQUIRED	
13	Chain pulley blocks of various & suitable capacities		As Required	
14	BAKING OVEN WITH THERMOSTAT AND TEMPERATURE GAUGE FOR WELDING ELECTRODES	AS REQUIRED	2 (As Required)	
15	HOLDING OVEN WITH THERMOSTAT AND TEMPERATURE GAUGE FOR WELDING ELECTRODES	AS REQUIRED	2 (As Required)	
16	PORTABLE OVEN FOR WELDING ELECTRODES	AS REQUIRED	(As Required)	
17	ELECTRIC WINCH	2/3/5/10/15 TON CAPACITY	As per requirement	
18	HAND WINCH	0.5 TON CAPACITY	As per requirement	
19	SCAFFOLDING MATERIALS WITH CLAMPS.	SUITABLE FOR WORKING AT VARIOUS HEIGHTS	6,000 Pipes with 18000 clamps.	For Alignment, welding & Insulation works, qty may increases as per requirements.
20	PORTABLE GRINDING M/C	AS REQUIRED	as required	
21	PORTABLE DRILLING M/C	AS REQUIRED	as required	
22	HOISTING AND PULLEY DEVICES/PULLEYS	Assorted capacities	as required	
23	FIRE RETARDANT TARPAULINS	AS REQUIRED	as required	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps and MMEs to be deployed by Contractor

SN	DESCRIPTION	CAPACITY (MINIMUM)	MINIMUM QUANTITY PER UNIT	REMARKS
24	FIRE EXTINGUISHER	AS REQUIRED	as required	
25	Hydraulic Jacks	10/20/50/100 MT	as required	
26	Dewatering pumps		as required	
27	Spectrometer for metal testing		as required	
27	Elco meter for paint thickness checking		as required	
28	Hand Operated Megger 500 / 1000 V		as required	
29	Tong Tester 10, 20 Or 50 Amp + / - 3 % Accuracy		as required	
30	Digital and Analogue Multimetres		as required	
31	Inclined Manometer 0-50 mm Water Column		as required	
32	Calibrated Power driven HSFG bolt tightening machines with set value facility.		3 nos.	Qty may increases as per site requirements
33	Concrete Blocks		40 nos.	For making bed of steel structure for checking dimensional accuracy, configuration and minor rectification.
34	Air compressor	As per requirement	As per requirement	

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – IV: T&Ps and MMEs to be deployed by Contractor

- 4.1 **The above list is only indicative and these T&Ps may not be required for entire contract period but contractor shall ensure the availability of the T&Ps as per work requirement and T&P Deployment schedule.** T&P Deployment schedule shall be finalized at site in consultation with BHEL Engineer based on the work fronts/work requirement. BHEL decision shall be final and binding regarding the T&P deployment schedule. Contractor shall mobilize / maintain the T&P's as per the deployment schedule notified time to time by BHEL Engineer.
- 4.2 Contractor has to deploy T&P, MMD, IMTE as per requirement of site and as decided by BHEL Engineer.
- 4.3 If any one of T&P mentioned above is not needed for proper execution of scope of work, provided contractor has not utilized BHEL free issued T&P for completing such work, no recovery from contractor shall be applicable.
- 4.5 i.) In case deployment of T&P w.r.t requirement/schedule, is delayed or deployed for a shorter period or abnormal down time of T&P
or
ii) In case T&P w.r.t requirement was not deployed by the contractor as per instruction of BHEL and BHEL had to deploy either its own T&P
or
iii) BHEL had to deploy the T&P from outside agency,
-then recovery shall be done from the contractor as under:
- 4.5.1 In case BHEL had to deploy its own T&P, hire charges of T&P applicable for outside agencies as per extant guidelines for "Hire Charges on issue of Capital Tools & Plants" shall be recovered.
- 4.5.2 In case BHEL had to deploy the T&P from outside agency, actual hiring cost plus applicable overheads shall be recovered.
- 4.6 All the tools and tackles/measuring instruments shall be duly tested/calibrated and valid certificate to that effect should be submitted to BHEL site in-charge before the start of work.
- 4.7 T&P's mentioned above shall be specifically deployed as per the respective packages. However, as per work requirement and availability of T&Ps the inter use in Material Handling and Mechanical works may be permitted as per the instruction of the BHEL Engineer.
- 4.8 If the work related to T & Ps mentioned above is completed then, BHEL can release that T & P during contract period / extended period if any. However, written

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – IV: T&Ps and MMEs to be deployed by Contractor

permission shall be taken by contractor from BHEL construction Manager for releasing the T&P.

- 4.9 In case of any specific requirement of higher capacity crane apart from the vendors scope shall be provide by the BHEL on sharing basis free of charge,
- 4.10The T&P deployment as specified in above table is only indicative, however the contractor has to ensure the availability of required T&P till completion of all the work under his scope in this tender.
- 4.11In the eventuality of contractor not deploying cranes / abnormal down time of cranes in his scope during the period specified above, and BHEL arranges for the same [either BHEL's own cranes / hired cranes], prevailing BHEL Corporate Crane hire charges (may vary from time to time) shall be recovered from the contractor's running bills. Corresponding pages of Corporate Crane hire charges are enclosed as part of VOL I as File titled "**Annexure 1- BHEL T&P Hire Charges**". (Please note that these charges are as valid up to May 31, 2021 and may get revised further).
- 4.12 For loading and transportation, all necessary T&P such as Trailers, Cranes, Winches, welding generators, slings, jacks, sleepers, rails etc., are to be arranged by the contractor.
- 4.13The contractor has to furnish a list of Tools and plants including cranes / tractors /trailers / trucks etc. which he has proposed to deploy for this work.
- 4.14Crane operators deployed by the contractor shall be tested by BHEL before he go to operate the cranes.
- 4.15 The contractor shall arrange crane operator, diesel, petrol and other consumables required for the tools and plants, equipments etc. Preventive and routine maintenance of T & P are also to be arranged by the contractor at his cost without any delay. Required number of experienced mechanics and helpers for routine maintenance of the above cranes shall be provided by the contractor within his quoted rate.**

B: MEASURING AND MONITORING EQUIPMENTS (MMEs):

To be finalized at site as per requirement.

NOTE:

- 1. All above T&Ps are to be deployed by contractor as and when required as per instruction of BHEL engineer. If works gets delayed due to non-availability of above T&Ps, BHEL reserves the right to deploy the same and recover the charges**

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – IV: T&Ps and MMEs to be deployed by Contractor

thereof from the contractor as per prevailing market rate/hiring rate/BHEL internal hiring rates + Applicable overhead rates.

2. This above list of T&Ps is only indicative and neither exhaustive nor limiting. Quantities indicated above are only the minimum required. Contractor shall deploy all necessary T&P to meet the schedules & as prescribed by BHEL engineer and required for completion of work.
3. Depending upon the nature of work and availability of facilities locally, contractor may have to arrange for a temporary workshop for facilitating uninterrupted progress of work.
4. Necessary electrical / water / air connection required for operation of any of the tools & tackles shall be to Contractor's account.
5. Contractor has to submit the Calibration certificates of all the precision Equipement to BHEL. BHEL may ask for recalibration of the MMEs /precision equipments for ensuring quality of work. Contractor must re-ascertain/ recheck range and accuracy of each IMTE from BHEL Engineer well in advance before arranging calibration/ deployment.
6. Any T&Ps, Cranes, Slings, D-shackles and other lifting tackles, Trailers required for shifting of material from store to site shall be arranged by contractor over and above T&Ps/ crane provided by BHEL.
7. T&P and the mobilization shown in the above mentioned list is suggestive requirement considering parallel working in Main plant structural area. Mobilization schedule as mutually agreed at site for major T&Ps, have to be adhered to. Numbers / time of requirement will be reviewed time to time at site and contractor will provide required T&P / equipments to ensure completion of entire work within schedule / target date of completion without any additional financial implication to BHEL. Vendor will give advance intimation & certification regarding capacity etc. prior to dispatch of heavy equipments. Also on completion of the respective activity, demobilization of T&P in total or in part can be done with the due approval of engineer in charge. Retaining of the T&Ps during the contract period will be mutually agreed in line with construction requirement.
8. In the event of need of change of type of any of major T&Ps, approval shall be taken from BHEL Engineer in-charge prior to mobilization. The decision of Number of T&P required due to replacing the enlisted T&P as per above table, shall be taken after analyzing the production capacity and suitability of both the T&Ps.
9. Crane operators deployed by the contractor shall be tested by BHEL before they are allowed to operate the cranes.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – IV: T&Ps and MMEs to be deployed by Contractor

10. The above list is only indicative and these T&Ps may not be required for entire contract period but contractor shall ensure the availability of the T&Ps as per work requirement and T&P Deployment schedule. T&P Deployment schedule shall be finalized at site in consultation with BHEL Engineer based on the work fronts/work requirement. BHEL decision shall be final and binding regarding the T&P deployment schedule. Contractor shall mobilize / maintain the T&P's as per the deployment schedule notified time to time by BHEL Engineer.

11. The T&P deployment as specified in above table is only indicative, however the contractor has to ensure the availability of required T&P till completion of all the work under his scope in this tender.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – V: T&P and MMEs to be provided by BHEL on sharing basis

5. LIST OF T&P TO BE PROVIDED BY BHEL FREE OF HIRE CHARGES ON SHARING BASIS:

SL NO	DESCRIPTION & CAPACITY OF T&P	QUANTITY	REMARKS
1	Cranes of Capacity above 150 MT.	As required	Cranes excluded from the contractors scope, required for mentioned work will be arranged by BHEL as per requirement.
2	Air Leak Test equipment with all auxiliaries.	01 SET	Air Leak Test equipment with all auxiliaries (Air Blower for ESP ATT) shall be provided by the BHEL.
3.	HUCK BOLTING MACHINE COMPLETE SET WITH SPARES **	As required	

Note:

** : BHEL will provide the Huck bolting machine with hoses & Noses however if Any repair or replacement required during operation, agency has to arrange the same on his cost.

- 5.1 All the T&Ps mentioned above shall be given to contractor on shareable basis and the allotment is made by BHEL on need basis.
- 5.2 Besides the T&P mentioned above, which is being made available to the contractor on free of hire charges, any additional crane and other T & P which may be required for successful and timely execution of the work covered within the scope of this tender shall be arranged and provided at site by the contractor at his cost. In case if the contractor fails to provide such equipments, BHEL will arrange for the same and the cost will be recovered from the contractor's bill with BHEL overheads, as applicable from time to time which may vary even during contract period.
- 5.3 All the distribution boards, connecting cables, hoses etc., and temporary connection work including electrical connections for the BHEL issued T & Ps shall have to be arranged by the contractor at his cost.
- 5.4 The day-to-day and routine maintenance including replacement of spares for the BHEL T&Ps will be carried out by the contractor at his own cost. However, BHEL shall supply spare parts free of charges for normal wear and tear only.
- 5.5 Any loss/damage of tools by the contractor shall have to be replaced or otherwise cost thereof shall be recovered from the contractor.
- 5.6 Contractor shall make necessary arrangements like laying of special sleeper beds and steel plates (sleepers for BHEL owned/hired cranes shall be provided by the

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – V: T&P and MMEs to be provided by BHEL on sharing basis

BHEL), assembly and dismantling of heavy attachment, boom, jib etc for movement and operation of the crane. Contractor shall provide necessary manpower assistance for initial and final assembly & dismantling and for subsequent operations of boom extension and reduction during execution of work. Levelled area in ESP & FGD area will be provided by BHEL/customer for the cranes Consolidation of the ground, if required (Area required for movement of crane), and preparation (including civil work with material) for placing crane for operation shall be done by the contractor, at his cost. Necessary plates / sleepers required for marching operation shall also be provided by the BHEL only for BHEL owned cranes.

5.7 BHEL will provide Huck bolting machine with one set of 12mm and 16mm jaws. Further Requirement of jaws to be arranged by the contractor at his cost. Consumables like O-ring, backup ring, springs, hydraulic fluid for top-up etc., required for maintenance of the huckbolting machine to be arranged by contractor at his cost.

Note: For Crane:

1. The cranes may be BHEL owned or may be obtained on hiring basis including operating and maintenance crew.
2. Operator and O&M for BHEL owned crane will be provided by BHEL.
3. Contractor shall provide the fuel for BHEL provided cranes (Hired/owned) for his use.
4. Contractor shall provide necessary manpower assistance for initial and final assembly & dismantling and for subsequent operations of boom extension and reduction during execution of work. Contractor shall also make necessary arrangements like laying of special sleeper beds and steel pates (all arranged by contractor) for movement and operation of the crane.
5. Cranes provided by BHEL will be on sharing basis with other agencies / contractors of BHEL. The allocation of cranes shall be the discretion of BHEL engineer, which shall be binding on the contractor. Cranes will be deployed at appropriate time as decided by BHEL for suitable duration and intended purpose. Augmentation of BHEL T & P under special circumstances shall be discretion of BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: Time Schedule

TIME SCHEDULE & MOBILIZATION

6.1 INITIAL MOBILIZATION

After receipt of fax LOI, Contractor shall discuss with Project Manager / Construction Manager regarding initial mobilization. Contractor shall reach site, make his site establishment and be ready to commence the erection work within two weeks from the date of issue of Letter of Intent or as per the directions of Construction Manager/ Project Manager of BHEL. Such resources shall be progressively augmented to match the schedule of milestones and commissioning.

6.2 MOBILIZATION FOR ERECTION, TESTING, ASSISTANCE FOR COMMISSIONING ETC.

The activities for erection, testing etc. shall be started as per directions of Construction Manager of BHEL. Contractor shall mobilize further resources (in addition to those required for activities under clause no. 6.1) as per requirement to commence the work of erection, testing etc. of ESP, FGD and auxiliaries, including touchup Painting (as and where required), duct structure etc progressively augment the resources to match schedule of the project.

6.2.1 The contractor shall have to mobilize his resources earlier than the start of contract period for preparatory work like taking over and chipping of foundations, blue-matching, grouting of packer plates etc. or start of fabrication. The contractor shall complete all the works in the scope of this contract within the contract period. Pending points identified by the customer/BHEL during the execution of the contract are to be liquidated during the contract period itself.

6.3 COMMENCEMENT OF CONTRACT PERIOD AND TENTATIVE SCHEDULE

Erection/placement on its designated foundation / location, of the first major permanent equipment / component / column covered in the scope of these specifications, (whichever is earlier as decided by BHEL) shall be recognized as “start of contract period”. Smaller items like packer plates, shims, anchors, inserts etc. will not be considered as start of contract period.

Based on the availability of civil foundations from BHEL and materials from manufacturing units, contractor may have to advance the start of erection after getting clearance from construction manager, or the start of erection may get delayed due to site condition.

The Contractor has to subsequently augment his resources in such a manner that following major milestones of erection & commission are achieved on specified schedules.

According to the contract between BHEL and Owner the schedule of important milestones is as follows:

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: Time Schedule

Schedule of ESP & FGD Unit #1 (Pkg-A) & 2 (Pkg-B):

SL No.	Milestones	UNIT - 1	UNIT - 2
1	ESP Erection Start	1 st Month	1 st Month
2	Start of FGD Erection	11 th Month	11 th Month
3	Boiler Light up	17 th Month	17 th Month
4	ESP gas distribution Test	18 th Month	18 th Month
5	Commissioning of FGD	19 th month	19 th month
6	Completion of FGD all facilities	20 th Month	20 th Month
7	Synchronization on coal	22 th Month	22 th Month
8	Full Load Operation	23 th Month	23 th Month
9	Completion of Trial Run & all facilities	24 th Month (Tentatively by Nov-2021)	24 th Month (Tentatively by Feb-2022)

There is phase difference of 3 months in between unit#1 & 2.

Above time schedule is tentative and in order to meet above schedule in general, and any other intermediate targets set, to meet customer/project schedule, contractor shall arrange & augment all necessary resources from time to time as per the instructions of BHEL.

6.4 CONTRACT PERIOD

The contract period for completion of entire work under scope for each of the packages shall be **24 (Twenty Four) months for Package-A and 24 (Twenty Four) Months for Package-B** from the "START OF CONTRACT PERIOD" as specified earlier for completion of the entire work.

6.4.1 The period from the commencement of preparatory work for erection till the actual "start of contract period" shall not be reckoned for the above purpose.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: Time Schedule

6.5 PROVISION OF PENALTY IN CASE OF SLIPPAGE OF INTERMEDIATE MILESTONES:

In case of slippage of Two Major Intermediate Milestones, mentioned as M1 & M2 hereunder, Delay Analysis shall be carried out on achievement of each of these two Intermediate Milestones in reference to F-14.

Milestones	Activities	To be completed by
M1	Boiler Light up	17 th Month from Date of Start
M2	Synchronization on coal	22 th Month from Date of start

Note: Refer clause no 12.0 of ANNEXURE-4 IMPORTANT INFORMATION of the NIT regarding modalities against provision of penalty in case of slippage of Intermediate Milestones.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-VII: Terms of Payment

The progressive payment for erection, testing and commissioning on accepted price of contract value will be released as per the break up given hereinafter:

7.1 Payment schedule for ESP works:

SL NO	Contract (Package-A & package-B) -->	ESP		INSULATION
	Rate schedule Identifier ----->	ESP (1.1)	NPP (ESP outlet Funnel to Chimney) (1.2)	1) Iron Components (1.4) 2) Wool mattresses (1.3) 3) Aluminium sheeting/Insu. Cladding (1.5)
I	PRO RATA PAYMENTS (85%)			
1.1	ON PRE-ASSEMBLY WHEREVER APPLICABLE (IF NOT APPLICABLE, THIS PORTION SHALL BE CLUBBED WITH PLACEMENT IN POSITION)	15	15	--
1.2	PLACEMENT IN POSITION	20	10	50
1.3	ALIGNMENT	15	15	15
1.4	WELDING/BOLTING/FIXING	20	30	20
1.5	NDT , Grouting , HANGERS & SUPPORTS ETC WHEREVER NECESSARY AS PER DRG	--	15	--
1.6	COMPLETION OF HOPPERS ALONG WITH ALL DOORS, HEATING ELEMENTS, POKING DOORS, ETC	5	--	--
1.7	COMPLETION OF INNER, OUTER ROOF INSULATOR HOUSING, RECTIFIER TRANSFORMERS, PENT HOUSE MONO RAILS, HOISTS ETC	5	--	--
1.8	ERECTION OF EMITTING AND COLLECTING RAPPING SYSTEM WITH ALL DRIVES	5	--	--
	TOTAL FOR PRO RATA PAYMENTS (TOTAL 85%)	85	85	85

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-VII: Terms of Payment

SL NO	Contract (Package-A & package-B) -->	ESP		INSULATION
	Rate schedule Identifier ----->	ESP (1.1)	NPP (ESP outlet Funnel to Chimney) (1.2)	1) Iron Components (1.4) 2) Wool mattresses (1.3) 3) Aluminium sheeting/Insu. Cladding (1.5)
II	STAGE/MILESTONE PAYMENTS (15%)			
2.1	AIR & GAS TIGHTNESS TEST	1.5(6x0.25)	5	--
2.2	GAS DISTRIBUTION TEST	1.5(6x0.25)	--	1
2.3	CHARGING OF ESP FIELDS	3(6x0.50)	--	1
2.4	Boiler Light Up	--	1	2
2.5	Full Load	2	2	2
2.6	Trial Operation of Unit	1	2	2
2.7	Painting	1	1	--
2.8	Area cleaning, temporary structures cutting/removal and return of scrap	1	1	3
2.9	Punch List points/pending points liquidation	2	1	1
2.10	Material Reconciliation	1	1	2
2.11	Completion of Contractual Obligation	1	1	1
	TOTAL FOR STAGE/MILESTONE PAYMENTS (15%)	15	15	15
	TOTAL I + II	100	100	100
	NOTE: The terms of payment is only for enabling release of payment through RA Bills and is not indicative of the actual quantum of value of work.			

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-VII: Terms of Payment

7.2 Payment Schedule for FGD:

Sr. No	Contract (FGD Package)						
	Rate Schedule Identification	(Structure & Duct /dampers) (2.1)	(Tan ks) (2.2)	(Rotating M/c) (2.3)	(Insulati on)(2.4)	(Piping) (2.5)	(Misc Eqpt/ structure steel) (2.1)
I	PRO RATA PAYMENTS (85%)						
1	Completion of preassembly, (if not applicable this portion shall be clubbed with Placement in position)	20%	20%	20%		20%	20%
2	Placement in position	25%	20%	20%	50%	20%	25%
3	Alignment	20%	10%	20%		10%	20%
4	Welding /bolting/fixing as required	15%	20%	20%	35%	15%	15%
5	Completion of non-destructive examination & stress relieving/ heat treatment, (if not applicable, then this portion to be paid along with welding	5%	10%	5%		10%	5%
6	H&S wherever applicable as per drawing					5%	
7	Hydro test of piping/ water fill test /Vaccum box test of tanks/Holiday Test (as applicable)		5%			5%	
8	TOTAL FOR PRO RATA PAYMENTS	85%	85%	85%	85%	85%	85%

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract –Volume I A

Page 85 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-VII: Terms of Payment

II	STAGE MILESTONE PAYMENT (15%)						
1.	Completion of air & gas tightness test for FGD inlet & Outlet Ducts	2.5%	2.5%	2.5%	2.5%	2.5%	2.5%
2.	Completion of Trial run of Slurry pumps/absorber system commg (If Slurry pump not in scope)	1.5%	1.5%	1.5%	1.5%	1.5%	1.5%
3.	Trial run of Wet ball mills or absorber system commg (If mills are not in scope)	2%	2%	2%	2%	2%	2%
4.	Trial run of Oxidation Blower	1% (4x0.25%)	1% (4x0.25%)	1% (4x0.25%)	1% (4x0.25%)	1% (4x0.25%)	1% (4x0.25%)
5.	Trial run of FGD System	2%	2%	2%	2%	2%	2%
6.	Completion of touchup Painting	2%	2%	2%	2%	2%	2%
7.	Area cleaning, temporary structures cutting/removal and return of scrap	1%	1%	1%	1%	1%	1%
8.	Liquidation of pending points	2%	2%	2%	2%	2%	2%
9.	Completion of all contractual obligation and de mobilization of site office	1%	1%	1%	1%	1%	1%
	TOTAL FOR STAGE/MILESTONE PAYMENTS (15%)	15%	15%	15%	15%	15%	15%
	TOTAL I + II	100%	100%	100%	100%	100%	100%

TECHNICAL CONDITIONS OF CONTRACT (TCC)

CHAPTER VIII TAXES and DUTIES

8.0 TAXES, DUTIES, LEVIES (Rev 13 dated 05/11/2018)

1. All taxes excluding GST, GST Cess & BOCW Cess but including, Royalties, fees, license, deposits, commission, any State or Central Levy and other charges whatsoever, if any, shall be borne by you and shall not be payable extra.
2. Any increase of the taxes excluding GST, GST Cess & BOCW Cess, at any stage during execution including extension of the contract shall have to be borne by the contractor. Quoted/ accepted rates/ price shall be inclusive of all such requirements. Please note that since GST on output will be paid by BHEL separately as enumerated below, your quoted rates/ price should be after considering the Input Credit under GST law at your end.
3. **GST :**
The successful bidder shall furnish proof of GST registration .GST along with Cess (as applicable) legally leviable & payable by the successful bidder as per GST Law, shall be paid by BHEL. Hence Bidder shall not include GST along with Cess (as applicable) in their quoted price.
4. GST charged in the Tax Invoice/Debit note by the contractor shall be released separately to the contractor only after contractor files the outward supply details in GSTR-1 on GSTN portal and input tax credit of such invoice is matched with corresponding details of outward supply of the contractor and has paid the GST at the time of filing the monthly return
5. Bidder shall note that the GST Tax Invoice complying with GST Invoice Rules (Section 31 of GST Act & Rules referred there under) wherein the 'Bill To' details will as below:
BHEL GSTN – As per **Annexure -1**
NAME -- Bharat Heavy Electricals Limited
ADDRESS – Site address
6. Bidder to immediately intimate on the day of removal of Goods (in case of any supply of goods) to BHEL along with all relevant details and a scanned copy of Tax Invoice to below email ids to enable BHEL to meet its GST related compliances :-
Email id ---- to be intimated later on.

TECHNICAL CONDITIONS OF CONTRACT (TCC) CHAPTER VIII TAXES and DUTIES

In case of delay in submission of the abovementioned documents on the date of dispatch, BHEL may incur penalty /interest for not adhering to Invoicing Rules under GST Law. The same will be liable to be recovered from the successful bidder, if such delay is not attributable to BHEL.

7. In case of raising any Supplementary Tax Invoice (Debit / Credit Note) Bidder shall issue the same containing all the details as referred to in Section 34 read with Rule 53.
8. Bidder shall note that in case GST credit is delayed/ denied to BHEL due to delayed / non receipt of goods and /or tax invoice or expiry of the timeline prescribed in GST Law for availing such ITC, or any other reasons not attributable to BHEL, GST amount shall be recoverable from the vendor along with interest levied / leviable on BHEL, as the case may be.
9. Bidder shall upload the Invoices raised on BHEL in GSTR-1 within the prescribed time as given in the GST Act. Bidder shall note that in case of delay in declaring such invoice in your return and GST credit availed by BHEL is denied or reversed subsequently as per GST Law , GST amount paid by BHEL towards such ITC reversal as per GST law shall be recoverable from the bidder along with interest levied / leviable on BHEL.
10. Way Bill: Successful Bidder to arrange for way bill / e-waybill for any transfer of goods for the execution of the contract.
The Bidder has to make their own arrangement at their cost for completing the formalities, if required, with Issuing Authorities, for bringing materials, plants & machinery at site for execution of the works under this contract, Road Permit/ Way Bill, if required, shall be arranged by the contractor and BHEL will not supply any Road Permit/ Way Bill for this purpose.
11. **New taxes and duties:-**Any New taxes & duties, if imposed subsequent to due date of offer submission as per NIT & TCN, by statutory authority during contract period including extension, if the same is not attributable to you, shall be reimbursed by BHEL on production of relevant supporting document to the satisfaction of BHEL. However, you shall obtain prior approval from BHEL before depositing new taxes and duties.
Benefits and/or abolition of all existing taxes must be passed on to BHEL against new Taxes, if any, proposed to be introduced at a later date.

TECHNICAL CONDITIONS OF CONTRACT (TCC) CHAPTER VIII TAXES and DUTIES

In case any new tax/levy/duty etc. becomes applicable after the date of bidder's offer but before opening of the price bid, the bidder must convey its impact on his price duly substantiated by documentary evidence in support of the same before opening of the price bids. Claim for any such impact after opening the price bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

12. For transportation work, bidder shall declare in his quotation whether he is registered under GST, if yes, whether he intends to claim GST on forward charge basis. In absence of this declaration, BHEL will proceed further with the assumption that bidder intends not to claim GST on forward charge basis. However, in case of GST registered transporter, the amount to the extent of goods and service tax will be retained till BHEL avails the credit of GST. Further, transporter shall issue tax invoice which inter alia includes gross weight of the consignment, name of the consigner and the consignee, registration number of vehicle in which the goods are transported, details of goods transported, details of place of origin and destination, GSTIN of the person liable for paying tax whether as consigner, consignee or goods transport agency, and also containing other information as mentioned under rule 46.
13. **TDS under Income Tax shall be deducted at prevailing rates on gross invoice value from the running bills unless exemption certificate from the appropriate authority/ authorities is furnished.**
14. **TDS under GST shall be deducted at prevailing rates on applicable value from the running bills.**
15. Refer Annexure – 2 for BOCW Act & Cess Act.

ANNEXURE-1

State wise GSTIN no.s of BHEL

Sl. No	Projects under state	GSTIN
1	Andhra Pradesh	37AAACB4146P7Z8
2	Bihar	10AAACB4146P1ZU
3	Chhattisgarh	22AAACB4146P1ZP
4	Gujarat	24AAACB4146P1ZL
5	Jharkhand	20AAACB4146P5ZP
6	Madhya Pradesh	23AAACB4146P1ZN
7	Maharashtra	27AAACB4146P1ZF
8	Orissa	21AAACB4146P1ZR
9	Telangana	36AAACB4146P1ZG

TECHNICAL CONDITIONS OF CONTRACT (TCC)

CHAPTER VIII TAXES and DUTIES

ANNEXURE-2

BOCW Act & Cess Act

Bidder may please note that the sub-contractor/bidder of BHEL engaging building or construction worker in connection with building or other construction work, are required to follow the procedures enumerated below:

1. It shall be the sole responsibility of the contractor as employer to ensure compliance of all the statutory obligations under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
2. It shall be sole responsibility of the contractor engaging Building Workers in connection with the building or other construction works in the capacity of employer to apply and obtain registration certificate specifying the scope of work under the relevant provisions of the Building and Other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 from the appropriate Authorities.
3. It shall be responsibility of the contractor to furnish a copy of such Registration Certificate within a period of one month from the date of commencement of Work.
4. It is responsibility of the contractor to register under the Building and other Construction Workers' Welfare Cess Act, 1996 and deposit the required Cess for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 at such rate as the Central Government may , by notification in the Official Gazette, from time to time specify. However, before registering and deposit of Cess under the Building and other Construction Workers' Welfare Cess Act, 1996, the contractor will seek written prior approval from the Construction Manager.
5. It shall be sole responsibility of the contractor as employer to get registered every Building Worker, who is between the age of 18 to 60 years of age and who has been engaged in any building or other construction work for not less than ninety days during the preceding twelve months as Beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996.

TECHNICAL CONDITIONS OF CONTRACT (TCC) CHAPTER VIII TAXES and DUTIES

6. It shall be sole responsibility of the contractor as employer to maintain all the registers, records, notices and submit returns under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
7. It shall be sole responsibility of the contractor as employer to provide notice of poisoning or occupation notifiable diseases, to report of accident and dangerous occurrences to the concerned authorities under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the rules made thereunder and to make payment of all statutory payments & compensation under the Employees' Compensation Act, 1923.
8. It shall be the responsibility of the sub-contractor as employer to make payment/deposit of applicable cess amount on the extent of work involving building or construction workers engaged by the sub-contractor within a period of one month from the receipt of payment. It shall also be responsibility of the Contractor to furnish BHEL on monthly basis, Receipts/ Challans towards Deposit of the Cess under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder along with following statistics :
 - (i) Number of Building Workers employed during preceding one month.
 - (ii) Number of Building workers registered as Beneficiary during preceding one month.
 - (iii) Disbursement of Wages made to the Building Workers for preceding wage month.
 - (iv) Remittance of Contribution of Beneficiaries made during the preceding month
9. BHEL shall reimburse the contractor the Cess amount deposited for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder. However, BHEL shall not reimburse the Fee paid towards the registration of establishment, fees paid towards registration of Beneficiaries and Contribution of Beneficiaries remitted.
10. It shall be responsibility of the Building Worker engaged by the Contractor and registered as a beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 to contribute to the Fund at such rate per mensem as may be specified by the State government by notification in the Official Gazette. Where such beneficiary authorizes the contractor

TECHNICAL CONDITIONS OF CONTRACT (TCC) CHAPTER VIII TAXES and DUTIES

being his employer to deduct his contribution from his monthly wages and to remit the same, the contractor shall remit such contribution to the Building and other construction Workers' Welfare Board in such manner as may be directed by the Board , within the fifteen days from such deduction.

11. Bidders may please note that though the quoted price is exclusive of BOCW (which will be reimbursed by BHEL as per sub-clause 9 above) , however, If at any point of time during the contract period, non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder is observed, BHEL reserves the right to deduct the applicable cess (1%) on the contract value and penalty (if any, imposed by Cess Authorities) from the payables on account of non-compliance.

12. The contractor shall declare to undertake any liability or claim arising out of employment of building workers and shall indemnify BHEL from all consequences / liabilities / penalties in case of non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER IX SPECIFIC INCLUSION

Not Applicable

TECHNICAL CONDITIONS OF CONTRACT (TCC)

CHAPTER X SPECIFIC EXCLUSIONS

10.0 EXCLUSIONS

The following works are specific exclusions from the scope of work under erection, testing & commissioning of tender specification-

- i. Sub-delivery items and electrical components such as push-buttons, junction boxes etc.
- ii. E&C work of cable trays, cables and earthing etc
- iii. Control panels, EPMS, MCC etc.
- iv. Electrical & C&I items of handling system (PG 99)
- v. All electrical and control & instrumentation items except those specified elsewhere in these specifications.
- vi. Civil works except to the extent specifically indicated elsewhere in this tender.
- vii. Pneumatic copper tubing and fittings thereof.
- viii. Testing and commissioning of heating elements, thermostats, HV rectifier transformers.
- ix. Electrical and C&I items of Variable Frequency Drives as provided elsewhere in these specifications.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

WEIGHT SCHEDULE:-

ESP, DUCT SUPPORTING STRUCTURES, GATES & DAMPERS
(SUMMARY)

FOR 3X800 MW PVUNL PROJECT PATRATU

Table 1:

ESP For (Pkg-A & Pkg-B Each)					
Rate Sc ID*	Package	Trichy	BAP	Jhansi	Total
1.1	ESP		13237.7	684	13,921.700
1.2	Non Pressure Parts (ESP outlet Funnel to chimney)	2,645.45	303.50		2,948.950
1.3	Min wool for ID Duct and ESP Insulation	242	490		732.00
1.4	Iron Part for ID duct & ESP	20.9	131		151.9
1.5	Insulation Cladding	70	115		185.00
	TOTAL	2,978.35	14,277.20	684.00	17,939.55

* Rate Sc ID: Rate Schedule Identifier

Table 2: WEIGHT DETAIL OF ESP, NPP, INSULATION AND FGD AND ITS ASSORIES

3x800 MW PVUNL Patratu, ESP Application PGMA List						
Pgma	Description	Wt In MT	ESP#1 (Pkg-A)	ESP#2 (Pkg-B)	CAT	Rate Sc ID
ESP						
79801	ROLL/SLIDE SUPPORTS	40	40	40	ESP	1.1
79805	ESP-SUB-DELIVERY COMPONENT	1	1	1	ESP	1.1
79806	INSULATOR HOUSING AS	103.4	103.4	103.4	ESP	1.1

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

79808	GAS DIST. ASSY	99.7	99.7	99.7	ESP	1.1
79809	GD-RAPPING MECHANISM	19	19	19	ESP	1.1
79810	GD_DRIVE ARRANGEMENT	1.3	1.3	1.3	ESP	1.1
79811	GAS SCREEN-EP	25	25	25	ESP	1.1
79813	EMIT SYST SUSPENSION	32.8	32.8	32.8	ESP	1.1
79814	SUPPORT INSULATORS	32.2	32.2	32.2	ESP	1.1
79815	EMITTING ELECTRODES	54	54	54	ESP	1.1
79816	EMIT ELECT RAPP MECH	74.2	74.2	74.2	ESP	1.1
79817	DRIVE ARGT. FOR EMIT. SYS	62	62	62	ESP	1.1
79819	COL ELEC SUSPENSION	220	220	220	ESP	1.1
79820	COLLECTING ELECTRODE	2305	2305	2305	ESP	1.1
79821	EMIT SYS FRAME-TOP	195.5	195.5	195.5	ESP	1.1
79822	EMIT SYS FRAME BOTOM	287.4	287.4	287.4	ESP	1.1
79823	INSPECTION DOORS	35.4	35.4	35.4	ESP	1.1
79824	SHOCK BARS	169.4	169.4	169.4	ESP	1.1
79825	COLL ELECT RAPP MECH	144.1	144.1	144.1	ESP	1.1
79826	COLL ELEC RAPP DRIVE	13.8	13.8	13.8	ESP	1.1
79828	ESP ROOF BEAM	420	420	420	ESP	1.1
79830	ELECTRICAL SD COMPTS	36.7	36.7	36.7	ESP	1.1
79831	GEARED MOTORS FOR RAPPING	33.45	33.45	33.45	ESP	1.1
79832	EMIT SYS FRAME-MIDLE	678	678	678	ESP	1.1
79837	JUNCTION BOX & PUSH BUTTON	2.4	2.4	2.4	ESP	1.1
79841	ELECTRICAL MISCELLANEOUS I	30	30	30	ESP	1.1
79842	OUTER ROOF-EP	418.7	418.7	418.7	ESP	1.1
79843	HOPPER RIDGES	157.1	157.1	157.1	ESP	1.1
79844	HOPPER UPPER PART	600	600	600	ESP	1.1
79845	HOP MLD&LOWER PART	940	940	940	ESP	1.1
79846	INSULATOR SUPP PANEL	170.4	170.4	170.4	ESP	1.1
79847	ROOF PANEL ASSY	228.5	228.5	228.5	ESP	1.1
79848	CASING STRUCTURE	640	640	640	ESP	1.1

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract - Volume I A

Page 96 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

79849	CASING SHELL/PANEL	997.1	997.1	997.1	ESP	1.1
79850	INLET-OUTLET FUNNEL	260.4	260.4	260.4	ESP	1.1
79855	PENT HOUSE FOR E P	256.8	256.8	256.8	ESP	1.1
79857	SPLITTER&GUIDE VANES	46.3	46.3	46.3	ESP	1.1
79859	SUPPORTS FOR ELECTRICAL IT	30.7	30.7	30.7	ESP	1.1
79860	CABLE-CABLE RACKS	280.5	280.5	280.5	ESP	1.1
79861	EP PERF TEST EQUIPT	23.95	23.95	23.95	ESP	1.1
79862	CABLE TRAY AND FLEXIBLE SU	208	208	208	ESP	1.1
79863	ASH LEVEL INDICATOR	4.3	4.3	4.3	ESP	1.1
79864	MISCELLANEOUS ITEMS	15	15	15	ESP	1.1
79865	APP PLATFORM-HOPPER	269.7	269.7	269.7	ESP	1.1
79866	WATER WASHING SYSTEM	6.1	6.1	6.1	ESP	1.1
79872	INTERLOCKS-EP	3.3	3.3	3.3	ESP	1.1
79873	ELECTRICALLY OPERTD HOIST&	5.8	5.8	5.8	ESP	1.1
79874	OPACITY MONITOR & ACCESSOR	1	1	1	ESP	1.1
79877	LT SWITCH BOARD/ESP SWTICH	60	60	60	ESP	1.1
79878	BAPCON & ACCESSORIES	0.7	0.7	0.7	ESP	1.1
79880	FOUNDATION MATLS FOR ESP	35	10	10	ESP	1.1
79881	SUPPOTING STRUCTURES FOR E	1950	1950	1950	ESP	1.1
79889	GUIDE PLATE/VANE EP INLET	15	15	15	ESP	1.1
79890	HEATING ELEMENTS	1.7	1.7	1.7	ESP	1.1
79891	PANEL TYPE HOPPER HEATERS	50	50	50	ESP	1.1
79895	IOS PANEL	0.2	0.2	0.2	ESP	1.1
79988	COMMISSIONING SPARES	0	0	0	ESP	1.1
79996	TOOLS & TACKLES	0	0	0	ESP	1.1
89610	EP GALLERIES&STAIRS	119.1	119.1	119.1	ESP	1.1
89611	ESP ROOF HANDRAILS	13.5	13.5	13.5	ESP	1.1
89612	FLOOR GRILL AND STEP TREAD	91.9	91.9	91.9	ESP	1.1
89613	FLOOR GRILL AND MOBILE LAD	157.7	157.7	157.7	ESP	1.1
89614	PENT HOUSE ROOFING SHEETS	63.5	63.5	63.5	ESP	1.1
89618	HSFG BOLTS FOR ESP STRUT	25	25	25	ESP	1.1

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 97 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

Sub Total of PG 79,89		13262.7	13237.7	13237.7		
BHEL Jhansi Supply Transformers	95KVp 1000mA HVR Trfr with silicone Oil	684	684	684	ESP	1.1
Sub-Total		684	684	684	0	
Sub Total of ESP		13946.7	13921.7	13921.7	0	
Insulation						
79867	MIN WOOL FOR ESP INSULATIO	490	490	490	Insulation	1.3
79868	FIXING COMP. FOR ESP INSUL	131	131	131	Insulation	1.4
89615	INSULATION CLADDING SH FOR	115	115	115	Insulation	1.5
Sub-total of Insulation Total		736	736	736		
33-xxx	Insualtion For Duct	242	242	242	Insulation	1.3
33-xxx	FIXING COMP. FOR Duct INSUL	20.9	20.9	20.9	Insulation	1.4
32-xxxx	Al cladding sheet	70	70	70	Insulation	1.5
Sub Total Of PG 33		332.90	332.90	332.90	0.00	
Sub Total Of Insulation		1,068.90	1,068.90	1,068.90		
ESP-NON PRESSURE PART(ESP - NPP)						
PGMA	Descriptions	WT in MT	ESP#1	ESP#2		
39-012	FOUNDATION MATERIALS	29	29.00	29.00	ESP NPP	1.2
39-142	COLS FRAMES NEAR ID	202	202.00	202.00	ESP NPP	1.2
39-993	CONSUMABLES AND EREC	13	13.00	13.00	ESP NPP	1.2
39-141	COLS FRAMES NEAR ID	269	269.00	269.00	ESP NPP	1.2
39-700	HSFG FASTENERS FOR P	6	6.00	6.00	ESP NPP	1.2
39-810	FLOOR GRILL	80	80.00	80.00	ESP NPP	1.2
39-150	COL FRAMES BETN I.D.	219	219.00	219.00	ESP NPP	1.2
39-300	PLATFORMS - AFTER ESP	336	336.00	336.00	ESP NPP	1.2
39-850	HAND RAIL AND HAND R	48	48.00	48.00	ESP NPP	1.2
39-820	STAIRS	23	23.00	23.00	ESP NPP	1.2
Sub Total of PG 39		1,225.00	1,225.00	1,225.00	0.00	
48-492	DUCT - IDFAN-CHIMNY	315	315.00	315.00	ESP NPP	1.2
48-495	SUPORT IDFAN-CHIMNEY	52.5	52.50	52.50	ESP NPP	1.2

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract - Volume I A

Page 98 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

48-498	DUCT - ,ID FAN-CHIM,	470	470.00	470.00	ESP NPP	1.2
48-265	Supports Aihtr Toprinozzle And Seca	31.5	31.50	31.50	ESP NPP	1.2
48-911	Slide Brg PI & Pac Bellow-Blr	2.1	2.10	2.10	ESP NPP	1.2
48-200	INS TAPPINGS ON DUCT	2	2.00	2.00	ESP NPP	1.2
48-482	DUCT - ESP TO ID FAN	420	420.00	420.00	ESP NPP	1.2
48-485	SUPPORT - ESP TO ID FAN	52.5	52.50	52.50	ESP NPP	1.2
48-494	EXPNJT - IDFAN- CHIMNY	26.25	26.25	26.25	ESP NPP	1.2
48-484	EXPNJT - ESP TO ID FAN	31.5	31.50	31.50	ESP NPP	1.2
48-912	Slide Brg PI-Id Sys	2.1	2.10	2.10	ESP NPP	1.2
48-993	Erection material	15	15.00	15.00	ESP NPP	1.2
Sub Total Of PG 48		1,420.45	1,420.45	1,420.45	0.00	
57470	GATE-ESP OUTLET	87.7	87.70	87.70	ESP NPP	1.2
57480	GATE-ID FAN INLET	78.6	78.60	78.60	ESP NPP	1.2
57490	GATE-ID FAN OUTLET	71.2	71.20	71.20	ESP NPP	1.2
57491	BLOWER WITH MOTOR	14	14.00	14.00	ESP NPP	1.2
57497	KNIFE GATE VALVE	12	12.00	12.00	ESP NPP	1.2
57577	PLATFORMS AND LADDERS(only installed ,dampers platforms & ladders)	20	20.00	20.00	ESP NPP	1.2
57466	ELECT ACTUATOR FOR GATE,DAMPER(only for installed gae & dampers)	20	20.00	20.00	ESP NPP	1.2
Sub Total Of PG 57		303.50	303.50	303.50	0.00	
SubTotal Of ESP-NPP		2,948.95	2,948.95	2,948.95		
Total weight including ESP and Trichy Supply		17,964.55	17,939.55	17,939.55	0.00	0.00
PGMA	Description	Wt in MT	FGD#1	FGD#2	Category	
FW213	ABSORBER SYSTEM INTERNALS	22	22	22	Struct/Duct/Damper	2.1
FW215	MIST ELIMINATOR & ACCESSOR	28	28	28	Struct/Duct/Damper	2.1
FW219	ABSORBER SYSTEM- BASE	61	61	61	Struct/Duct/Damper	2.1
FW220	ABSORBER SYSTEM- STRUCTURES	816	816	816	Struct/Duct/Damper	2.1

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 99 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

FW221	ABSORBER SYSTEM- CASING BOT	130	130	130	Struct/Duct/Damper	2.1
FW222	ABSORBER SYSTEM- CASING TOP	607	607	607	Struct/Duct/Damper	2.1
FW223	ABSORBER SYSTEM ACCESSORIE	39	39	39	Struct/Duct/Damper	2.1
FW224	ABSORBER SYSTEM- LINING-C27	89	89	89	Struct/Duct/Damper	2.1
FW227	EMERGENCY QUENCH SYSTEM	9	9	9	Struct/Duct/Damper	2.1
FW228	ABSORBER-W/D INTERFACE	14	14	14	Struct/Duct/Damper	2.1
FW229	W/D WASH SYSTEM	9	9	9	Struct/Duct/Damper	2.1
FW251	EXPANSION JOINT BETWEEN BY	15	15	15	Struct/Duct/Damper	2.1
FW253	EXPANSION JOINT BETWEEN SC	16	16	16	Struct/Duct/Damper	2.1
FW255	DUCT BETWEEN BYPASS DUCT I	146	146	146	Struct/Duct/Damper	2.1
FW257	DUCT BETWEEN SCRUBBER AND	146	146	146	Struct/Duct/Damper	2.1
FW260	DUCT STRUCTURE BETWEEN DUC	86	86	86	Struct/Duct/Damper	2.1
FW262	DUCT STRUCTURE BETWEEN SCR	86	86	86	Struct/Duct/Damper	2.1
FW280	FOUNDATION MATL FOR DUCT S	10	10	10	Struct/Duct/Damper	2.1
FW281	FOUNDATION MATL FOR SCRUBB	50	50	50	Struct/Duct/Damper	2.1
FW282	FOUNDATION MATL FOR ELEVAT	10	10	10	Struct/Duct/Damper	2.1
FW292	STRUCTURES FOR ELEVATOR	4	4	4	Struct/Duct/Damper	2.1
FW293	ELEVATOR AND ACCESSORIES	4	4	4	Struct/Duct/Damper	2.1
FW314	MISCELLANEOUS- FGD SYSTEM	20	20	20	Struct/Duct/Damper	2.1
FW610	GALLARIES&RAILINGS FOR SCR	218	218	218	Struct/Duct/Damper	2.1
Sub Total of Structure/Duct /Damper		2635	2635	2635		
FW212	SLURRY RECIRCULATION PUMP	80	80	80	Rotary Mc	2.3
FW230	AIR OXIDATION SYSTEM	14	14	14	Rotary Mc	2.3
	RC Pump Motors	208	208	208	Rotary Mc	2.3
	Oxidation Blowers	34	34	34	Rotary Mc	2.3

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 100 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

	motors					
Sub Total of Motors weight		336	336	336		
FW244	OXIDATION AIR DISTRIBUTION	20	20	20	pipng	2.5
Sub Total of Piping		20	20	20		
FW265	LINING OF DUCT BETWEEN SCR	18	18	18	Insulation	2.4
FW267	INSULATION MATERIALS FOR D	40	40	40	Insulation	2.4
FW268	FIXING COMPONENTS AND CLAD	40	40	40	Insulation	2.4
Sub Total of Insulation		98	98	98		
FW226	EMERGENCY QUENCH WATER TAN	22	22	22	Tank	2.2
Sub Total of Tanks		22	22	22		
Sub Total Of Individual FGD Package (A&B)		3111	3111	3111	0	
Total Weight of ESP and FGD plus Trichy Supply excluding Common System		21,075.55	21,050.55	21,050.55		
COMMON SYSTEMS of FGD SYSTEMS (Applicable to unit#1 only)						
PGMA	Description	WT in MT	FGD#1 Weight			
FW710	MONORAIL FOR HOIST & CRANE	60	60		Struct/Duct/Damper	2.1
FW721	AGITATOR SUPPORT	50	50		Struct/Duct/Damper	2.1
FW722	GALLERIES & RAILINGS FOR T	50	50		Struct/Duct/Damper	2.1
FW729	LIMESTONE SILO-SS 304 LINI	10	10		Struct/Duct/Damper	2.1
FW730	LIMESTONE SILO STRUCTURE	385	385		Struct/Duct/Damper	2.1
FW732	LIMESTONE SILO ACCESSORIES	28	28		Struct/Duct/Damper	2.1
FW733	LIMESTONE SILO APPROACH PL	18	18		Struct/Duct/Damper	2.1
FW740	FOUNDATION MATL FOR TANKS	30	30		Struct/Duct/Damper	2.1
FW761	STRUCTURE FOR PIPERACKS	60	60		Struct/Duct/Damper	2.1
FW763	FNDN:MATL FOR PIPE RACK GY	22	22		Struct/Duct/Damper	2.1
FW766	PLATFORM FOR PIPE RACK-LEF	75	75		Struct/Duct/Damper	2.1
FW769	TRESTLE FOR PIPE RACKS	50	50		Struct/Duct/Damper	2.1

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 101 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

Sub Total (Structure.Duct /Damper)		838	838			
FW701	SLURRY PUMPS & ACCESSORIES	60	60		Rotary Mc	2.3
FW702	WATER PUMPS & ACCESSORIES	60	60		Rotary Mc	2.3
FW715	HANDLING EQUIPMENT IN FGD	150	150		Rotary Mc	2.3
FW720	AGITATORS	50	50		Rotary Mc	2.3
FW734	LIMESTONE MILL	470	470		Rotary Mc	2.3
FW736	PRIMARY HYDROCLONE AND ACC	20	20		Rotary Mc	2.3
FW737	SECONDARY HYDROCLONE AND A	10	10		Rotary Mc	2.3
FW738	GYPSUM BELT FILTER AND ACC	180	180		Rotary Mc	2.3
	Wet ball Mill Motor	36	36		Rotary Mc	3.3
Sub Total (Rotary Machine)		1036	1036			
FW751	PROCESS WATER PIPE ACCESSO	85	85		pipng	2.5
FW753	SLURRY PIPE ACCESSORIES	200	200		pipng	2.5
FW754	SERVICE AIR PIPE ACCESSORI	60	60		pipng	2.5
FW755	INSTRUMENT AIR PIPE ACCESS	60	60		pipng	2.5
FW758	VALVES AND FITTINGS COMMON	130	130		pipng	2.5
Sub Total (Piping)		535	535			
FW790	TOOLS	10	0		Sapres	
FW988	COMMISSIONING SPARES	20	0		Sapres	
FW997	MAND SPARE-MECHANICAL	240	0		Sapres	
Sub Total (Spares)		270	0	0		
FW731	LIMESTONE SILO	180	180		Tank	2.2
FW742	LIMESTONE SLURRY STORAGE T	160	160		Tank	2.2
FW743	AUXILIARY ABSORBER TANK	142	142		Tank	2.2
FW744	FILTRATE TANK	18	18		Tank	2.2
FW745	WASTAGE WATER TANK	85	85		Tank	2.2
FW747	HYDROCLONE WASTE WATER TAN	23	23		Tank	2.2
FW748	PROCESS WATER TANK	30	30		Tank	2.2
FW798	AIR RECEIVERS	7	7		Tank	2.2

BHEL-PSWR

E-TS No: BHE/PW/PUR/NTPRT-ESP FGD U1/2199 and BHE/PW/PUR/NTPRT-ESP FGD U2/2200

Technical Conditions of Contract -Volume I A

Page 102 of 159

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

FW802	NEUTRALISATION TANK & ACCE	3	3		Tank	2.2
FW741	LINING FOR TANK AND SUMPS	36	36		Tank	2.2
Sub Total (Tanks)		684	684			
Weight Of Common System		3363	3093	0	0	
Total weight of FGD for Unit#1 (Pkg A)		6474	6204		0	
Total weight of ESP & FGD For U#1 & U#2 (Pkg A & Pkg B)		24438.55	24143.55	21050.55		

Non Billable PGMA

1. 79-988- COMMISSIONING SPARES
2. 79-996 – Tools & Tackles
3. FW790- Tools
4. FW988- Commissioning Spares
5. FW997 – Mandatory Spares

Summary of Estimated Weight (in MT) of Various System in The Scope of Work

1. ESP and Its accessories weight						
Rate Sc ID*	Package	Trichy	BAP	Jhansi	Total (Pkg-A)	Total (Pkg-B)
1.1	ESP		13237.7	684	13,921.700	13,921.700
1.2	Non Pressure Parts (ESP outlet Funnel to chimney)	2,645.45	303.50		2,948.950	2,948.950
1.3	Min wool for ID Duct and ESP Ins	242	490		732.00	732.00
1.4	Fixing component for ID duct & ESP	20.9	131		151.9	151.9
1.5	Insulation Cladding	70	115		185.00	185.00
	TOTAL	2,978.35	14,277.20	684.00	17,939.55	17,939.55

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

2. FGD and Its accessories weight						
Rate Sc ID*	Package	Design Weight	FGD U#1	FGD-Common (Applicable Pkg#A)	Total Weight FGD#1 (Pkg #A)	FGD#2 (Pkg# B)
2.1	Structure/Duct/D amper	2635	2635	838	3473	2635
2.2	Tanks	22	22	684	706	22
2.3	Rotary machines	336	336	1036	1372	336
2.4	Insulation Cladding	98	98	0	98	98
2.5	Piping	20.00	20	535	555	20
	TOTAL	3,111.00	3,111.00	3,093.00	6,204.00	3,111.00
	Grand Total (ESP+FGD)				24,143.55	21,050.55

* Rate Sc ID: Rate schedule ID/ Rate schedule Identifier

NOTE TO WEIGHT SCHEDULE:

- Weight for ESP are same and weight difference is in the FGD systems. Common systems of FGD are in the scope of Unit#1(Pkg-A) only.**
- The information furnished is only a description regarding the items to be erected by the contractor. BHEL reserves the right to add or exclude any components / items / systems according to the site requirements / customer requirements to complete the system in all respects.
- The above detailed Bill of Quantity is furnished for reference.
- The weight indicated above is approximate and liable to vary. However the payment will be made to the contractor for the tonnage actually erected at the respective category as per the quoted / accepted tonnage rate.
- There may be variation or addition of PGMAs, description, weights etc., and any additional scope of work supplied under the above package shall be erected by the contractor and payment will be made as per the quoted / accepted rate in the respective category.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
CHAPTER XI - ESTIMATED WEIGHT FOR VARIOUS SYSTEMS IN SCOPE
OF WORK (BOQ)

6. The erection & dismantling of air blowers and connecting pipes and ducts providing blanks/ dummies at the required locations and conducting gas tightness test is in the scope of the contract and shall be carried out within the quoted rate.
7. Any others/ components which are integral to ESP & Auxiliaries supplied by BHEL Manufacturing Units are also to be erected and commissioned by the contractor within the quoted/ accepted tonnage rate/ Lump sum value.
8. The Erection & Alignment of HV rectifier transformer is in the scope of the contractor. However dry out, testing and commissioning is not in the scope of this contract.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

GENERAL REQUIREMENTS - COMMON TO ALL WORK

Site Visit by the Bidder

12.1 The bidder shall, prior to submitting his tender for the work, visit and examine the site of works and its surroundings at his own expense, and obtain and ascertain for himself on his own responsibility all information that may be necessary for preparing his tender and entering into a contract, and take the same into account in the quoted contract price for the work.

12.2 The bidder shall satisfy themselves about the following factors:

- i) Site conditions including access to the site, existing and required roads and other means of transport/communication for use by him in connection with the work including diverting and re-routing of services.
- ii) Requirement and availability of land and other facilities of his enabling works, establishment of his nursery, office, stores etc.
- iii) Ground conditions including those bearing upon transportation, disposal, handling and storage of materials required for the work or obtained there-from.
- iv) Source and extent of availability of suitable materials, including water etc., and labour (skilled and unskilled) required for work, and laws and regulations governing their use and employment.
- v) Geological, meteorological, topographical and other general features of the site and its surroundings as are pertaining to and needed for the performance of the work.
- vi) The limit and extent of surface and subsurface water to be encountered during the performance of the work, and the requirement of drainage and pumping.
- vii) The type of equipment and facilities needed, for and in the performance of the work:
- viii) The extent of lead and lift required for the work in complete form over the entire duration of the contract, and
- ix) All other information pertaining to and needed for the work including information as to the risks, contingencies and other circumstances which may influence or affect the work or the cost thereof under this contract.

12.3 Scope of work covered under this specification requires quality workmanship, engineering and green belt management along with the supply of all consumables, tools and tackles and testing instruments. The contractor shall ensure timely completion of work. The contractor shall have adequate tools, measuring

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- instruments etc. in his possession. He shall also have adequate trained, qualified and experienced engineers, supervisory staff and skilled personnel. The manpower deployment identified by contractor shall match with above scope of works.
- 12.4 It is not the intent to specify herein all details of all material. Any item related this work not covered by this but necessary to complete the system will be deemed to have been included in the scope of the work.
- 12.5 All the necessary certificates and licenses required to carry out this scope of work are to be arranged by the contractor then and there at no extra cost.
- 12.6 Site testing wherever required shall be carried out for all items / materials installed by the contractor to ensure proper installation and functioning in accordance with drawings, specifications and manufacturer's recommendations.
- 12.7 The contractor shall carryout additional tests if any, which the Engineer feels necessary because of site conditions and also to meet system specification
- 12.8 The work shall be executed under the usual conditions without affecting power plant construction / operation and in conjunction with other operations and contracting agencies at site. The contractor and his personnel shall co-operate with the personnel of other agencies, co-ordinate his work with others and proceed in a manner that shall not delay or hinder the progress of work as a whole.
- 12.9 All the work shall be carried out as per instructions of BHEL engineer. BHE engineer's decision regarding the correctness of the work and method of working shall be final and binding on the contractor.
- 12.10 Wherever Construction sequences are furnished by BHEL, the contractor shall follow the same sequence.
- 12.11 Contractor shall execute the supply and works as per sequence prescribed by BHEL at site engineer. No claims for extra payment from the contractor will be entertained on the grounds of deviation from the methods of execution of similar job in any other site or for any reasons whatsoever. If required by BHEL, the contractor shall change the sequence of his operation so that work on priority sectors can be completed within the projects schedule. The contractor shall afford maximum assistance to BHEL in this connection without causing delay to agreed completion date.
- 12.12 Contractor shall, transport all materials to site (From Storage Yard) and unload at site / working area for inspection and checking. All material handling equipment required shall be arranged by the contractor.
- 12.13 Contractor shall retain all T&P / Testing instrument / Material handling equipment's etc. at site as per advice of BHEL engineer and same shall be taken out from site only after getting the clearances from engineer in charge. The contractor at his cost shall arrange necessary security measures for adequate protection of his

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- machinery, equipment, tools, materials etc. BHEL shall not be responsible for any loss or damage to the contractor's construction equipment and materials. The contractor may consult the Engineer-in-Charge on the arrangements made for general site security for protection of his machinery equipment tools etc.
- 12.14 The Contractor may have to execute work in such a place and condition where other agencies also will be under such circumstances. However, completion time for construction, agreed will be subject to the condition that contractor's work is not hampered by the agencies.
- 12.15 Contractor has to work in close co-ordination with other agency at site. BHEL engineer will co-ordinate area clearance. In a project of such magnitude, it is possible that the area clearance may be less / more at a particular given time. Activities and Construction program have to be planned in such a way that the milestones are achieved as per schedule/ plans. Contractor shall arrange & augment the resources accordingly.
- 12.16 The contractor must obtain the signature and permission of the security personnel of the customer / BHEL for bringing any of their materials inside the site premises. Without the Entry Gate Pass these materials will not be allowed to be taken outside.
- 12.17 Contractor shall remove all scrap materials periodically generated from his working area and collect the same at one place earmarked for the same. Load of scraps is to be shifted to a place earmarked by BHEL. Failure to collect the scrap is likely to lead to accidents and as such BHEL reserves the right to collect and remove the scrap at contractor's risk and cost if there is any failure on the part of contractor in this respect.
- 12.18 The contractor shall ensure that his premises are always kept clean and tidy to the extent possible. Any untidiness noted on the part of the contractor shall be brought to the attention of the contractor's site representative who shall take immediate action to clean the surroundings to the satisfaction of the Engineer in- Charge.
- 12.19 The contractor is strictly prohibited from using BHEL's regular components like angles, channels, beams, plates, pipe / tubes, and handrails etc. for any temporary supporting or scaffolding works. Contractor shall arrange himself all such materials. In case of such misuse of BHEL materials, a sum as determined by BHEL engineer will be recovered from the contractor's bill. The decision of BHEL engineer is final and binding on the contractor.
- 12.20 No member of the already erected structure / buildings, other component and auxiliaries should be removed / modified without specific approval of BHEL engineer.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- 12.21 Some time it may be required to re-schedule the activities to enable other agencies to commence / continue the work so as to keep the overall project schedule.
- 12.22 The terminal points decided by BHEL are final and binding on the contractor for deciding the scope of work and effecting the payment for the work done up to the terminals.
- 12.23 Crane operators deployed by the contractor shall be tested by BHEL before he is allowed to operate the cranes.
- 12.24 Completion of work, all the temporary buildings, structures, pipe lines, cable etc. shall be dismantled and levelled and debris shall be removed as per instruction of BHEL by the contractor at his cost. In the event of his failure to do so, the expenditure towards clearance of the same will be recovered from the contractor. The decision of BHEL Engineer in this regard is final.
- 12.25 It is the responsibility of the contractor to do the checking, testing etc. if necessary, repeatedly to satisfy BHEL Engineer with all the necessary tools and tackles, manpower etc. without any extra cost. The testing will be completed only when jointly certified so, by the BHEL Engineer.
- 12.26 The contractor's work shall not hinder other work, either underground or over ground, such as electrical, phone lines, water or sewage lines, etc. In areas of overlap, the contractor shall work in coordination with other related contractors.
- 12.27 Any damage by the landscape contractor's team to such utilities will be penalized and contractor shall be responsible for cost for such damages.

12.28 SITE INSPECTION

- 12.28.1 The owner / employer or his authorized agents may inspect various stages of work during the currency of the contract awarded to him. The contractor shall make necessary arrangements for such inspection and carry out the rectification pointed out by the owner / employer without any extra cost to the owner / employer. No cost whatsoever such duplication of inspection of work be entertained.
- 12.28.2 BHEL / Customer will have full power and authority to inspect the works at any time, either on the site or at the contractor's premises. The contractor shall arrange every facility and assistance to carry out such inspection. On no account will the contractor be allowed to proceed with work of any type unless such work has been inspected and entries are made in the site inspection register by customer / BHEL.
- 12.28.3 **Wherever the performance of work by the contractor is not satisfactory in respect of workmanship, deployment of sufficient labour or equipment, delay in execution of work or any other matter, BHEL shall have the right to engage labour at normal ruling rates and get the work executed through other agency and debit the cost to the contractor and the contractor shall have no right to**

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

claim compensation thereof. In such a case, BHEL shall have the right to utilize the materials and tools brought by the contractors for the same work.

12.29 DOCUMENTATION

12.29.1 **The following information shall be furnished by the bidder within two weeks of award of contract for purchaser's approval**

- a) Bar chart covering planned activities at site
- b) Detailed organization chart
- c) Details of T&P available with contractors with documents proofs.

12.29.2 The following information shall be furnished by the bidder after testing and inspection: Test certificates of various tests conducted at site. All inspection and test certificates shall be signed by BHEL representative also.

12.30 The intent of specification is to provide services according to the most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for proper and efficient execution of this work shall not relieve the Contractor of the responsibility of providing such facilities to complete the work without any extra compensation.

12.31 The terminal points decided by BHEL shall be final and binding on the Contractor for deciding the scope of work and effecting payment for the work done.

12.32 The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The Contractor and his personnel shall cooperate with personnel of BHEL, BHEL'S Customer, Customer's consultants and other Contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work of the project as a whole.

12.33 The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The Contractor should ensure proper planning and successful & timely completion of the work to meet the overall project schedule. The Contractor must deploy adequate quantity of tools & plants, modern / latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.

12.34 Contractor shall erect and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL Engineer's decision regarding correctness of the work and method of working shall be final and binding on the Contractor. No claims for extra payment from the Contractor will be

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- entertained on the ground of deviation from the methods / sequence adopted in erection of similar sets elsewhere.
- 12.35 All necessary certificates and licenses, permits & clearances required including certificates/license/clearances to carry out this work from the respective statutory/ local authorities are to be arranged by the Contractor at his cost in time to ensure smooth progress of work.
- 12.36 The work shall conform to dimensions and tolerances specified in the various drawings / documents that will be provided during various stages of erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations due to Contractor's fault, the Contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by BHEL and recoveries will be effected from the Contractor's bills towards expenditure incurred including cost of materials and departmental overheads of BHEL as per GCC.
- 12.37 The Contractor shall perform any services, tests etc, which may not be specified but nevertheless, required for the completion of work within quoted rates.
- 12.38 All necessary certificates and licenses required for carrying out this work are to be arranged by the Contractor expeditiously.
- 12.39 The Contractor shall execute the work in the most substantial and workman like manner. The stores shall be handled with care and diligence.
- 12.40 BHEL reserves right to recover from the Contractor any loss which arises out of undue delay / discrepancy / shortage / damage or any other causes due to Contractor's lapse during any stage of work. Any loss to BHEL due to Contractor's lapse shall have to be made good by the Contractor as per GCC.
- 12.41 All cranes, transport equipment, handling equipment, tools, tackles, fixtures, equipment, manpower, supervisors/engineers, consumables etc, except otherwise specified as BHEL scope of free issue, required for this scope of work shall be provided by the Contractor. All expenditure including taxes and incidentals in this connection will have to be borne by Contractor unless otherwise specified in the relevant clauses. The Contractor's quoted rates should be inclusive of all such contingencies.
- 12.42 During the course of erection, testing and commissioning certain rework / modification / rectification / repair / fabrication etc may become necessary on account of feed back / revision of drawing etc. This will also include modifications / re-works suggested by BHEL / customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repair etc promptly and expeditiously. Daily log sheets signed by BHEL engineer and indicating the details of work carried out, man-hours etc shall be maintained by the

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- Contractor for such reworks. Claim of Contractor if any, for such works will be governed by relevant clauses of 'General Conditions of Contract'.
- 12.43 All works such as cleaning, leveling, aligning, trial assembly, dismantling of certain equipments / components for checking and cleaning, surface preparation, fabrication of structures, tubes and pipes as per general engineering practice and as per BHEL Engineer's instructions at site, cutting, gouging, weld depositing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scrapping, lapping, fitting up etc as may be applicable in such erection works and which are treated incidental to the erection works and necessary to complete the work satisfactorily, shall be carried out by the Contractor as part of the work within the quoted rates.
- 12.44 The Contractor shall make all fixtures, temporary supports, steel structures required for jigs & fixtures, anchors for load and guide pulleys required for the work. Contractor shall arrange necessary steel for such usage.
- 12.45 The Contractor shall take delivery of the components, equipments, chemicals, and lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL Engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipments after usage shall be submitted to the BHEL and reconciled periodically.
- 12.46 **Storage yard located at two to three different places and are about 10-12 KM from ESP area (May note that 10-12 KM is a range and a few KMs can be main road and a few KMs may not be main road. Further there are no traffic restrictions as such). Contractor shall plan and transport equipments, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the Contractor's shed and at work areas in an orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, same shall be done by Contractor most expeditiously as incidental to work.**
- 12.47 Plant materials should not be used for any temporary supports / scaffolding/ preparing pre-assembly bed etc.
- 12.48 The details of equipments to be erected under this contract are generally as per the schedule given in relevant appendices. These details are approximate and meant only to give a general idea to the tenderer about the magnitude of the work involved. Actual quantum and type of equipments will be based on the relevant erection documents which will be furnished to the Contractor in due course of erection and the weight and quantity as per the relevant engineering documents will only be admissible for the billing purpose.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- 12.49 **Hangers & Suspensions, supports etc. for tubes, piping, & ducts etc will be supplied in running / random lengths / sizes which shall be cut to suitable sizes and adjusted as required.**
- 12.50 Spring suspension / constant load hangers may have to be pre-assembled for required load and erection carried out as per instructions of BHEL. Adjustments, removal of temporary arrests/locks, cutting of excess thread length of hanger tie-rod etc have to be carried out as and when required. Load setting of spring hangers, as per BHEL's documents/instructions, during various stages of erection & testing and after floating of piping/ducting during cold and hot condition will have to be done as part of work. This exercise may have to be repeated till satisfactory results are achieved.
- 12.51 Layout of field routed/ small bore piping shall be done as per site requirement. Necessary sketch for routing these lines should be got approved from BHEL by the Contractor. There is a possibility of slight change in routing the above pipe lines even after completion of erection.
- 12.52 Welding of necessary instrumentation tapping points, thermowell, thermocouple pad, metal temperature pad and clamps, root valve, condensing vessel, flow metering & measurement devices, and control valves to be provided on pipe lines, tanks, pumps and piping are covered within the scope of this specification. The installation of all the above items will be Contractor's responsibility even if:
- a) Items are not specifically indicated under the respective product groups as given in the technical specifications.
 - b) Items are supplied by an agency other than BHEL.

Pre-heating, NDE, and Post weld heat treatment for above shall be done as per the specifications as part of work.

- 12.53 Certain instrumentation like pressure switches, air sets, filters, regulators, pressure gauges, junction boxes, power cylinders, dial thermometers, flow meters, valve actuators, flow indicators, centrifugal/speed switches of motors, accumulators etc are received in assembled condition as integral part of equipments. Contractor shall dismount such instruments for calibration and hand over the same to BHEL. C & I erection agency will do storage / re-erection calibration etc.
- 12.54 Actuators/drives of valves, dampers, gates, powered vanes etc may have to be serviced, lubricated, before erection, during pre-commissioning & commissioning, including carrying out minor adjustments required as incidental to the work.
- 12.55 All electrical motors have to be tested for IR & PI values prior to the trial run. Where required, dry out may have to be carried out by using external heating source. Contractor shall make all arrangements in this regard and complete the work as instructed. BHEL will provide the motorized insulation testers.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

- 12.56 In installation of various equipments it may become necessary to install these on temporary supports/ hanger due to various reasons including non-availability of suspension materials. Contractor shall install such temporary suspensions/hangers and later on shift the relevant equipments to their respective permanent hangers/suspensions/ supports as incidental to work. Requisite materials for such temporary arrangements will be provided by BHEL on free -returnable basis which shall be returned to BHEL after the use.
- 12.57 The work shall be carried out strictly in accordance to the “Field Quality Plan” approved by BHEL/client. Contractor, jointly with BHEL, shall prepare all necessary records of measurements/readings/ protocols etc.
- 12.58 All works such as cleaning, levelling, aligning, trial assembly, dismantling of certain equipments / components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per the general engineering practice and as per BHEL engineers instructions at site, cutting, weld desposing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scraping, lapping, fitting up etc as may be applicable in such erection works and which are treated incidental to the erection work and necessary to complete the work satisfactorily shall be carried out by the Contractor as part of the work.
- 12.59 Interconnection/ hookup, if any, with the existing system shall form part of work. Such interconnections, hookups may require shut down of running plant and the relevant work have to be completed within such planned shutdowns. This may call for working with enhanced resources and on extended hours. Contractor's offer shall cover all such contingencies.
- 12.60 Contractor shall regulate flow of material to and from site in such a manner and sequence that material accumulation at site does not lead to congestion at site. In case it is necessary to shift and restack the materials kept at work areas / site to enable other agencies to carry out their work or further any other reason, it shall be done by the Contractor most expeditiously. No claim for extra payment for such work will be entertained.
- 12.61 It may so happen that certain components like manhole doors, hanger etc may be supplied in loose items. They need to be assembled as per relevent drawings or as per advice of BHEL engineer prior to erection. This forms the part of the scope of work.
- 12.62 **The Contractor shall have total responsibility for all equipment and materials in his custody at Contractor's stores, loose, semi-assembled, assembled or erected by him at site. He shall effectively protect the finished works from action of weather and from damages or defacement and shall also cover the finished parts immediately on completion of work as per BHEL engineer's**

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XII General

instructions. The machine surfaces/finished surfaces should be greased and covered.

- 12.63 BHEL is operating web based computerized E-store system that includes, inter-alia, issue of materials, daily progress reporting, Contractor's running monthly billing and material reconciliation through a computerized data management system. Contractor shall install necessary hardware to hook-up with the BHEL's system and use the same for his scope of work.
- 12.64 In the event the computerized E-store/SOMS is inoperative for any reasons, the Contractor shall take delivery of materials from the storage area/sheds of BHEL/customer after getting the approval of the engineer/customer on standard indent forms to be specified by BHEL/customer. All these records however shall be updated in the E-store/SOMS as and when the E-store/SOMS is reactivated/normalized.
- 12.65 The Contractor shall take delivery of the components, equipments, chemicals, and lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL Engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipments after usage shall be submitted to the BHEL and reconciled periodically.
- 12.66 **There are few locations of storage yard within/beside plant premises. Major storage yard is located outside the Main Plant Boundary, in more than one location, at a distance of approximately 10-12 KM from the erection site (May note that 10-12 KM is a range and a few KMs can be main road and a few KMs may not be main road. Further there are no traffic restrictions as such).** Contractor shall plan and transport equipments, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the Contractor's shed and at work areas in an orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, same shall be done by Contractor most expeditiously as incidental to work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

13 DETAILS OF SCOPE OF WORK FOR ESP, AUXILIARIES & NPP

The scope of work is further detailed in the specifications hereinafter.

The scope of the work will comprise of but not limited to the following:

(All the works mentioned hereunder shall be carried out within the accepted rate unless otherwise specified.)

13.1 ERECTION OF ELECTROSTATIC PRECIPITATOR

13.1.1 Wherever called for, pre-assembly of supporting structures, casing walls, inlet outlet funnels, hoppers etc have to be done, on ground.

13.1.2 Loading of collecting electrodes either from top or bottom, to be decided suiting site conditions, shall be done with due care as per instructions.

13.1.3 Straightness of all collecting electrodes has to be checked on ground prior to loading in to the field.

13.1.4 Bundle of collecting electrodes should be handled only with special lifting beam and slings supplied for the purpose.

13.1.5 Huck bolting M/c with necessary auxiliaries is provided by the BHEL. Electrical connections, operation etc shall also be arranged by the Contractor.

13.1.6 Clearances as prescribed amongst collecting electrodes and with casing walls have to be maintained. spot heating of collecting electrodes, wherever called for, shall be done as part of work to achieve the required clearances.

13.1.7 Erection, alignment/ fixing in final position, of high voltage rectifiers of ESP is in the scope of work. However testing & commissioning will be done by other agency.

13.1.8 Installation of high voltage interlocks (excepting rotary switch interlock of switchgear panels) is in the scope of work.

13.1.9 Complete erection, alignment, testing, pre-commissioning and commission etc for drive motors of collecting electrodes and emitting electrode rapping mechanism is in the scope of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.1.10 Additional platforms of permanent nature for approaching different equipments, as per site requirement which may not be indicated in drawings shall be fabricated and installed by the contractor. However the contractor will be paid (as per Rate Schedule 1.2 of ESP Pkg) for this work on accepted tonnage rate for erection. The material required for platform will be supplied by BHEL free of cost.
- 13.1.11 All the bearings, Gearboxes etc., of the equipment and electrical motors to be erected are provided with protective greases only. Contractor shall arrange as and when required by the engineer for cleaning the bearing/gear boxes etc., with kerosene or some other agent if necessary by dismantling some of the parts of the equipment during erection and shall arrange for regressing/ lubricating them with recommended lubricants and assembling back.
- 13.1.12 Any fixtures, concrete block supports, steel structures required for temporary supporting for pre-assembly or checking and welding for lifting and handling during pre-assembly and erection shall be arranged by the contractor.
- 13.1.13 Fixing, welding of necessary instrumentation tapping points for regular measurements as well as performance testing, to be provided on auxiliaries covered within the scope of this specification will also be the responsibility of the contractor and will be done as per the instructions of BHEL Engineer. The fixing / welding of all the above items will be contractor's responsibility even if the
- i. Product groups under which these items are supplied are not specifically indicated in the Tender Specification.
 - ii. Items are supplied by an agency other than BHEL.
- 13.1.14 Suspension for pipes/Ducts will be supplied in running lengths which shall be cut to size and adjusted as required. All joints connecting ducts, expansion pieces shall be seal welded on inside and as well outside. Also it may sometime become necessary to remove any of the erected members to facilitate erection of bigger / pre-assembled equipment. In such as the removal and re-erection of such members, which are essential will have to be carried out by the contractor without any extra payment.
- 13.1.15 In the case of structural members / ducts, in certain cases, the raw material will be supplied in random lengths and the contractor will have to make up the length/prepared the edges to suit the matching profile weld/bolt connect the joints at no extra cost.
- 13.1.16 Normally, the matching profile will be cut out for the structural members but the contractor will have to carry out suitable alterations / adjustments at site, without any extra payment, in case it becomes necessary.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.1.17 Contractor has to arrange required fire proof tarpaulins to protect the machined components / assembled parts drawn from BHEL before and after erection at their cost.
- 13.1.18 It is the responsibility of the contractor to do the alignment, checking, etc. if necessary, repeatedly to satisfy BHEL Engineer / Customer Engineers with all the necessary tools and tackles, manpower etc. without any extra cost. The alignment will be completed only when jointly certified so, by the BHEL Engineer & Customer. Also the contractor should ensure that the alignment is not disturbed afterwards.
- 13.1.19 Works such as minor rectification of foundation bolts, reaming of holes, drilling of dowels, matching of bolts and nuts, making new dowel pin etc. are covered in the scope of work.
- 13.1.20 Contractor shall engage separate gangs throughout the contract period, exclusively for proper housekeeping of the site. The contractor has to make necessary arrangements for collection and for bringing down the scrap from various locations as indicated by BHEL Engineer. The housekeeping must be a routine and continuous activity in the various work fronts. If the contractor does not do this job satisfactorily, BHEL will arrange for the same at the cost of the contractor. Periodical payments to the contractor for the work done will be considered only if the housekeeping is certified as satisfactory by the customer.
- 13.1.21 It is the responsibility of the contractor to engage his workmen in shifts or on overtime basis for achieving the desired progress and target set by BHEL. The contractor's quoted rate shall include all these contingencies.
- 13.1.22 All the valves, lifting equipments, etc. shall be serviced and lubricated to the satisfaction of BHEL Engineer before erecting the same and also during pre commissioning. The bearings shall be properly cleaned, serviced and lubricated before commissioning at no extra cost. Even after commissioning the equipment, if there are problems in the operation they have be attended to by the contractor during the tenure of the contract. Welding or joining of

13.2 AIR LEAK TEST

After erection of ESP and before clearing for insulation, air leak test has to be carried out. Necessary equipment like, air blower, ventury and instrumentation etc. will be provided by BHEL free of charges. Handling at stores, transport, erection, commissinoning and carrying out the leakage test, attending to the leakages till satisfactory sealing / leak proofness shall be in scope of the work. Contractor shall dismantle the test equipments and return to BHEL stores in good condition after due reconciliation, cleaning and servicing. No separate/ additional payment is envisaged for the above.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

13.3 MAIN SUPPORTING STRUCTURES, EXTERNAL STRUCTURES, ELEVATOR STRUCTURES, STAIRWAYS, GALLERIES & PLATFORMS & HANDLING ARRANGEMENT

- 13.3.1 In some cases, the structural material will be supplied in random lengths, which have to be fabricated to suit the requirement as incidental to work. Also, it may sometimes be necessary to remove some of the erected members to facilitate erection of bigger/ pre-assembled equipments. In such cases, the removal and re-erection of such members as agreed by the BHEL Engineer, will have to be done by the Contractor as incidental to work.
- 13.3.2 Contractor shall arrange materials required for temporary cat ladders & working platforms during erection of columns, platforms and other structural components. Such arrangements shall, as far as possible, be only of clamping & bolting type, as welding on columns etc will not be permitted. After the completion of work these shall be removed.
- 13.3.3 All the hand rails and toe guards shall be provided as per drawings and site requirement. hand rails supplied in running lengths shall be suitably cut, edge prepared and welded. Also, hand rails/ guards may have to be provided from the safety point of view in certain places though not indicated in the erection drawings. The weld joints of hand rails shall be ground smooth to flush finish.
- 13.3.4 Electroforged floor grills will be supplied for this project. These may have to be cut to suit requirement. Cutting shall be done only by mechanical cutters **and not by gas cutting**. Cold galvanizing compound is to be applied on the cut surface/edge. Cold galvanizing paint supply is in Contractor scope.
- 13.3.5 Fixing of floor grills shall be done by self-tapping screws **and not by weldable studs**. Special purpose electrically operated hand tools are available in the market for this, which drills, taps and fixes the screws in a single operation. Supply of necessary self-drilling-cum-tapping screws and fixing clips are in contractor scope. Contractor shall deploy the **drilling cum fixing machine** required for this purpose as a regular scope of work.
- 13.3.6 The Contractor shall also install additional platforms of permanent nature for approaching different equipment as per the site requirement and to meet O&M requirements, though these may not indicated in the erection drawings. Materials

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

required for such platforms will be supplied by BHEL in random sizes on free issue basis. These have to be fabricated to suit the requirement. Payment only for erected weight as certified by BHEL engineer shall be made at the rate applicable for structures. No payment is envisaged for fabrication of structures.

- 13.3.7 All relevant provisions as above shall apply, mutatis-mutandis, to the work of external structures, interconnecting structures, elevator structures, ESP stairways and galleries & equipment handling system etc.

13.4 OTHER PRODUCTS AND SYSTEMS AND COMMON REQUIREMENTS

- a) The ducting covered under this scope of work is, ESP to ID fans & ID Fan to chimney, dampers/gates and their drives, supports and suspensions etc for these systems.
- b) Ducts / expansion bellows (metallic & non-metallic) are normally supplied in loose components / segments and these are to be assembled and welded/ jointed at site before erection. The fabric portion of non-metallic expansion joints (NMEJ) namely bolster, fabric belt and canopy shall be installed by Contractor under supervision/guidance of equipment supplier/BHEL for the first few cases. Contractor shall ensure that all subsequent NMEJ are assembled with due care and proper procedure. In similar manner all joints, connecting ducts, expansion pieces and dampers shall be seal welded. These welds have to be made leak proof and tested as per technical instruction / requirement.
- c) Certain structural items like ~~silencer supports~~, roof cladding structure, platform etc will be supplied in running lengths which shall be cut to required suitable sizes and adjusted/trimmed as part of work.
- d) Contractor has to make canopies for motors (If no supplied by the BHEL units), actuators, ~~lub oil units, control valves, etc.~~ material for this will be supplied in random lengths / sizes. No separate payment for fabrication is envisaged. Only the erection tonnage rate applicable for structure will be paid for this work.
- e) Actuator / drives of dampers, gates etc may have to be serviced, lubricated before erection, during precommissioning and commissioning, including carrying out adjustments required as incidental of the work.
- f) All welded joints should be painted with anticorrosive paint / primer immediately after completion of all work. Necessary paints and other consumables for the above work are in the scope of the Contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- g) Hangers and suspensions, support steels for ducts and other equipments, ~~piping~~ etc will be supplied in running/random lengths/ sizes, which shall be cut to suitable sizes and adjusted as required.
- h) Touch up and preservative painting of all components issued to and/or erected by Contractor shall form part of scope of work. The Contractor shall arrange all paints, primer and consumables, T&P and facilities.
- l) **ARRANGING PAINTS, PRIMERS FOR TOUCHUP PAINTING (AS APPLICABLE) AS PER TENDER SPECIFICATION FOR ALL ERECTED MATERIALS UNDER SCOPE OF ESP PACKAGE IS IN THE SCOPE OF CONTRACTOR.**

13.5 Erection Sequence of FGD

- 13.5.1 All normal erection and assembly techniques necessary for completion of works under this specification and magnitude have to be carried out. The omission of specific technique /method/process does not absolve the contractor of his responsibility for the particular operation. These would include,
 - 13.5.1.1 Scaffolding and rigging operations,
 - 13.5.2.2 Machine / flame / electric cutting, grinding, welding, radiography and stress relieving.
 - 13.5.2.3 Fitting, fettling, filing, straightening, chamfering chipping, scrapping, reaming, as cleaning, checking, levelling, blue matching, aligning and assembly.
 - 13.5.2.4 Machining, surface grinding, drilling, doweling, shaping
 - 13.5.2.5 Temporary erections for alignment, dismantling of certain equipment for checking, cleaning, servicing and site fabrication.
 - 13.5.2.6 Insulation and painting
- 13.5.2 Any fixtures, scaffolding materials, approach ladder, concrete block supports, steel structures required for temporary supporting, pre-assembly or checking, welding, lifting and handling during pre-assembly and erection shall be arranged by contractor at his cost.
- 13.5.3 No members of any ladder / structure / platform should be cut without specific approval of BHEL. In case it is necessary to cut, the contractor shall rectify / repair in a manner acceptable to BHEL / customer without any additional cost.
- 13.5.4 The contractor shall erect scaffolding / temporary platforms for erection. These should be of adequate capacity and shall never be over loaded. These should be

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

replaced when not found suitable during erection work and dismantled on work completion and removed from work site.

13.5.5 It shall be the responsibility of the contractor to provide ladders on columns for initial work till such time stairways are completed. For this, the ladder should not be welded on the column and should be pre-fabricated clamping type ladders. No temporary welding on any structural member is permitted except under special circumstances with the approval of BHEL. In case it is absolutely necessary then the contractor shall cut the temporary structure and rectify the column as directed by the engineer.

13.5.6 The contractor is strictly prohibited in using the FGD/ Auxiliary Components for any temporary supporting or scaffolding works etc. In case of such misuse a sum of determined by Engineer will be recovered from contractor's bills.

13.5.7 Below mentioned erection sequence is indicative only and give the general idea to the contractor for absorber erection. :

1. Marking and packer liner setting
2. Bottom plate installation
3. Ist stage casing panel installation
4. Baffle panel installation
5. Scaffolding and Structure up to 24.8 Mtr.
6. 2nd stage casing panel installation
7. Scaffolding and Structure up to 28.5 Mtr.
8. 3rd stage casing panel installation
9. Inlet duct panel installation
10. Scaffolding and Structure up to 31.75 Mtr.
11. 4th stage casing panel installation
12. Scaffolding and Structure up to 35.4 Mtr. and spary pipe installation
13. 5th stage casing panel installation
14. Scaffolding and Structure up to 39 Mtr.
15. 6th stage casing panel installation
16. Scaffolding and Structure up to 43 Mtr.
17. 7th stage casing panel installation
18. Scaffolding and Structure up to 47 Mtr. and remaining structure erection
19. Ceiling panel installation
20. Rubber lining (Only to indicate erection schedule).
21. Dismantling of scaffolding up to mist eliminator level

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

22. Absorber internals (Spray pipe and mist eliminator) installation
23. Dismantling of scaffolding up to spray pipe level
24. Absorber internals (Spray pipe and spray nozzle) installation
25. All scaffolding dismantling
26. Fiber grating installation
27. Agitator installation

13.5.8 Casing Panel Installation

- i. Splices of bottom plates at which casing panel are located shall be cleaned.
- ii. Location of casing shall be marked on the foundation. Then, according to the casing panel assembly drawings, the location of vertical splices between plates shall be marked.
- iii. Temporary assembly of lower stage casing panel shall be done by Tack-weld the guide pieces to the bottom plate at prescribed intervals of inside and outside the circular marking.
- iv. Temporary assembly of upper stage casing panel shall be done As per Match marks which have been provided on the inside surface of the lower stage casing panel shall be matched to vertical splice line and assembled.
- v. After that welding of the casing panel to be done The weld between lower stage casing panel and bottom plate shall be performed in a suitable time after the completion of vertical splice for lower stage casing panel.
- vi. Vertical splice shall be welded from side by back step method of 1/3 of wall plate width after the completion of assembly of upper wall plate. After the welding from outside, grinding from inside shall be performed with grinder. Welding of horizontal splices shall alternate across the 1st wall. 2nd wall weld's shall be laid simultaneously.
- vii. Spacers used for root gap of welds shall be removed.
- viii.
 1. Appurtenances such as manholes and nozzles shall be installed after marking on correct locations in accordance with the layout dwgs. The time to install then shall be decided in consideration of site construction progress.
 2. The location of large diameter nozzles which will be connected to rubber line pipes shall be determined in accordance with the final piping locations which shall be set at the site.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

13.5.9 Spray Pipe Installation

- i. Check all concerned absorber dimensions, i.e. tolerance of absorber casing, support beam location, absorber nozzle location, flange face location, bolt hole location, size and spacing etc., before Spray Pipe installation.
- ii. Install the temporary support on absorber nozzles for inserting Spray Pipe into absorber. The temporary support shall be installed at almost the same height of bottom of Spray Pipe
- iii. Lift Spray Pipe up to the same height as absorber nozzle.
- iv. Insert the tip of Spray Pipe into the absorber, and unload the tip of Spray Pipe onto the temporary support.
- v. Insert Spray Pipe into the absorber by using of chain block.
- vi. Insert bolt to Spray Pipe flange and Spray Pipe saddle, and tighten as temporary. Then check the horizontal level and insert shim plate to adjust the horizontal level. The level tolerance should be referred to specific drawing.
- vii. Tighten all the bolts and nuts. In case of dissimilar material between Spray Pipe flange (especially FRP made) and absorber flange, bolt tightening procedure should be strictly complied with the specific drawings in order to prevent the crack on the flanges.
- viii. Loosen the saddle setting bolts and nuts by half rotation to allow the Spray Pipe thermal expansion, and then lock the nuts by double nuts fixing.

13.5.10 Spray Nozzle

- i. Modify the scaffolding for installation of Spray Nozzle. Set the Spray Nozzle on the Spray Pipe flange, and tighten the bolts and nuts up to about 75% of full torque by using of torque wrench.
- ii. Check the horizontal level of Spray Nozzle face within the tolerance which is specified in the drawings, and tighten up to full torque. This level is most important for FGD performance. The special care shall be taken to SiC made Spray Nozzle, since these are weak against mechanical shock and impact.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

13.5.11 Mist Eliminator Installation

- i. Check all concerned absorber dimensions, ie. tolerance of absorber casing, support beam location, bolt hole location, size and spacing etc., before installation of Mist Eliminator.
- ii. Insert the lower washing spray pipe into the absorber. In order to protect the FRP made pipe, do not slide the pipe on the support.
- iii. Insert the dedicated shim plates between pipe and pipe support, and fixing Ubands or U-bolts and external flanges.
- iv. Install the lower panel of Mist Eliminator and tightly coupled each other by means of comb brace and tie insulock.
- v. Install the lower down washing spray pipe and upper up washing spray pipe a same manner as the above.
- vi. Install the upper panel of Mist Eliminator, and install upper washing spray pipe as same manner as the above. After installation of Mist Eliminator, to protect the panels by means of load spreaders e.g. wooden planks to allow walking on them during further stage of installation.

13.6 Certain adjustment in length may be necessary while erecting pipelines / ducts / casings etc. The contractor should remove the extra lengths / add extra lengths to suit the final layout after preparing edges afresh by adopting specified heat treatment procedures.

13.7 Suspensions for ducting will be supplied in running lengths, which shall be cut to size and adjusted as required. Ducts / expansion bellows are dispatched to site in loose walls plates / pieces and these are to be assembled and welded at site along with stiffeners etc., before erection within the finally accepted rates. All joints connecting duct expansion piece and dampers shall be seal welded on inside as well as on outside.

13.8 Mechanical erection works associated with the power cylinders, valves, valve actuators etc., coming under various groups shall be provided by contractor within the finally accepted rates. The Erection, testing and commissioning of all electrically operated valves, actuators and dampers is covered within the scope of this specification.

13.9 The contractor shall carry out trial run of all motors including checking the direction of rotation in the uncoupled condition. Checking of alignment and recoupling of the motor to the driven equipment as per instructions of BHEL

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

engineer and to their satisfaction. All electrical motors have to be tested for IR & PI values prior to the trial run. Where required, dry out may have to be carried out by using external heating source. Contractor shall make all arrangements in this regard and complete the work as instructed. Vendor shall all necessary MMDs including the motorized insulation testers for the above test.

- 13.10** The contractor shall fabricate pipe, special bends etc., threading and welding as required for installing lube oil system and carry out the acid cleaning of the fabricated piping. The contractor shall also service the lube oil system, carrying out the hydraulic test of oil coolers etc.
- 13.11** Contractor shall carry out kerosene testing of all bearing housings of various rotating equipment like pumps, fans etc., as per BHEL engineer's instructions. Performance of hydro test of oil coolers of rotating machines and hydro test of other equipment as per BHEL engineer's instructions is included in the scope of work. Forced lube oil system of motors or rotating equipment form parts of the work under this specification.
- 13.12** Certain rotating machinery after initial runs and commissioning of the equipment have to be hot aligned as per the instructions of BHEL engineer. Cleaning fans, ducting etc., free of extraneous steel, scaffolding materials electrodes, all foreign materials etc., before trial run of rotating machinery, and at various stages of pre-commissioning activities as per BHEL engineer's instruction, is within the scope of work.
- 13.13** Some of the rotating equipment and electrical motors are provided with protective greases only. Contractor shall arrange for cleaning of the same with kerosene or some other reagent. If necessary, dismantling some of the parts of the equipment would be necessary. He shall arrange for re-greasing / lubricating them with recommended lubricants and for assembling back the dismantled parts, at quoted rate. Lubricants will, however, be supplied free of cost by BHEL.
- 13.14** After initial trial of rotating equipment, control and power cabling for motors and other equipment / instrumentation shall have to be disconnected for checking alignment and re-setting / re-alignment / hot alignment. Contractor shall have to arrange for disconnecting control and power cabling as per BHEL engineer's instructions and clearance and reconnect the control and power cabling after realignment. Quote tonnage rate shall be inclusive of the above.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.15** Packer plates supplied may have to be machined to the correct dimensions. It may also be necessary to blue match the same with each other/ with equipment / with foundations as per BHEL instructions
- 13.16** Contractor shall arrange changing of preservative oil in the gearboxes, journal and other bearing assemblies of rotating equipment when in storage areas or after erection of equipment as the case may be as per the instructions of BHEL engineer. Necessary lubricants / oil will be supplied by BHEL and the same will be drawn by contractor from BHEL / customer's stores and transporting to site. No additional payment will be made for such works even though supply of lube oil might have been made under regular dispatch-able unit (DU) number against product group main assembly (PGMA) and appearing in the shipping list. Prior to the commissioning of the equipment, oil should be drained and collected in drums provided by BHEL and returned to BHEL / customer's stores.
- 13.17** The fans, mills and other rotating machines shall be checked for clearances and other vital tolerances. Necessary assistance for balancing of equipment during trial run, if required, shall be provided by the contractor free of cost.
- 13.18** Whenever required the contractor shall arrange for pre-qualification of process task Performers.
- 13.19** Ducts/ expansion bellows (metallic & non-metallic) are normally supplied in loose wall plates/ segments and these are to be assembled and welded at site before erection. Correction of ovalities/ distortion of ducts, expansion bellows etc occurred during transportation/ handling are to be carried before erection as part of work. Erection of mechanical components of non-metallic joints is included in the scope of work. All joints connecting ducts, expansion pieces and dampers shall be seal welded. These welds have to be made leak proof and tested as per technical instruction / requirement.
- 13.20** Non specified jobs at the interface / terminal points like bolting welding, gasket changing etc. have to be done by the contractor within the quoted price.
- 13.21** Instrument tapping coming on the FGD and associated equipment's to be welded/fitted by the contractor with in the quoted price.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.22** The terminal points decided by BHEL should be final and binding on the contractor for deciding the scope of work and effecting payment for the work done.
- 13.23** Actuators / drives of dampers, gates, powered vanes etc. may have to be serviced, lubricated, before erection, during pre-commissioning & commissioning, including carrying out minor adjustments required as incidental to the work.
- 13.24** All rotating machines and equipment shall be cleaned, lubricated, checked for their smooth rotation, if necessary by dismantling and refitting before erection. If, in the opinion of Engineer, the equipment is to be checked for clearance, tolerance at any stage of work or during commissioning period, all such works are to be carried out by contractor at his cost.
- 13.25** All the shafts of rotating equipment shall be properly aligned to those of the matching equipment within design tolerances All bearings, shafts and other rotating parts shall be thoroughly cleaned and suitably lubricated before starting.
- 13.26** All the motors and equipment shall be suitably doweled after alignment of shafts with taper / parallel machined dowels as per the direction of the Engineer. Dowel pins required are to be machined by the contractor at his own cost. However the materials for dowel pins shall be issued by BHEL free of cost.
- 13.27** The HT motor bearings shall be blue matched at site and checked for bearing clearances. The contractor if required shall carry out scraping of bearing housing. No extra claim for blue matching up to 1mm initial gap will be entertained.
- 13.28** The contractor at no extra cost to BHEL shall carry out servicing and realignment of skid mounted equipment.
- 13.29** Certain instruments like pressure gauges, pressure transmitters, temperature gauges, flow switches and indicators, etc., are received in assembled condition as integral part of equipment. Contractor shall be responsible for safe receipt, installation and custody of these instruments supplied mounted on skids / equipment. The calibration of skid / equipment mounted instruments shall be arranged by BHEL through other agency engaged for C&I. Contractor will be informed by BHEL engineer about the details of C&I agency. The contractor shall coordinate with the C&I agency for removal, calibration and re-installation of the instruments. Though C&I agency will remove and reinstall the instruments after

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

calibration, the contractor for this package will maintain the list of all the instruments removed & reinstalled. Instruments prior to removal and after reinstallation shall be considered in custody of the contractor for this package.

- 13.30** All electrical panels, control gears, motors and such other devices shall be properly dried by heating to improve IR value, before they are energized. Bearings, slip rings commutators and other exposed parts shall be protected against moisture ingress and corrosion during storage and periodically inspected.
- 13.31** The contractor shall completely erect and test all the piping systems, covered in the specification including sampling lines up to and including sample coolers, hangers & supports, valves and accessories in accordance with the drawings furnished. This includes all necessary bolting, welding, pre-heating, stress relieving, testing, cleaning and painting. System shall be demonstrated in condition to operate continuously in a manner acceptable to the Engineer. Welding shall be used throughout for joining pipes except where flanged, screwed or other type joints are specified or shown on the drawings. All piping shall be erected true to the lines and elevation as indicated in the drawings.
- 13.32** Pipes sent in standard length shall be cut to suit the site conditions and the layouts. Tubes or pipes wherever deemed to be convenient will be sent in running lengths with sufficient bends. Bends upto 65-mm nominal bore will have to be fabricated at site. Only cold cutting methods are to be employed for cutting of pipes and tubes irrespective of the size and material. Gas Cutting, if any, will be allowed only in CS LP piping.
- 13.33** The contractor shall ensure lowering of pipes in position with adequate precautions as to avoid any damage to either material or men. Only the anchoring points earmarked for the purpose of lowering the pipes are to be used.
- 13.34** It is possible that a few flanges may not be matching. The contractor shall be required to cut and re-weld the same as and when required without any additional cost.
- 13.35** Wherever piping erected by the contractor is connected to equipment / piping erected by the other agencies the joint at the connecting point shall be the responsibility of the contractor who is erecting the piping under this specifications.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.36** Normally the high-pressure valves will have prepared edges for welding. But, if it becomes necessary, the contractor will prepare new edges or recondition the edges by grinding or chamfering to match the corresponding tubes and pipes within the scope of the work.
- 13.37** All fittings like 'T'-pieces, weld neck flanges, reducers etc., shall be suitably matched with pipes for welding. The valves will have to be checked, cleaned or overhauled in full or in part before erection and during commissioning.
- 13.38** The contractor shall be responsible for correct orientation of all valves so that seats, stems and hand wheels will be in desired location. It is the responsibility of the contractor to obtain the information regarding orientation of valves not fully located on drawings before the same are installed.
- 13.39** Suspension for piping, etc., will be supplied in running lengths, which shall be cut to suitable sizes and adjusted as required.
- 13.40** The adjustment of all hangers & supports erected in both cold & hot conditions for maintaining the proper slopes towards the drain pots and application of cold pull in the piping wherever required is also included in the scope of the contractor.
- 13.41** Spring suspensions / constant load hangers have to be pre-assembled for required load and erection carried out as per instructions of BHEL. Any adjustments, removal of temporary arrests / locks etc., have to be carried out as and when required.
- 13.42** Contractor shall install piping in such a way that no excessive or destructive expansion forces exists in either the cold condition or under conditions of maximum temperature and pressure. All bends, expansion joints and any other special fittings necessary to take care of proper expansion shall be incorporated as per the advice of Engineer. During installation of expansion joints, anchors, care must be taken to see that full design movement is available at all times from maximum and minimum temperature.
- 13.43** The hanger assemblies shall not be used for attachment of rigging to hoist the pipes into position. Other means shall be used to securely hold the pipe in position

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

till pipe supports are completely assembled and attached to the pipe and building structure.

- 13.44** Layout of small-bore piping, oil systems etc. as required shall be done as per site requirement. Necessary sketch for routing these lines should be got approved from BHEL by the contractor. There is a possibility of slight change in routing the above pipelines even after completion of erection or from aesthetic point of view. Contractor at no extra cost should carry this out. As built drawing is to be submitted by the contractor after erection completion.
- 13.45** All the valves, including motorized valves, flap valves, dampers, actuators, etc. shall be serviced and lubricated to the satisfaction of Engineer before erecting the same and during pre-commissioning also. Welding or jointing of extension spindle for valves to suit the site conditions and operational facility shall be part of erection work within the quoted rates.
- 13.46** Erection and welding of necessary instrumentation tapping points, thermocouple pads, thermo-wells, valves, battery of first root valves, condensing vessels, flow nozzles and control valves to be provided on, auxiliaries and pipe lines are covered within the scope of this specification. This will be the responsibility of the contractor and will be done as per the instructions of BHEL Engineer. The welding of all the above items will be contractor's responsibility even if the:
- a. Product groups, under which these items are released, are not covered in the scope of this tender.
 - b. Items are supplied by any agency other than BHEL.
- 13.47** The contractor shall carry out the tightening of the field bolts on the equipment and piping covered under this specification by using either the calibrated torque wrench method or the turn of part method. The methods used the tools and the equipment deployed shall be subject to the approval of Engineer. The competent technicians shall carry out the bolting work.
- 13.48** The contractor shall prepare as built piping drawing & submit to BHEL Engineer for approval & verification of material used.
- 13.49** Plate Type Heat exchangers will be supplied for cooling of Auxiliary Cooling water lines. Vendor scope covers erection of these PHEs as per the instruction of BHEL engineers.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.50** Contractor has to make canopies for motors, actuators, lub oil units, control valves etc. Material for this will be supplied in random lengths / sizes. No separate payment for fabrication is envisaged. Only the erection tonnage rate applicable for Misc eqpt. / structure steel item no. 3 of rate schedule will be paid for this work.
- 13.51** BHEL will provide free of cost only the shims and packer plates (either machined or plain) which go as permanent part of the equipment. Certain packer plates and shims over and above the quantity received as a part of supplies from manufacturing units of BHEL, will have to be cut out from steel plates / steel sheets at site to meet site requirement. Contractor shall cut and prepare packers and shims by gas cutting/chiseling / grinding/machining and de-burr the same. However, machining of the packers wherever necessary shall be arranged by the contractor.
- 13.52** All lifting tackles including wire-ropes slings, shackles, used by the contractor, shall be got approved by BHEL Engineer. It will be the responsibility of the contractor to ensure safe lifting of the equipment taking due precautions to avoid any accidents and damages to equipment and personnel. Calibration/fitness testing certificates from recognized agency are to be submitted to BHEL site office for equipment/instrument/appliances to be used, as per requirement of BHEL/ISO system. Expenditure on such works forms a part of the scope of work.
- 13.53** The contractor shall erect scaffoldings/Temporary platforms supports etc required during erection before the permanent supports are erected. These should be of adequate capacity and shall never be overloaded. These should be replaced when not found suitable during erection work. All structure materials required for the above shall be arranged by the contractor at his own cost. No such material shall be supplied by BHEL in any case. Welding of temporary supports, cleats etc on the columns shall be avoided. In case of absolute necessity, contractor shall take prior approval from BHEL Engineer. Further, any cutting or alteration of member of the structure or platform or other equipment shall not be done without specific prior approval of BHEL Engineer.
- 13.54** Tanks shall be supplied by the units in more than one segment (rolled sections) having height of segment approx. 2500 mm. Contractor have to complete the assembly at site with necessary welding/NDT/testing as per the approved FQP. Rubber lining of the tanks shall be in the scope of the rubber lining vendor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIII ESP, FGD, Auxiliaries and Piping

- 13.55** Lime stone silos shall be supplied by the units in more than one segment (3 to 4 segment) and height of segment shall be 2500 mm. Contractor shall have to complete the assembly at site with necessary welding/NDT/testing as per the approved FQP. Rubber lining of the tanks shall be in the scope of the rubber lining vendor.
- 13.56** complete the assembly, final welding,/NDT/testing as per the approved drawings/ documents FQP.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIV FOUNDATIONS & GROUTINGS

14 PREPARATION OF FOUNDATIONS, AND GROUTING OF EQUIPMENT OF ESP & AUXILIARIES & FGD & ITS AUXILIARIES

- 14.1 Minor adjustment of foundation level, dressing and chipping of foundation surfaces and blue-matching (wherever required) for of all equipments as per BHEL Engineers instructions, should be done by the Contractor as part of the work. Contractor/BHEL shall prepare protocols before taking over the foundations. Dressing and chipping of foundations up-to 20 mm for achieving proper levels will be within the scope of work/specification.
- 14.2 All temporary foundations and anchor points required for installing erection Equipments and winches, foundations for pumps, tanks etc are in the scope of Contractor. All building materials like cement, steel including re-inforcement bars, grits cements etc for such temporary foundations shall have to be arranged by the Contractor within the quoted rates. All such foundations shall be demolished and normal ground conditions restored after the usage.
- 14.3 BHEL will provide free of cost only the shims and packer plates (either machined or plain) which go as permanent part of the equipment. Certain packer plates and shims over and above the quantity received as a part of supplies from manufacturing units of BHEL will have to be cut out from steel plates / steel sheets at site to meet site requirement. Contractor shall cut and prepare packers and shims by gas cutting / chiseling / grinding and de-burr the same. However, machining of the packers wherever necessary, shall be arranged by contractor.
- 14.4 Complete grouting of structures equipments, including anchor/ foundation bolts, beneath base, base hollows etc, as may be applicable, is included in the scope of Contractor. Arranging all labour, building materials including cement, ordinary portland as well as quick setting – free flow - non-shrink grout mix (e.g. conbextra gp1/gp2), form work, shuttering, and any other requirements is in the Contractor's scope. Contractor shall obtain approval of BHEL for cement (Ordinary Portland as-well-as quick setting – free flow- non-shrink grout mix) prior to use. Cleaning of foundation surfaces, pocket holes and anchor bolt pits and de-watering and making them free of oil, grease, sand and other foreign materials by soda washing, water washing, compressed air and other approved methods are within the scope of this specification/ work.
- 14.5 After the grouting has finally set and cured, alignment of equipments involved shall be checked again to verify for any disturbance or any other reason. If required, de-coupling of equipments has to be done for conducting the verification. In case any disturbance is noticed the cause, if any, shall be removed and re-alignment done as part of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-
DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

15 WELDING, RADIOGRAPHY AND OTHER NON-DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

- 15.1 Installation of equipment involves good quality welding, NDE checks, post weld heat treatment etc. Contractor's personnel engaged should have adequate qualification on the above works.
- 15.2 The method of welding (viz) arc, TIG/MIG or other method will be indicated in the detailed drawing/documents. BHEL Engineer will have the option of changing the method of welding as per site requirement.
- 15.3 Unsatisfactory and continuous poor performance may result in discontinuation of concerned welder.
- 15.4 The welded surface shall be cleaned of slag and painted with primer paint to prevent rusting, corrosion. For this consumables like paint /primer etc will be in the Contractor's scope.
- 15.5 Welding electrodes have to be stored in enclosures having temperature and humidity control arrangements. This enclosure shall meet BHEL specifications.
- 15.6 Welding electrodes, prior to their use, call for baking for specified period and will have to be held at specified temperature for specified period. Also, during execution, the welding electrodes have to be carried in portable ovens.
- 15.7 All charges towards testing of Welders for destructive and nondestructive test, testing and approval of welders for engaging in the erection work shall be borne by the contractor.
- 15.8 All welded joints shall be subjected to acceptance by BHEL Engineer.
- 15.9 All the welded joints shall be subjected to Non-Destructive testing as per the drawings / standards / procedures and as per the site requirement contractor's quoted rate shall inclusive of the same.
- 15.10 Engineer may stop any welder from the work if his performance is unsatisfactory for any reason or if there is a high percentage of rejection in the joints welded by him. The welder having passed qualification tests does not absolve the contractor of contractual obligation to continuously check the welder's performance.
- 15.11 Faulty welds caused by the poor workmanship shall be cut and re-welded at the contractor's expense. The Engineer, prior to any repair being made, shall approve the

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

procedure for the repair of defective welds. After the repair has been carried out, the compliance shall be submitted to the engineer.

- 15.12 The contractor shall carry out the root run welding of all HP / LP piping, valves by TIG welding method only. The contractor shall have to carry out full TIG welding of butt weld joints of tubes / pipes of lesser thickness if required. During the root runs of stainless steel joints, the contractor shall before and during welding have to purge the pipes with inert gas. All arrangements required for the above shall be the responsibility of the contractor at no additional cost.
- 15.13 All expenses for testing of contractor's welders including destructive and non-destructive tests conducted by BHEL at site or at laboratory shall have to be borne by the contractor only. Limited quantity of raw material required for making test pieces will be supplied by BHEL free of cost.
- 15.14 The regulators used on welding machines shall be calibrated before putting these into use for work. The Contractor at his cost shall also arrange periodic calibration for the same.
- 15.15 Only BHEL/ CUSTOMER approved electrodes and filler wire are to be arranged and used by the contractor, within the finally quoted price. BHEL/ PVUNL reserve the right to test from the certified lab of approved electrode being used by the contractor. Testing charges for the same shall be borne by the contractor. All electrodes shall be baked and dried in the electric electrode-drying oven to the required temperature for the period specified by the Engineer before these are used in erection work. All welders shall have electrodes drying portable oven at the work spot. The electrodes brought to the site will have valid manufacturing test certificate. The test certificate should have a co-relation with the lot number/ batch number given on electrode packets. No electrodes will be used in the absence of above requirement. The thermostat and thermometer of electrode drying oven will be also calibrated and test certificate from Govt. approved/ accredited test house traceable to National/ International standards will be submitted to BHEL before putting the oven in use. The contractor shall also arrange periodical calibration for the same.
- 15.16 The contractor shall maintain a record in the form as prescribed by BHEL of all operations carried out on each weld. He has to maintain a record indicating the number of welds, the names of welders who welded the same, date and time of start and completion, preheat temperature, radiographic results, rejection if any, percentage of rejection etc. and submit copies of the same to the BHEL Engineer as required. Interpretation of the BHEL Engineer regarding acceptability or other wise of the welds shall be final.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-
DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

- 15.17 The contractor shall carry out the edge preparation of weld joints at site in accordance with the details acceptable to BHEL Engineer. Wherever possible machining automatic flame cutting should be done. Gas cutting will be allowed only wherever edge preparation otherwise is impractical. All slag / burrs shall be removed from the edge and all the hand cuts shall be ground smooth to the satisfaction of engineer.
- 15.18 All welds shall be painted with anticorrosive red oxide paint once radiography and stress relieving works are over. Necessary consumables and scaffolding etc including paints shall be provided by contractor at his own cost.
- 15.19 Pre-heating, radiography and other NDT tests, post heating and stress relieving after welding of tubes, pipes, including attachment welding wherever necessary, are part of erection work and shall be carried out by the contractor in accordance with the instructions of the Engineer. Contractor at his cost shall arrange all equipment and consumables essential for carrying out the above process.
- 15.20 Contractor shall arrange all necessary stress relieving equipment with automatic recording devices. The contractor arrange for labour, heating elements, thermocouples, thermo-chalks, temperature recorders, thermocouple attachment units, graphs, sheets insulating materials like asbestos cloth, ceramic beads, asbestos ropes etc. required for heat treatment/ stress relieving operations. The contractor should take a note of the following,
- 15.21 Temperature shall be measured by thermocouple and recorded on a continuous printing type recorder. All the recorded graphs for heat treatment works shall be the property of BHEL.
- 15.22 All stress relieving equipment will be used after due calibration and submission of test certificate to BHEL. Periodic calibration from Govt. Approved / accredited Test Houses traceable to National / International standards will also be arranged by the contractor for such equipment at his cost.
- 15.23 The contractor shall obtain the signature of Engineer or his representative on the strip chart of the recorder prior to the starting of SR operations.
- 15.24 The contractor shall also be equipped for carrying out other NDT like LPI / MPI/UT / Hardness test etc. as required as per welding schedules / drawings within the finally accepted price / rates. For UT machine shall be used of recordable type.
- 15.25 The technical particulars, specification and other general details for radiography work shall be in accordance with ASME, IBR or ISO as specified by BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

- 15.26 Contractor for radiography work shall use iridium-192. The geometric un-sharpness shall not exceed 1.5 mm. The contractor should take adequate safety precautions while carrying out radiography. Contractor at his cost shall arrange necessary safe guards required for radiography (including personnel from BARC).
- 15.27 Low speed high contrasts, fine grain films (D-7 or equivalent) in 10 cm width only be used for weld joint radiography. Film density shall be between 1.5 to 2.0.
- 15.28 All radiographs shall be free from mechanical, chemical or process marks, to the extent they should not confuse the radiographic image and defect finding. Penetrameter as per ASME or ISO must be used for each exposure.
- 15.29 Lead numbers and letters are to be used (generally 6mm size) for identification of radiographs. Contract number, joint identification, source used, welder's identification and SFD are to be noted down on paper cover of radiograph.
- 15.30 Lead intensifying screens for front and back of the film should be used as per the above referred ASME specification.
- 15.31 The joint is to be marked with permanent mark A, B, C to identify the segments. For this a low stress stamp shall be used to stamp the pipe on the down streamside of the weld.
- 15.32 For multiple exposures on pipes, an overlap of about 25-mm of film should be provided.
- 15.33 Radiography personnel with sufficient experience and certified by M/s BARC for conducting radiographic tests in accordance with safety rules laid down by Division of Radiological protection only have to be deployed. These personnel should also be registered with DRP / BARC for film badge service.
- 15.34 All arrangements for carrying out radiography work including dark room and air conditioner and other accessories shall be provided by contractor within the space allotted for office at his cost. As an alternative the contractor may deploy an agency having all above facilities and who are duly approved / accredited by BARC and / or other Regulatory authorities. Detailed particulars of such agencies will be submitted and got approved by BHEL Engineer before the actual deployment of agency for radiography work.
- 15.35 The contractor shall have a dark room fully equipped with radiography equipment, film (un-exposed), chemicals and any other dark room accessories if they keep the source inside the plant.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT

Or

Agency should tie up with A RT agency inside the plant premises with Dark room and pit room facilities.

Or

Agency should be tie up with an outside agency for the dark/pit room facility out side the plant premises.

- 15.36 The agency has to ensure the timely testing of weld joints in failing of same BHEL may take alternative arrangement on Agency risk and cost.
- 15.37 Radiography inspection of welds shall be performed in accordance with requirements and recommendation of BHEL Engineer. The quantum of radiographic inspection shall be as per provision of ASME / BHEL/PVUNL approved documents. Subsequently radiographic inspection will be done on the basis of quality of welding. However minimum percentage of joints to be radiographed shall not be less than the requirement of BHEL welding schedule / IBR / Customer's requirements. The percentage may be increased depending upon the quality of joints and at the discretion of BHEL. Radiography on LP piping joints is not envisaged. However other NDT test as called for in the FQP including LPI, MPI and HT will have to be carried out.
- 15.38 All the Radiographs shall be properly preserved and shall become the property of BHEL. They are to be reconciled with the work done, joints radiographed and submitted to BHEL / customer
- 15.39 Since radioisotopes are being used, all precautions and safety rules as prescribed by BHEL/BARC/ Customer shall be strictly followed. BARC / DRP certificate to be provided before taking up the work.
- 15.40 Radiography of joints shall be so planned after welding that the same is done either on the same day or next day of the welding to assess the performance of HP welders. If the performance of welder is unsatisfactory, he is to be replaced immediately.
- 15.41 Wherever radiographs are not accepted, on account of bad shot, joints shall be radiographed and re- submitted for evaluation.
- 15.42 However, if the defect persists after first repair, further repair work followed with radiography shall be repeated till the joint is made acceptable. In case the joint is not repairable, the same shall be cut, re-welded and re-radiographed at contractor's cost.
- 15.43 If the contractor does not carry out radiography work due to non-availability of source / film / chemical / operator etc., BHEL will get the work done departmentally or through some other agency at the risk and cost of the contractor.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
**Chapter-XV WELDING, RADIOGRAPHY AND OTHER NON-
DESTRUCTIVE TESTING, POST WELD HEAT TREATMENT**

- 15.44 Heat treatment and radiography may be required to be carried out at any time (day and night) to ensure the continuity of progress. The contractor shall make all necessary arrangements including labour, supervisors/ Engineer required for the work as per directions of BHEL.
- 15.45 The contractor shall assist BHEL Engineer in preparing complete field welding schedule for all the field welding activities to be carried out in respect of piping and equipment erected by him involving high pressure welding at least 30 days prior to the scheduled start of erection work at site. The contractor shall strictly adhere to such schedules.
- 15.46 Check shots as per the requirement of BHEL/ PVUNL will be taken at agency cost.
- 15.47 Welding of galvanised iron pipes/fittings would be permitted provided the same is carried out by means of special electrodes suitable for the above application and the same shall be approved by contractor. After, welding, welded portions shall be applied with three coats of zinc silicate treatment/rich paint over one coat of suitable primer. Further, the Contractor shall provide proper zinc paint at the point of welding..

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI LINING & INSULATION

16 LINING AND INSULATION

Application of insulation, finishing, cladding and outer casing etc of the following:

2. ESP & Auxiliary.
3. FGD and its auxiliaries.

- 16.1** All attachment welding, including welding of hooks / supports as per pitch both on equipment and piping shall be done as directed by Engineer. Attachment welding shall have to be done by certified welders. If necessary contractor may have to cut the hooks to correct length. Application of red oxide paint including supply of paint on welded portions as directed by BHEL is also included in scope of work.
- 16.2** The mineral wool mattresses (bonded / un-bonded) / LRB mattresses are received at site in standard sizes. These are to be dressed / cut to suit site requirements by the contractor.
- 16.3** The number of layers / thickness of mineral wool / LRB mattresses for auxiliaries, pipe lines, valves and other vessels shall be as per various drawings and as directed by Engineer. For applying the mineral wool mattress, the required holding materials, if necessary by fabrication of rings/ hooks shall be fixed as directed and as per drawings and spec.
- 16.4** The contractor should ensure, proper finishing of surface of the insulation, sheeting and cementing.
- 16.5** The contractor should ensure that the finished surface of the insulation works conforms to the dimensions and tolerances given in the drawings. Aesthetic finish and accuracy of work are most important.
- 16.6** It is the responsibility of the contractor to ensure that the insulation materials and sheet metal covering issued to him for application are well protected against loss or damage from weather conditions. Closed / semi closed sheds or any other arrangements required for this will be by him at his cost. If any damage occurs to the material due to improper storage or due to any causes attributable to the contractor except for normal breakage or damages allowed in such cases, the cost of such damaged material shall be to the account of the contractor.
- 16.7** Aluminum sheet cladding will be fabricated to the sizes and shapes specified in drawings. Beading, swaging, beveling of sheets, crowning the sheets if necessary will be carried out by him. Two coats of anti-corrosive black bituminous paint are to be applied on inner surfaces of the cladding. Bitumen sealing compound on the joints if necessary is included in the scope of this work. Contractor may note that he will also supply anti-corrosive black bituminous paint & bituminous sealing compound

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI LINING & INSULATION

required for above works at his cost. However if supply by the BHEL MUs same will be issue free of charges to contractor.

- 16.8** Aluminum sheet metal cladding over insulation will consists of plain / ribbed / corrugated sheets. The sheets will be supplied in standard sizes. Cutting them to required size, grooving, fabricating bends, boxes etc., for proper covering is contractors responsibility. Any cutting / bending / welding of fabricated skin casing sheets if required will also covered within the scope of this contract.
- 16.9** A logbook shall be maintained by the contractor to obtain clearance for application of insulation. If the contractor does the work on his own accord without prior permission the area may have to be redone at his cost.
- 16.10** The work shall conform to dimension and tolerances specified in the various drawing and documents that will be provided during the execution. if any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the Contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by engaging other agencies or departmentally and recoveries will be deducted from Contractor's bills towards expenditure incurred including 30% departmental charges.
- 16.11** All insulation and refractory materials including iron components and outer sheet casing materials, cladding sheets etc required will be supplied by BHEL and the same have to be erected/ applied as per the drawings and specifications of BHEL by the Contractor.
- 16.12** **The Contractor shall provide all the necessary scaffolding materials, temporary structures and necessary safety devices etc, during all stages of work. Scaffolding materials (poles, gratings etc) shall be of light weight construction. Contractor shall arrange steel pipes & clamps with accessories like base plate attachment, fixing pins, struts etc for scaffolding required for this work. However, BHEL's decision in this regard shall be final and binding. Contractor shall arrange the scaffolding materials in sufficient quantity.**

The Contractor shall provide the required quantity of wire, nails, and planks for formwork and other materials for shuttering and curing works.

- 16.13** Wool insulation is received at site as loose bonded mattresses in standard sizes. These are to be dressed/cut to suite the equipments. Multiple layers of wool have to be applied as directed and as per drawings and specifications for all equipments/ systems covered under the scope of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI LINING & INSULATION

- 16.14** The cladding and outer casing are aluminium sheets. All relevant specifications and procedures with regards to beading, sealing etc for aluminium sheets have to be adhered to.
- 16.15** Cladding/outer casing shall be fixed expeditiously, so as to avoid damage to the insulation from the weather. The overlapping surface of outer casing/cladding sheet shall be coated with sealing compound, which will be supplied by BHEL free of cost.
- 16.16** To take care of bimetal corrosion due to variety of metals in contact of each other viz retainer to support, support to outer casing/cladding, cladding-to-cladding etc, suitable paints specified by BHEL, to be applied and/or neoprene rubber packing/strips or any other insert may have to be fixed as required.
- 16.17** The Contractor shall leave certain gaps and openings while doing the work as per the instructions of BHEL Engineer to facilitate inspection during commissioning to fix gauges, fittings, instruments etc. these gaps will have to be finished as per drawings at later date by the Contractor at his cost.
- 16.18** Contractor shall cut open works in needed as per BHEL Engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over without any extra payment.
- 16.19** A log book shall be maintained by the Contractor for the clearance of the area for application of refractory and insulation. Where the Contractor does the work on his own accord without prior permission, the work should be re-done, at his own cost, where necessitated.
- 16.20** Wastage allowances for the material issued are envisaged as follows:

➤ a	Wool mattresses	-	2%
➤ b	Cladding sheets	-	2%

The wastage allowance will be applicable on the net issued quantity i.e. total quantity issued reduced by the quantity returned to stores as unused/fresh item. Contractor shall reconcile the material issues periodically as prescribed by BHEL site.

- 16.21** If during erection and commissioning any of the parts are to be insulated temporarily fixed and then replaced by permanent ones at a later date or if any of the parts are to be removed for modification, rectification, adjustment and then refitted or if some parts are to be opened for inspection and checking and for measurement of metal surface temperature the same may necessitate removal and re-application of insulation and sheet metal cladding, which shall be done by the contractor and the erection rate quoted shall be inclusive of such contingencies.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVI LINING & INSULATION

16.22 Removable type of insulation shall be provided for valves, fittings, expansion joints etc as per the drawings or as directed by BHEL Engineer.

16.23 All temporary pipelines required during testing, pre-commissioning and commissioning should be insulated as directed by BHEL at no extra cost to BHEL. However required insulation material shall be issued by BHEL free of cost.

16.24 The following works are also included in the scope of this contract.

a) Cutting of cladding sheets as per the profile of the equipment and painting on inner surface two coats of bituminous paint. Paint will be arranged by Contractor.

b) Cutting of the wool mattresses in the required shape and application of finishing layer of required thickness wherever required.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII PAINTING

17 PAINTING

Touch-up Painting: All structures / components shall be supplied from BHEL units/ workshops with finish coats of paint. Therefore final painting is not applicable in the scope of contractor. However touch up painting (wherever required), incidental to the work, shall be in the scope of the contractor, including supply of the required paints and primers and associated consumables.

Though the final painting is not there in the scope of the contractor, in case any shop painted structure/component is required to be repainted due to the reasons attributable to the contractor such as Mis-handling, damage during erection process, other reasons incidental to the work etc, such re-painting/finish painting of the components/structures shall be in the scope of the contractor including the supply of paints and primers along with all required consumables & deployment of tools e.g wire brush, paint brush, Spray M/c, cleaning agents etc.

Contractor shall carry out surface preparation and touchup painting works as per BHEL/Customer specification and instruction of BHEL engineer at site.

Contractor shall carry out surface preparation and touchup **painting** works as per BHEL/Customer specification and instruction of BHEL engineer at site.

17.1 Paints and painting work carried at site shall confirm to the following codes and standards:

IS:5 – Colour for ready mixed paints and enamels.

IS : 101 Part 1 to 9 – Methods of sampling and test for paints, varnishes and related products

IS : 1477 Part I&II – Code of practice for painting of ferrous metals in building

IS : 2932 – Specifications for enamel, synthetic and exterior,

a) Under Coating

b) Finishing

IS: 9407 – Colour code for identification of pipelines used in thermal power plants.

Contractor shall satisfy himself, availability of all information in the specifications for proper selection of the paints and ensure their applications as per Codes.

17.2 Primer Painting:

a) After surface preparation, two coats of **epoxy resin based zinc primer** shall be applied. Dry film thickness of each coat shall be as per the recommendations of primer/paint manufacturer. Primer shall be applied by either spraying or bushing ensuring a continuous film without “holidays”. Primer coat shall be immediately applied without any time lag after the surface preparation.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII PAINTING

b) Any equipment shall be carefully examined and where ever the primer coat is damaged shall be recoated with primer. However over the field welds, bolts and nuts etc. two primer coats as per a) shall be applied.

17.3 Finish Painting (If required)

a) After the primer coat has dried out, the surface shall be cleaned of dust without scratching or in any way damaging the primer coat. Over this, dry surface finish painting shall be carried out.

b) Finish painting shall be carried out in two coats. Dry film thickness of each coat shall be as per the recommendation of the primer/paint manufacturer. Minimum thickness including primer and paint coating shall be as per specification.

c) Paint shall be applied either by brushing or spraying. It shall be ensured that brush marks are a minimum and the requirements of workmanship are as specified in IS: 1477 (for site painting works on systems, structures and components).

d) Paint used shall be stirred frequently to keep the pigment in suspension. Paint shall be of ready mixed type in original sealed containers as packed by the paint manufacturer. Addition of thinners shall not be permitted.

e) No painting shall be done in frost/foggy weather or when the humidity is high enough to cause condensation on the surface to be painted. Paint shall not be applied when the temperature of the surface to be painted is 5° C or below.

f) Work of painting of condenser surfaces in various areas and at various stages of work are specified elsewhere in these specifications.

17.4 Components of pumps & Motors and auxiliaries will in general be supplied painted by BHEL manufacturing units as per their standard applicable painting schemes. Contractor shall carry out primer and finish painting coats and DFT requirement with colour codes & specifications as per requirement of customer.

All exposed metal parts of the equipment including piping, structures, railings etc. wherever applicable, after installation unless otherwise surface protected, shall be first painted with at least one coat of suitable primer which matches the shop primer paint used, after thoroughly cleaning all such parts of all dirt, rust, scales, greases, oils and other foreign materials by wire brushing, scraping or sand blasting, and the same being inspected and approved by BHEL engineer for painting. Afterwards, the above parts shall be finished with two coats of alloyed resin machinery enamel paints.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII PAINTING

17.5 Touch-up painting on damaged areas -

a) For coatings damaged up to metal surface.

Surface preparation shall be carried out by manual cleaning. Minimum 6 inches adjoining area with existing coating shall be roughened by wire brushing, emery paper rubbing etc., for best adhesion of patch primer. Primer coat of touch-up primer has to be applied by brush immediately after the surface preparation.

Over this primer coat, finish coat and final finish coat shall be applied as covered above by brush within maximum seven (7) days of application of touch up primer.

17.6 Painting of welded areas / painting of areas exposed after removal of temporary supports / touch-up painting on damaged areas of employer's structures, where inter-connection, welding / modification etc. has been carried out by the bidder.

(a.) Clean the surface to remove flux spatters and loose rust, loose coatings in the adjoining areas of weld seams by wire brush and emery paper.

(b.) Painting procedure to be followed for touch-up painting on damaged areas.

17.7 The scope of work includes painting (including supply) of colour bands, lettering, marking and signs for direction of flow/rotation, names etc of approved colours as per the standard colour codes and specifications specified in tender specification or as advised by BHEL/Customer engineer at site for the equipments / components covered in these specifications.

17.8 In certain isolated instances where it is not possible to clean the equipments as explained above, cleaning by grinding might have to be resorted to. No damage to the equipment/components should be caused.

17.9 Surface to be painted should be free of oil and grease. It should be removed by using suitable cleaning agents including permitted solvents. Surface cleaned by chemical agent, if required, shall be treated further as prescribed in use of such cleaning agents.

17.10 During the preparation of surface, if the shop coat is damage by chemical cleaning or by mechanical means, contractor shall repair the same free of cost.

17.11 Specified drying time shall be permitted from one to another coat.

17.12 This work requires working at higher altitudes from ground level to as high as 50 mtr and more. The work spread is also substantial involving substantial run of structures and piping. Contractor shall take sufficient precautions to avoid any accident and hazard in all respects. The ropes, ladders, scaffolding materials, clamps etc and climber used should be of standard quality for safe and smooth execution of work.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII PAINTING

17.13 Contractor shall carry out the work in such a way that other erected equipment, structure, civil foundations and other property are not damaged. For damages in any of such cases due to lapses by Contractor, BHEL shall have the right to recover the cost of such damages from the Contractor.

17.14 Contractor shall take due care to cover/protect the equipment which are already painted while carrying out the painting of other adjacent equipment. If so happens, it shall be cleaned and repainted by the Contractor without any extra charges.

17.15 In general, painting of structural parts and colour bands, lettering, marking of direction of flow/rotation etc will be carried out by brush painting. However, areas/equipments inaccessible for manual painting have to be painted by spray painting. The decision of BHEL engineer, in this regard, shall be final and binding on the Contractor. Laying of air hose pipe and any other line required shall be done by Contractor at his cost

17.16 Final painting work shall be started after obtaining clearance from BHEL engineers and as per his instructions.

17.17 Acceptance of Final Painting for required thickness shall be as per the thickness measured by Alcometer by Customer/BHEL Engineer. Contractor shall have to carry out painting till the required thickness is achieved.

17.18 Painting two coats of bituminous paint on Insulation cladding sheet inner surface.

17.19 The scope of painting includes application of color bands, lettering the names of the systems equipment's; tag Nos of valves, marking the directions of flow and other data required by BHEL within the quoted rate.

17.20 The actual color to be applied shall be approved by the customer before starting of actual painting work.

17.21 Primer & finish paint shall be of reputed paint supplier approved by BHEL / Customer. Contractor has to procure paints from the BHEL / Customer approved agencies only, and the paints should be as per the customer painting specification. The quality of the finish paint shall be as per the standards of IS or equivalent as approved by BHEL / Customer. Before procurement of paint the contractor has to obtain the clearance from BHEL authorities. The batch certificates of paints to be submitted to BHEL Engineer before using the same.

17.22 No paint shall be applied when the surface temp is above 55 deg. Centigrade or below 10 deg. Centigrade, and when the humidity is greater than 90% to cause condensation on the surface or frost / foggy weather.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVII PAINTING

17.23 All surfaces to be painted shall be thoroughly cleaned, free from scales, dirt and other foreign matter. Paint shall be applied in an even & uniform film free from lumps, streaks, runs, sags and uncoated spots.

17.24 Before applying the subsequent coats, the thickness of each coat shall be measured and recorded with BHEL / Customer.

16.25 Wherever applicable, supply and application of primer / final painting of all the insulation items erected under the scope of this tender. The painting shall be as required and specified in the painting schedule, which forms the part of this tender book.

17.26 Required paints, thinner other consumable such as wire brush, brush etc. shall have to be arranged by the contractor at their own cost. The required manpower, other required consumables, T & P etc. shall be provided by the contractor with in the quoted rate. The arrangements of primer/paint will being contractor's scope.

17.27 Any equipment which has been given the shop coat of primer shall be carefully examined after its erection in the field and shall be treated with touch up coat of same primer wherever the shop coat has been abraded, removed or damaged during transit / erection, or defaced during welding.

17.28 Mostly the equipment / items / components will be supplied with one coat of primer paint and one coat of finish paint. However, during storage and handling, the same may get peeled off / deteriorate. All such surfaces are to be thoroughly cleaned and to be touch up painted with suitable approved primer and finish paint matching with shop paint / approved final color.

NOTE: PAINTING

Contractor shall arrange all paints, primers, tools and other consumables including scaffolding materials required for touch-up painting. Paint is to be BHEL approved make only and painting should be as per colour scheme and quality approved / specified by Engineer. Valid Test Certificate for the paint so supplied shall be made available before use of the same on work. No paint whose shelf life has expired should be used for painting.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

- 18.1 Testing, & commissioning will involve, though not limited to these, various testing e.g., leak test, trial runs of equipments; checking/setting various clearances/ parameters, ensuring operation of various equipments free of undue restrictions, coal firing, trial operation and loading etc are some of these activities. All the activities for commissioning of the set, as informed by BHEL from time to time shall be completed.
- 18.2 All these tests should be repeated till all the equipments satisfy the requirement / obligations of BHEL to their client and also the relevant statutory authority.
- 18.3 Contractor shall lay / install necessary blanking arrangement in funnels, hoppers for conduct of Air leak test of ESP, ATT of ducting etc. this may involve fabrication & erection, welding & after satisfactory completion of test removal of same by cutting & grinding. Temporary installation itself has to be tested, tried, and subject to non-destructive examinations as per the instructions of BHEL as part of work
- 18.4 No payment will be made for temporary installations made for testing of systems & similarly no payment will be made for electrical installations made for any temporary system.
- 18.5 All materials, equipment's necessary for installation of temporary system as above will be supplied by BHEL as free returnable issue in random sizes / lengths. However, servicing, fabrication, erection, dismantling of the same after completion of the process, and handing over back to BHEL stores will be the responsibility of the Contractor.

In accounting of materials following wastage allowances are provided:

1. Structural items : 5%

- ✓ Contractor shall cut / open / dismantle work, if needed, as per BHEL Engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over.
- ✓ Similarly, during the course of erection, if certain portion of equipments erected by the Contractor has to be undone for enabling other Contractors / agencies of BHEL / customer to carry out their work, Contractor shall carry out such jobs expeditiously and promptly and make good the job after completion of work by other Contractors / agencies of BHEL / customer as per BHEL engineer's / agencies of BHEL / customers instructions. Claims, if any, in this regard shall be governed as relevant clauses of 'General Conditions of Contract

18.6 Commissioning activities will continue till the completion of trial operation. During this period Contractor shall make available the services of separate dedicated

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

workforce comprising of suitable skilled and semi-skilled / un-skilled workmen and supervisory staff alongwith necessary tools and plants, consumables etc.

18.7 It shall be specifically noted that the Contractor may have to work round the clock during the pre-commissioning and commissioning period alongwith BHEL Engineers and hence considerable overtime payment is involved. The Contractor's quoted rates shall be inclusive of all these factors.

18.8 The Contractor shall carry out any other tests as desired by BHEL engineer on erected equipment covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or whole of work performed by the Contractor.

18.9 During this period, though BHEL/ client's staff will also be associated in the work, the Contractor's responsibility will be to arrange for complete requirement of men and required tools and plants, consumables, scaffolding and approaches etc., till such time the commissioned unit is taken over.

18.10 Conducting of performance guarantee test (PG test) is in the scope of work. Contractor shall install all necessary tapping points; instruments etc and provide necessary assistance in this regard.

18.11 In case PG test is getting delayed beyond the contract period (normal plus extension if any) due to reasons not attributable to the Contractor, PG test issue will be mutually discussed and decided. However installation of necessary tapping points, impulse pipes, approaches etc are to be completed by the Contractor.

18.12 The Contractor shall carry out any other tests as desired by BHEL engineer on erected equipment covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or whole of work performed by the Contractor.

18.13 FGD commissioning and testing:

18.13.1 The contractor shall carry out all the required tests, pre-commissioning and commissioning activities required for the successful and reliable operation of FGD system as per the approved commissioning procedure / quality plans of BHEL/PVUNL. These would include, Air /gas tightness test of ducts, Hydraulic test of piping , Holiday test of underground piping Water fill test/vacuum box test of tanks, Trial run of pumps/blowers/ball mills/feeders/vacuum belt filter/hydrocyclones, Testing of fire protection system etc. as instructed by BHEL using their own consumables, labour and scaffoldings etc. Specific omission of any test which is required for the

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

successfully commissioning of the FGD system does not absolve the contractor of its responsibilities of performing of that test.

- 18.13.2** All required tests (Mechanical and electrical) indicated by BHEL and their clients for successful commissioning are included in the scope of these specifications. These tests / activities may not have been listed in these specifications but contractor shall conduct the tests as per the approved commissioning procedure.
- 18.13.3** The 'Initial Operation'/trial operation of the complete facility as an integral unit shall be conducted for 720 continuous hours. During the period of initial operation of 720 hours, the FGD System shall operate continuously at full load for a period not less than 72 hours .The Initial Operation shall be considered successful, provided that each item/ part of the facility can operate continuously at the specified operating characteristics, for the period of Initial Operation with all operating parameters within the specified limits and at or near the predicted performance of the equipment/ facility.
- 18.13.4** Specialized test equipment, if any, shall be provided by BHEL / its client free of hire charges. However contractor has to take proper care of the equipment issued to him.
- 18.13.5** After completion of erection of ducts, the contractor shall conduct the air/gas tightness of the inlet duct from ID fan outlet to absorber inlet and outlet duct from absorber outlet up to wet stack chimney. Erection etc. of blowers and blanks and putty required for conducting air tightness test shall be carried out as part of work (Putty to be procured by the contractor without any extra cost to BHEL).
- 18.13.6** All the tests may have to be repeated till all the equipment satisfy the requirement /obligation of BHEL at various stages. The contractor shall do all the repairs for site welded joints arising out of the failure during testing.
- 18.13.7** The scope of pre-commissioning activities cover installation of all necessary equipment including temporary piping, supports, valves, blanking, pumps, tanks, with access platforms valves, along with accessories required for hydro test for any other tests. The scope also covers the offsite disposal of effluents of the tests under the scope of this contract as per instruction of BHEL Engineer.
- 18.13.8** It shall be the responsibility of the contractor to provide various category of workers in sufficient numbers along with Supervisors during Pre-commissioning, commissioning and post commissioning of equipment and attending any problem in the equipment erected by the contractor till handing over. The contractor will provide necessary consumables, T&P's,

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

IMTE's etc., and any other assistance required during this period. Association of BHEL's / Client's staff during above period will not absolve contractor from above responsibilities.

- 18.13.9** It shall be specifically noted that the above employees of the contractor may have to work round the clock along with BHEL Engineers and hence overtime payment by the contractor to his employees may be involved. The contractors finally accepted rates should be inclusive of all these factors also.
- 18.13.10** In case, any rework is required because of contractor's faulty erection, which is noticed during pre-commissioning and commissioning, the same has to be rectified by the contractor at his cost. If any equipment / part is required to be inspected during pre-commissioning and commissioning, the contractor will dismantle / open up the equipment / part and reassemble / redo the work without any extra claim.
- 18.13.11** During commissioning, opening / closing of valves, changing of gaskets, realignment of rotating and other equipment, attending to leakage and adjustments of erected equipment may arise. The finally accepted price / rates shall also include all such work.
- 18.13.12** The contractor shall make all necessary arrangements including making of temporary closures on piping / equipment for carrying out the hydro-static testing on all piping, equipment covered in the specification at no extra cost.
- 18.13.13** The valves will have to be checked, cleaned or overhauled in full or in part before erection, during pre-commissioning and commissioning as may be necessary.
- 18.13.14** In case any defect is noticed during tests, trial runs and commissioning such as loose components, undue noise or vibration, strain on connected equipment etc., the contractor shall immediately attend to these defects and take necessary corrective measures. If any readjustment and realignment are necessary, the contractor at his cost shall do the same as per Engineer's instructions including repair, rectification and replacement work. The parts to be replaced shall be provided by BHEL.
- 18.13.15** All temporary supports shall be removed in such ways that pipe supports are not subjected to any sudden load. During hydraulic testing of pipes, all piping having variable spring type supports shall be held securely in place by temporary means while constant spring type support hangers shall be pinned or blocked solid during the test.
- 18.13.16** The contractor shall carry out cleaning and servicing of valves and valve actuators prior to pre-commissioning tests and / or trial operations of the plant. A system for recording of such servicing operations shall be developed

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

and maintained in a manner acceptable to BHEL Engineer to ensure that no valves and valve actuators are left unserviced. Wherever necessary as required by BHEL Engineer, the contractor shall arrange to lap / grind valve seats. Cleaning and servicing of all the filters / strainers, toppings of oils coming in the system shall be done by the contractor within the accepted price.

18.13.17 At the time of each inspection, the contractor shall take note of the decisions / changes proposed by the Engineer and incorporate the same at no additional cost. The contractor shall carry out any other test as desired by BHEL Engineer/ Manufacturer on erected equipment covered under scope of this contract during testing and commissioning to demonstrate the physical completion of any part or parts of the work performed by the contractor.

18.13.18 The scope of pre-commissioning, commissioning and post commissioning activities cover installation of all necessary temporary piping, supports, valves, blanking, pumps, tanks etc. and other accessories with access platforms valves, pressure gauges, electric cables, switches, cutting of some of existing valve, placing of rubber wedges in the valves etc., required for hydro test, or any other tests as the case may be and will carry out above activities under this scope of work as per instructions of BHEL. The scope also covers the off site disposal of effluents.

18.13.19 It shall be the responsibility of the contractor to preserve the cleaned surface as per BHEL's requirement.

18.13.20 The contractor shall make all necessary arrangements including making of temporary closures on piping/ equipment for carrying out the hydro-static testing on all piping equipment covered in the specification at no additional cost. The contractor shall carryout the required test on the pipelines such as Hydraulic Test of various piping systems, Ultrasonic Test for weld defects and finding thickness, Dye penetrant test, Magnetic particles test for Weld defects and materials defects etc. All facilities (manpower, materials, equipment, consumables etc.) including proper approaches wherever required shall be provided by the contractor for satisfactory conduction of above tests. Special equipment such as magnetic particle tester, ultrasonic test kit and engineers required for these tests shall be arranged by the contractor along with Qualified technician within finally accepted rates.

18.13.21 In certain places blanking has to be resorted prior to Hydraulic test and spool pieces have to be erected in place of control valves, orifices and other fittings and these spool pieces have to be subsequently replaced with the regular valves/ fittings by the contractor at no extra cost.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XVIII TESTING, PRE-COMMISSIONING, COMMISSIONING

- 18.13.22** During this period though the BHEL's/ client's staff will also be associated in the work, the contractor's responsibility will be to arrange for the complete requirement of supervision, consumables, labour, T&P and IMTEs required till such time the commissioned units are taken over by the BHEL's customer.
- 18.13.23** It is possible that due to any reason the final supporting may not be completed before conducting Hydraulic Test. The contractor may have to strengthen or install any additional supports as per instruction of BHEL. This work is a part of the work and no additional payment shall be made on this account.
- 18.13.24** All the shafts of the equipment shall have to be properly aligned to that of matching equipment to perfection, accuracy as required and the equipment shall be free from excessive vibration so as to avoid over-heating of bearings or other conditions, which may tend to shorten the life of the equipment. All bearings, shafts and other rotating parts shall be thoroughly cleaned and lubricated as per recommendations of BHEL engineer.
- 18.13.25** During commissioning changing of gaskets , tightening of bolts, realigning of rotating and other equipment, attending to leakage and minor adjustments of erected equipment may arise. The quoted rate of contractor shall be inclusive of all such works.
- 18.13.26** Lubricating oil units of the rotating machines are to be cleaned thoroughly before pouring of final lubricating oil. Topping up of lubricants during running of the set till handing over to be done by the vendor. Required lubricants both for first filling and topping up are to be supplied by BHEL free of cost. The empty containers of the lubricating oils should be returned to BHEL stores/place indicated by BHEL from time to time.
- 18.13.27** The instruction of the motor manufacturer regarding storage of the motors and re conservation must be strictly followed without any deviation.
- 18.13.28** Attending the punch points post commissioning and resolve the deficiency for handing over the unit to customer M/s PVUNL.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-XIX PRESERVATION & PROTECTION OF COMPONENTS

19 PRESERVATION & PROTECTION OF COMPONENTS

- i. At all stages of work, equipments/materials in the custody of Contractor, including those erected, will have to be preserved as per the instructions of BHEL. Necessary preservation agents including the primer & paint, for the above work shall be provided by the Contractor.
- ii. The Contractor shall make suitable security arrangements including employment of security personnel and ensure protection of all materials/ equipment in their custody and installed equipments from theft/fire/pilferage and any other damages and losses.
- iii. Contractor shall collect all scrap materials periodically from various area of work site, deposit the same at one place earmarked at site or shift the same to a place earmarked in BHEL/ client's stores. In case of failure of Contractor in compliance of this requirement, BHEL will make suitable arrangement at Contractor's risk and cost.
- iv. The entire surplus, damaged, unused materials, packaging materials / containers, special transporting frames, gunny bags, etc shall be returned to BHEL stores by the Contractor.
- v. The Contractor shall not waste any materials issued to him. In case it is observed at any stage that the wastage/excess utilisation of materials is not within the permissible limits, recovery for the excess quantity used or wasted will be effected with departmental charges from the Contractor. Decision of BHEL on this will be final and binding on the Contractor.
- vi. For any class of work for which no specifications have been laid down in these specifications, work shall be executed as per the instructions of BHEL.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter- XX: Weightage/ Factor

Table -1 Schedule of Quantities

Weightages / Factor for PACKAGE – A					
<p>PACKAGE - A: 1. COLLECTION OF MATERIALS FROM BHEL/ CLIENT'S STORES/ STORAGE YARD, TRANSPORTATION TO SITE, ERECTION, TESTING & ASSISTANCE FOR COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF ESP AND ITS AUXILIARIES, INCLUDING DUCT SUPPORTING STRUCTURE, ESP OUTLET DUCT UP TO CHIMNEY, LINING & INSULATION, SUPPLY AND TOUCHUP PAINTING ETC OF ESP of UNIT#1. AND 2. WORK OF MATERIAL HANDLING AND ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF THE FLUE GAS DESULPHURIZATION SYSTEM (FGD) UNIT#1. AND 3. Common system of FGD SYSTEM FOR 3 X 800 MW PVUNL PROJECT PATRATU DIST RAMGARH JHARKHAND</p>					
SECTION	DESCRIPTION OF PACKAGES / ITEM OF WORK	Percentage weightage w.r.t Total Price			
1	E&C of ESP & Auxiliaries (Rate Schedule ID 1.1 to 1.5)	65.3100%			
2	E&C of FGD & Auxiliaries (Rate Schedule ID 2.1 to 2.5)	34.6900%			
Total Combined Contract Value		100.00%			
Rate Sc ID	Contract (ESP Package)	UNIT	QTY of ESP-#1 Pkg-A	Weightage/ Factor "X"	PG MAs covered
1.1	ESP	MT	13,921.700	0.000052278034	79 (part), 89 (part)
1.2	Non Pressure Parts (ESP outlet funnel to Chimney) ESP	MT	2,948.950	0.000066429090	39, 48, 57
1.3	Min wool for ID DUCT & ESP (INSULATION)	MT	732.000	0.000065526101	33, 79 (Part)
1.4	Iron part for ID Duct & ESP (INSULATION)	MT	151.900	0.000077222139	79 (Part), 32 (Part)
1.5	Cladding Sheet (INSULATION)	MT	185.000	0.000089782029	89 (part) 32 (part)
Total weight		MT	17,939.55		
FGD Package			QTY of FGD-#1 Pkg-A		
2.1	Absorber/Structure/Duct Damper	MT	3,473.000	0.000154076127	
2.2	Tanks	MT	706.000	0.000209006441	
2.3	Rotary Machine	MT	1,372.000	0.000096641264	
2.4	Insulation & Sheeting	MT	98.000	0.000135188519	

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter- XX: Weightage/ Factor

2.5	Piping	MT	555.000	0.000308999596	
	Total weight	MT	6,204.00		

Note: The quantity indicated in the BOQ is approximate only and is liable for variation. Payment will be as per actual quantity executed as certified by BHEL Engineer above Unit rate of individual items of BOQ.

TABLE-2
PACAKGE-B Schedule of Quantities

Rate Sc ID	ESP Package	UNIT	QTY of ESP-#2 Pkg-B
1.1	ESP	MT	13,921.700
1.2	Non Pressure Parts (ESP outlet funnel to Chimney) ESP	MT	2,948.950
1.3	Min wool for ID DUCT & ESP (INSULATION)	MT	732.00
1.4	Iron part for ID Duct & ESP (INSULATION)	MT	151.9
1.5	Cladding Sheet (INSULATION)	MT	185.00
TOTAL			17,939.55
Rate Sc ID	FGD Package	UNIT	QTY of FGD-#2 Pkg-B
2.1	Absorber/Structure/Duct Damper	MT	2635
2.2	Tanks	MT	22
2.3	Rotary Machine	MT	336
2.4	Insulation & Sheeting	MT	98
2.5	Piping	MT	20.00
TOTAL			3,111.00

Note:

1. The quantity indicated in the BOQ is approximate only and is liable for variation. Payment will be as per actual quantity executed as certified by BHEL Engineer above Unit rate of individual items of BOQ.

2. Unit rates for Package- B shall be in line with the Unit rates of Package – A, considering the price matching philosophy as detailed in the NIT Cl no. 08. Modality of Award of work’ of Annexure 4 Important Information of the NIT.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter- XX: Weightage/ Factor

Instruction to Bidders for Vol-II-Price Bid and Schedule of Rates and Quantities

1. **Bidders shall quote Total Lump-sum Price for the entire scope of work in Rupees for Package-A only in VOL II PRICE BID at BHEL E-procurement Portal.** Any other entry elsewhere in the offer of the bidder shall be treated as Null and Void.
2. This Total Lump-sum Price is bifurcated in “Section 1 - E&C of ESP Package” and “Section 2 - E&C of FGD Package” based on the BHEL fixed percentage weightages w.r.t the total Total Lump-sum Price quoted by the bidder for Package A.
3. BHEL has pre-fixed the Weightages / Factor as detailed above in this chapter for deriving the Unit Rates for the BOQ of each section. Considering these BHEL pre-fixed the Weightages / Factor and (w.r.t) the total sectional prices derived in sl no. 2 above; unit rate of individual items shall be derived. Unit Rate/Item Rate thus arrived shall be rounded off to two decimal places.
4. Grand total amount for the work shall be derived by BHEL by summing up respective total amounts which are obtained by multiplying respective item Quantities of individual item to the applicable rate per UOM (Unit rate as derived in sl no. 3 above) rounded off to Two decimal places.
5. Grand total amount thus derived shall be rounded off to zero decimal places and shall be considered for award of the work.
6. **Bidders to note that this is an item rate contract. Payment shall be made for the actual quantities of work executed at the unit rate arrived at as per SI No. 3 above.**
7. For the convenience of bidders, BHEL has issued an excel sheet with all the requisite formulae as described above. ***However the referred excel sheet shall not form part of contract document. Further, this sheet should not be uploaded at the e-Portal.***