

CLARIFICATION NO. 03 TO BIDDING DOCUMENTS (TECHNICAL PORTION)

S.No	SECTION	Sub SECTION	Clause No.	Page No.	Description	Bidder Comments	CLARIFICATION BY NTPC
1	SECTION - VI	PART – B, A-01	1.02.00(f)	1 of 2.	The plant should be able to supply upto 60% of the rated steam flow at 8 ata at the input of the vapour absorption chiller (Absorption chiller not in bidder's scope)	Kindly furnish the flow and condensate return	Condensate return flow will be the same(60% of the rated steam flow)
2	SECTION - VI	PART – B, A-06	1.01.00(xi)	1 of 28	Steam Extraction for heating/cooling/ industrial use Internally controlled extraction to provide up to 60% of the steam at the upstream of the extraction point to provide steam at 8 ata at the terminal point.	Kindly furnish Flow, Temperature , Condensate Return and Terminal Point.	Condensate return flow will be the same(60% of the rated steam flow). Temperature will be around 90 degree centigrade. However bidder to provide the area for VAM to be installed and terminal point will be the entry and exit of the same.