

EPC PACKAGE FOR WASTE TO ENERGY PROJECT (2X350 TPD) FOR KAWAS GAS POWER STATION

Bidding Document No.: CS-2600-001-9

AMENDMENT NO. 03 TO TECHNICAL SPECIFICATIONS (TS), SECTION-VI

SL. NO.	SPECIFICATION REFERENCE				Existing	Read as
	SEC/ PART	SUB SEC.	PAGE NO.	CLAUSE NO.		
1.	Part-A	IV	7 / 13	3.01.01	Vendor shall guarantee Maximum Aux. Power Consumption 14 % i.e. 2086 KW at Load point D in the firing Diagram (LPD)	Vendor shall guarantee Maximum Aux. Power Consumption 14 % of Gross Power at Generator terminal at Load point D' in the firing Diagram (LPD')